



IFP-SUMMARY							
ARRAY NAME	ARRAY CONFIG			NUMBER OF PV MODULES	KW DC	TYPE OF CP	NO. OF COLUMNS
	3	X	14				
A1	3	X	14	42	20.37	OT - STRUCTURE	2
A2	5	X	20	100	48.50	T - STRUCTURE	3
A3	5	X	20	100	48.50	T - STRUCTURE	3
B1	5	X	23	115	55.78	T - STRUCTURE	4
B2	5	X	23	115	55.78	T - STRUCTURE	3
B3	5	X	28	140	67.90	T - STRUCTURE	3
TOTAL				612	296.82		18

REDESIGN LAYOUT 1-SUMMARY							
ARRAY NAME	ARRAY CONFIG			NUMBER OF PV MODULES	KW DC	TYPE OF CP	NO. OF COLUMNS
	3	X	14				
A1	3	X	14	42	20.37	OT - STRUCTURE	2
A2	5	X	20	100	48.50	T - STRUCTURE	3
A3	5	X	20	100	48.50	T - STRUCTURE	3
A4	3	X	21	63	30.56	OT - STRUCTURE	3
B1	3	X	47	141	68.39	OT - STRUCTURE	5
B2	3	X	37	111	53.84	OT - STRUCTURE	4
B3	3	X	19	57	27.65	OT - STRUCTURE	3
TOTAL				614	297.79		23

1 PROPOSED LAYOUT
SCALE - 1/4" = 1'-0"



REGISTRATION
BAKER ELECTRIC, INC.
 1298 PACIFIC OAKS PL.
 ESCONDIDO, CA 92029
 (760) 745-2001
C10-161756
 EXP. 5/31/2024

**SAN PASQUAL USD
 PROPOSED LAYOUT
 15305 Rockwood Rd,
 Escondido, CA 92027**

LOWER LOT RELOCATION_LAYOUT 1

PROJECT TITLE

SHEET DESCRIPTION

REV BY	DATE	DESCRIPTION

PROJECT NUMBER
24619

DRAWN BY
KC

CHECKED BY

DATE
09/11/2024

REVISION
a.0

E-101