

SURE-BIOCHEM LABORATORIES, LLC

Attn: Lawnside Public School
426 Charleston Avenue
Lawnside, NJ 08045

08/09/21

The following analytical report covers the analysis performed on samples submitted to Sure-BioChem Laboratories, LLC on 07/06/21. The results are tabulated on the attached data pages for the following client designated project:

Lead in Drinking Water

The reference number for these samples is LPS1 070621-01. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact us at (888) 398-7247.

Reviewed and Approved By:



09Aug21

Laboratory Manager or Other Approved Signatory



1000 Atlantic Avenue
Camden, NJ 08104

PHONE (888) 398-7247
FAX (888) 603-5064
E-MAIL info@surebiochem.com
WEB SITE <http://www.surebiochem.com>



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

Attn: **Terry Henry**
Lawnside Public School
426 E. Charleston Avenue
Lawnside, NJ 08045

Phone: (856) 546-4850
Fax:
Received: 07/6/21 12:50 PM

Project: LPS1 070621-01

Analytical Results

Client Sample Description S22037
Main Office Sink
Collected: 7/6/2021
9:10:00 AM
Lab ID: 012107906-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	6.86	1.00 µg/L	7/27/2021 VD	07/27/21 16:54 VD
-------	------	------	-----------	--------------	-------------------

Client Sample Description S22038
Principal's Office
Collected: 7/6/2021
9:11:00 AM
Lab ID: 012107906-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	3.19	1.00 µg/L	7/27/2021 VD	07/27/21 17:07 VD
-------	------	------	-----------	--------------	-------------------

Client Sample Description S22039
CST Director Sink
Collected: 7/6/2021
9:13:00 AM
Lab ID: 012107906-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	10.2	1.00 µg/L	7/27/2021 VD	07/27/21 17:08 VD
-------	------	------	-----------	--------------	-------------------

Client Sample Description S22040
Nurse's Office
Collected: 7/6/2021
9:16:00 AM
Lab ID: 012107906-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.34	1.00 µg/L	7/27/2021 VD	07/27/21 17:10 VD
-------	------	------	-----------	--------------	-------------------

Client Sample Description S22041
Library Office Sink
Collected: 7/6/2021
9:34:00 AM
Lab ID: 012107906-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	2.42	1.00 µg/L	7/27/2021 VD	07/27/21 17:11 VD
-------	------	------	-----------	--------------	-------------------



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

Attn: **Terry Henry**
Lawnside Public School
1426 E. Charleston Avenue
Lawnside, NJ 08045

Phone: (856) 546-4850
Fax:
Received: 07/6/21 12:50 PM

Project: LPS1 070621-01

Analytical Results

Client Sample Description S22042
Gym Sink #1
Collected: 7/6/2021
9:38:00 AM
Lab ID: 012107906-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.59	1.00 µg/L	7/27/2021 VD	07/27/21 17:13 VD

Client Sample Description S22043
Gym Sink #2
Collected: 7/6/2021
9:38:00 AM
Lab ID: 012107906-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.99	1.00 µg/L	7/27/2021 VD	07/27/21 17:15 VD

Client Sample Description S22044
Media Center Hallway Sink #1
Collected: 7/6/2021
9:19:00 AM
Lab ID: 012107906-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/27/2021 VD	07/27/21 17:16 VD

Client Sample Description S22045
Media Center Hallway Front Entrance Sink #1
Collected: 7/6/2021
9:19:00 AM
Lab ID: 012107906-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/27/2021 VD	07/27/21 17:18 VD

Client Sample Description S22046
Kitchen Sink #1
Collected: 7/6/2021
9:40:00 AM
Lab ID: 012107906-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.57	1.00 µg/L	7/27/2021 VD	07/27/21 17:19 VD



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

Attn: **Terry Henry**
Lawnside Public School
426 E. Charleston Avenue
Lawnside, NJ 08045

Phone: (856) 546-4850
Fax:
Received: 07/6/21 12:50 PM

Project: LPS1 070621-01

Analytical Results

Client Sample Description S22047 Kitchen Sink Left Side Main Area
Collected: 7/6/2021 9:44:00 AM
Lab ID: 012107906-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/27/2021 VD	07/27/21 17:21 VD

Client Sample Description S22048 Kitchen Sink Center of Room
Collected: 7/6/2021 9:41:00 AM
Lab ID: 012107906-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.19	1.00 µg/L	7/27/2021 VD	07/27/21 17:29 VD

Client Sample Description S22049 Kitchen Sink Right Side Main Area
Collected: 7/6/2021 9:45:00 AM
Lab ID: 012107906-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.84	1.00 µg/L	7/27/2021 VD	07/27/21 17:30 VD

Client Sample Description S22050 Staff Lounge Cooler
Collected: 7/6/2021 9:27:00 AM
Lab ID: 012107906-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/27/2021 VD	07/27/21 17:32 VD

Client Sample Description S22051 Staff Lounge Bathroom Sink #1
Collected: 7/6/2021 9:29:00 AM
Lab ID: 012107906-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.03	1.00 µg/L	7/27/2021 VD	07/27/21 17:33 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

Attn: **Terry Henry**
Lawnside Public School
426 E. Charleston Avenue
Lawnside, NJ 08045

Phone: (856) 546-4850
 Fax:
 Received: 07/6/21 12:50 PM

Project: LPS1 070621-01

Analytical Results

Client Sample Description S22052
 Staff Lounge Bathroom Sink #2
Collected: 7/6/2021
 9:31:00 AM
Lab ID: 012107906-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	7/27/2021 VD	07/27/21 17:35 VD
-------	------	----	-----------	--------------	-------------------

Client Sample Description S22053
 Staff Lounge Main Area Sink
Collected: 7/6/2021
 9:28:00 AM
Lab ID: 012107906-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	7/27/2021 VD	07/27/21 17:36 VD
-------	------	----	-----------	--------------	-------------------

Client Sample Description S22054
 Girl's Bathroom Front Entrance
Collected: 7/6/2021
 9:18:00 AM
Lab ID: 012107906-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	5.56	1.00 µg/L	7/27/2021 VD	07/27/21 17:38 VD
-------	------	------	-----------	--------------	-------------------

Client Sample Description S22055
 Boy's Bathroom Front Entrance Media Center Hallway
Collected: 7/6/2021
 9:24:00 AM
Lab ID: 012107906-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	2.15	1.00 µg/L	7/27/2021 VD	07/27/21 17:39 VD
-------	------	------	-----------	--------------	-------------------

Client Sample Description S22056
 Art Room Sink #1
Collected: 7/6/2021
 9:54:00 AM
Lab ID: 012107906-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	2.40	1.00 µg/L	7/27/2021 VD	07/28/21 8:43 VD
-------	------	------	-----------	--------------	------------------



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

Attn: **Terry Henry**
Lawnside Public School
426 E. Charleston Avenue
Lawnside, NJ 08045

Phone: (856) 546-4850
Fax:
Received: 07/6/21 12:50 PM

Project: LPS1 070621-01

Analytical Results

Client Sample Description S22057
Custodial Closet #1
Collected: 7/6/2021
9:23:00 AM
Lab ID: 012107906-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	45.0	1.00 µg/L	7/21/2021 IC	07/22/21 19:42 JW
-------	------	------	-----------	--------------	-------------------

Client Sample Description S22058
Boy's Locker Room Office
Collected: 7/6/2021
9:47:00 AM
Lab ID: 012107906-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	7.28	1.00 µg/L	7/27/2021 VD	07/28/21 21:34 VD
-------	------	------	-----------	--------------	-------------------

Client Sample Description S22059
Boy's Locker Room Bathroom Sink #1
Collected: 7/6/2021
9:48:00 AM
Lab ID: 012107906-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	6.10	1.00 µg/L	7/27/2021 VD	07/28/21 21:36 VD
-------	------	------	-----------	--------------	-------------------

Client Sample Description S22060
Boy's Locker Room Bathroom Sink #2
Collected: 7/6/2021
9:49:00 AM
Lab ID: 012107906-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	28.7	1.00 µg/L	7/21/2021 IC	07/22/21 19:44 JW
-------	------	------	-----------	--------------	-------------------

Client Sample Description S22061
Girl's Locker Room Office
Collected: 7/6/2021
9:50:00 AM
Lab ID: 012107906-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	10.2	1.00 µg/L	7/27/2021 VD	07/28/21 21:37 VD
-------	------	------	-----------	--------------	-------------------



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

Attn: **Terry Henry**
Lawnside Public School
426 E. Charleston Avenue
Lawnside, NJ 08045

Phone: (856) 546-4850
Fax:
Received: 07/6/21 12:50 PM

Project: LPS1 070621-01

Analytical Results

Client Sample Description S22062
Girl's Locker Room Bathroom Sink #1
Collected: 7/6/2021 9:52:00 AM
Lab ID: 012107906-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	72.0	1.00 µg/L	7/21/2021 IC	07/22/21 19:47 JW
-------	------	------	-----------	--------------	-------------------

Client Sample Description S22063
Girl's Locker Room Bathroom Sink #2
Collected: 7/6/2021 9:53:00 AM
Lab ID: 012107906-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	226 D	5.00 µg/L	7/21/2021 IC	07/22/21 20:29 JW
-------	------	-------	-----------	--------------	-------------------

Client Sample Description S22064
Lower Grade Water Fountain
Collected: 7/6/2021 10:05:00 AM
Lab ID: 012107906-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	16.7	1.00 µg/L	7/27/2021 VD	07/28/21 21:39 VD
-------	------	------	-----------	--------------	-------------------

Client Sample Description S22065
Upper Grade Sink #1
Collected: 7/6/2021 9:17:00 AM
Lab ID: 012107906-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	7/27/2021 VD	07/28/21 21:40 VD
-------	------	----	-----------	--------------	-------------------

Client Sample Description S22066
Upper Grade Sink #2
Collected: 7/6/2021 9:14:00 AM
Lab ID: 012107906-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	7/27/2021 VD	07/28/21 21:48 VD
-------	------	----	-----------	--------------	-------------------



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

Attn: **Terry Henry**
Lawnside Public School
426 E. Charleston Avenue
Lawnside, NJ 08045

Phone: (856) 546-4850
Fax:
Received: 07/6/21 12:50 PM

Project: LPS1 070621-01

Analytical Results

Client Sample Description S22067
Upper Grade Sink #3
Collected: 7/6/2021
9:15:00 AM
Lab ID: 012107906-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	7/27/2021 VD	07/28/21 21:50 VD
-------	------	----	-----------	--------------	-------------------

Client Sample Description S22068
Middle Grade Hallway Water Fountain
Collected: 7/6/2021
9:59:00 AM
Lab ID: 012107906-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	7/27/2021 VD	07/28/21 21:51 VD
-------	------	----	-----------	--------------	-------------------

Client Sample Description S22069
Middle Grade Water Fountain
Collected: 7/6/2021
10:00:00 AM
Lab ID: 012107906-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	7/27/2021 VD	07/28/21 21:53 VD
-------	------	----	-----------	--------------	-------------------

Client Sample Description S22070
Room 121
Collected: 7/6/2021
10:02:00 AM
Lab ID: 012107906-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	7/27/2021 VD	07/28/21 21:54 VD
-------	------	----	-----------	--------------	-------------------

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results