Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : Cherry Hill BOE #6503

PAS Project ID : P17-0269

Matrix : Drinking Water

Report Date : 01/25/17

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0269-01	CH50-A-1-ICE-03A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:10	1/23/17 15:08
P17-0269-02	CH50-A-1-S-02A	Lead	0.888 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:11	1/23/17 15:44
P17-0269-03	CH50-A-1-WC-01A	Lead	**19.2**	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	1/16/17 10:14	1/23/17 16:27
P17-0269-04	CH50-B-1-S-04A	Lead	5.04	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:18	1/23/17 16:01
P17-0269-05	CH50-B-1-S-05A	Lead	**18.8**	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	1/16/17 10:20	1/23/17 16:31
P17-0269-06	CH50-B-1-WC-06A	Lead	0.0571 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:22	1/23/17 16:35
P17-0269-07	CH50-B-1-S-07A	Lead	2.14	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:24	1/23/17 16:40
P17-0269-08	CH50-EG-WC-20A	Lead	0.265 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:27	1/23/17 16:44
P17-0269-09	CH50-EG-WC-19A	Lead	0.265 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:28	1/23/17 16:48
P17-0269-10	CH50-EG-BFS-21A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:33	1/23/17 16:52
P17-0269-11	CH50-EG-WC-80A	Lead	0.0571 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:33	1/23/17 16:56
P17-0269-12	CH50-EG-WF-18A	Lead	**19.3**	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	1/16/17 10:36	1/24/17 11:19
P17-0269-13	CH50-EG-WF-22A	Lead	**99.2**	ug/L	10	20.0	4.62	15.0 *	SM 3113 B	1/16/17 10:38	1/24/17 12:04
P17-0269-14	CH50-F-1-WF-26A	Lead	0.649 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:42	1/24/17 12:17
P17-0269-15	CH50-F-1-WF-25A	Lead	**24.6**	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	1/16/17 10:46	1/24/17 13:24
P17-0269-16	CH50-F-1-WF-24A	Lead	1.71 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:50	1/24/17 12:25
P17-0269-17	CH50-F-1-WF-27A	Lead	0.649 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:53	1/24/17 12:29
P17-0269-18	CH50-F-1-WF-23A	Lead	1.44 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:55	1/24/17 12:33
P17-0269-19	CH50-F-1-WF-28A	Lead	7.27	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:57	1/24/17 12:38
P17-0269-20	CH50-F-1-WF-59A	Lead	2.24	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:00	1/24/17 13:20
P17-0269-21	CH50-F-1-WF-58A	Lead	1.13 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:03	1/23/17 12:47
P17-0269-22	CH50-F-1-S-57A	Lead	14.7	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:06	1/23/17 12:56
P17-0269-23	CH50-F-1-S-55A	Lead	6.51	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:17	1/23/17 13:08
P17-0269-24	CH50-F-1-S-56A	Lead	6.77	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:16	1/23/17 13:12
P17-0269-25	CH50-F-1-S-50A	Lead	7.03	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:16	1/23/17 13:16
P17-0269-26	CH50-F-1-S-53A	Lead	14.7	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:15	1/23/17 13:44
P17-0269-27	CH50-F-1-S-51A	Lead	0.103 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:13	1/23/17 13:48
P17-0269-28	CH50-F-1-S-54A	Lead	5.74	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:15	1/23/17 13:52
P17-0269-29	CH50-F-1-S-52A	Lead	4.21	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:13	1/23/17 13:56
P17-0269-30	CH50-F-1-S-49A	Lead	3.44	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:20	1/23/17 14:00
P17-0269-31	CH50-E-1-S-44A	Lead	0.359 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:28	1/23/17 14:05
P17-0269-32	CH50-E-1-S-45A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:29	1/23/17 14:09
P17-0269-33	CH50-E-1-S-43A	Lead	1.64 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:32	1/23/17 14:22
P17-0269-34	CH50-E-1-S-42A	Lead	4.72	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:37	1/23/17 14:26
P17-0269-35	CH50-E-1-S-41A	Lead	1.13 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:39	1/23/17 14:31
P17-0269-36	CH50-E-1-S-40A	Lead	3.69	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:41	1/23/17 14:35
P17-0269-37	CH50-E-1-S-38A	Lead	0.359 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:44	1/23/17 14:40
P17-0269-38	CH50-E-1-S-37A	Lead	1.90 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:45	1/23/17 14:44
P17-0269-39	CH50-E-1-S-35A	Lead	1.13 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:48	1/23/17 14:48
P17-0269-40	CH50-E-1-S-31A	Lead	1.90 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:49	1/23/17 14:53
P17-0269-41	CH50-E-1-S-32A	Lead	1.38 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:52	1/23/17 14:57
P17-0269-42	CH50-E-1-S-33A	Lead	**23.8**	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	1/16/17 11:54	1/23/17 16:09
P17-0269-43	CH50-E-1-S-36A	Lead	2.41	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 11:56	1/23/17 15:32
P17-0269-44	CH50-E-1-ICE-47A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:00	1/23/17 15:37
P17-0269-45	CH50-E-1-S-46A	Lead	2.92	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:02	1/23/17 15:41
P17-0269-46	CH50-E-1-CM-81A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:04	1/23/17 15:45
P17-0269-47	CH50-E-1-CM-82A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:04	1/23/17 15:49

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
B = Compound found in blank and samples
E = Concentration exceeds calibration range
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : Cherry Hill BOE #6503

PAS Project ID : P17-0269

Matrix : Drinking Water

Report Date : 01/25/17

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0269-48	CH50-EV-BFS-29A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:13	1/23/17 16:22
P17-0269-49	CH50-EV-WC-83A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:12	1/23/17 16:26
P17-0269-50	CH50-AUD-1-WC-62A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:16	1/23/17 16:30
P17-0269-51	CH50-AUD-1-WC-63A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:16	1/23/17 16:34
P17-0269-52	CH50-D-1-WF-61A	Lead	1.13 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:18	1/23/17 16:38
P17-0269-53	CH50-D-1-WC-60A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:20	1/23/17 16:43
P17-0269-54	CH50-C-1-S-70A	Lead	13.4	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:24	1/24/17 13:28
P17-0269-55	CH50-C-1-S-10A	Lead	3.03	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:26	1/24/17 13:33
P17-0269-56	CH50-C-1-WC-11A	Lead	0.119 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:28	1/24/17 13:37
P17-0269-57	CH50-C-1-WC-12A	Lead	0.384 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:29	1/24/17 13:41
P17-0269-58	CH50-C-2-WC-13A	Lead	0.119 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:33	1/24/17 13:46
P17-0269-59	CH50-C-2-S-14A	Lead	2.24	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:35	1/24/17 13:50
P17-0269-60	CH50-B-2-WC-08A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:38	1/24/17 13:54
P17-0269-61	CH50-B-2-S-09A	Lead	2.50	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:40	1/24/17 14:07
P17-0269-62	CH50-C-3-S-15A	Lead	3.83	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:46	1/24/17 14:12
P17-0269-63	CH50-C-3-WC-16A	Lead	0.384 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:48	1/24/17 14:16
P17-0269-64	CH50-C-3-WC-17A	Lead	0.384 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:49	1/24/17 14:21
P17-0269-65	CH50-G-1-WF-64A	Lead	0.914 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:56	1/24/17 14:25
P17-0269-66	CH50-G-B-WF-65A	Lead	8.86	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 13:03	1/24/17 14:34
P17-0269-67	CH50-C-B-WC-67A	Lead	**18.3**	ug/L	2	4.00	0.924	15.0 *	SM 3113 B	1/16/17 13:08	1/24/17 15:47
P17-0269-68	CH50-G-B-WF-66A	Lead	0.914 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 13:16	1/24/17 14:59
P17-0269-69	CH50-G-B-ICE-68A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 13:20	1/24/17 15:03
P17-0269-70	CH50-G-B-S-69A	Lead	2.24	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 13:21	1/24/17 15:07
P17-0269-71	CH50-1-16-FBA	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 13:23	1/24/17 15:12
P17-0269-72	CH55-1-A-CM-17A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 08:20	1/24/17 15:16
P17-0269-73	CH55-1-A-ICE-01A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 08:25	1/24/17 15:20
P17-0269-74	CH55-1-16-FBA	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 08:27	1/24/17 15:24
P17-0269-75	CH86-OS-WC-02A	Lead	5.68	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 08:50	1/24/17 15:28
P17-0269-76	CH86-OS-S-01A	Lead	3.03	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 08:53	1/24/17 15:52
P17-0269-77	CH86-OS-S-03A	Lead	0.119 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 08:56	1/24/17 15:56
P17-0269-78	CH86-IT-WC-05A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:10	1/24/17 16:00
P17-0269-79	CH86-IT-S-04A	Lead	0.119 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:12	1/24/17 16:05
P17-0269-80	CH86-1-1G-FBA	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:13	1/24/17 16:09
P17-0269-81	CH55-1-F-S-06A	Lead	1.59 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 07:19	1/24/17 11:41
P17-0269-82	CH55-1-F-ICE-07A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 07:22	1/24/17 12:02
P17-0269-83	CH55-1-F-WC-09A	Lead	0.400 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 07:25	1/24/17 12:06
P17-0269-84	CH55-1-F-WC-08A	Lead	14.3	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 07:27	1/24/17 12:10
P17-0269-85	CH55-1-FG-ICE-10A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 07:29	1/24/17 12:14
P17-0269-86	CH55-1-FG-ICE-11A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 07:33	1/24/17 12:18
P17-0269-87	CH55-G-F-S-12A	Lead	1.14 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 07:34	1/24/17 12:23
P17-0269-88	CH55-G-F-WC-13A	Lead	0.104 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 07:38	1/24/17 12:27
P17-0269-89	CH55-G-F-WC-14A	Lead	0.252 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 07:39	1/24/17 12:31
P17-0269-90	CH55-H-ICE-05A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 08:06	1/24/17 12:44
P17-0269-91	CH55-1-A-S-02A	Lead	1.44 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 08:10	1/24/17 12:49
P17-0269-92	CH55-1-A-ICE-04A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 08:13	1/24/17 12:53
P17-0269-93	CH55-1-A-ICE-03A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 08:15	1/24/17 12:57
P17-0269-94	CH55-1-A-F-15A	Lead	0.104 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 08:17	1/24/17 13:02

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
B = Compound found in blank and samples
E = Concentration exceeds calibration range
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol



Mark D. Feitelson, Lab. Director

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ

Project ID : Cherry Hill BOE #6503

PAS Project ID : P17-0269

Matrix : Drinking Water

Report Date : 01/25/17

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0269-95	CH55-1-A-CM-16A	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:19	1/24/17 13:06
P17-0269-96	CH50-E-1-S-30A	Lead	7.36	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 12:07	1/24/17 13:10

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
B = Compound found in blank and samples
E = Concentration exceeds calibration range
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director