

Seaford Union Free School District

19-45336

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Seaford Middle School							
SUFSD-0428	3023	Girl's Bathroom	Bathroom Faucet	Non-Potable	1/15/2021	340	Placarded for Non-Drinking Use Until Remediated
SUFSD-0426	3023	Girl's Bathroom	Bathroom Faucet	Non-Potable	1/15/2021	150	Placarded for Non-Drinking Use Until Remediated
SUFSD-0388	2073	Auditorium I	Water Fountain-No Chiller	Potable	1/15/2021	27	Removed From Service, Pending Remediation
SUFSD-0355	2057	Connected to Rm 101	Classroom Faucet	Non-Potable	1/15/2021	23	Placarded for Non-Drinking Use Until Remediated
SUFSD-0288	2094	Room 231	Bathroom Faucet	Non-Potable	1/15/2021	18	Placarded for Non-Drinking Use Until Remediated
SUFSD-0265	2119	Kitchen	Spray Nozzle	Non-Potable	1/15/2021	50	Placarded for Non-Drinking Use Until Remediated
SUFSD-0264	2119	Kitchen	Kitchen Faucet (Cold)	Non-Potable	1/15/2021	19	Placarded for Non-Drinking Use Until Remediated
SUFSD-0259	2121	Kitchen Serving Area	Hand Wash Only	Non-Potable	1/15/2021	18	Placarded for Non-Drinking Use Until Remediated

Seaford Union Free School District

19-45336

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Seaford High School							
SUFSD-0146	2046	Boy's Locker Room	Bathroom Faucet	Non-Potable	1/14/2021	23	Placarded for Non-Drinking Use Until Remediated
SUFSD-0144	2046	Boy's Locker Room	Bathroom Faucet	Non-Potable	1/14/2021	46	Placarded for Non-Drinking Use Until Remediated
SUFSD-0140	2077	Girl's Locker Room	Bathroom Faucet	Non-Potable	1/14/2021	51	Placarded for Non-Drinking Use Until Remediated
SUFSD-0138	2077	Girl's Locker Room	Bathroom Faucet	Non-Potable	1/14/2021	20	Placarded for Non-Drinking Use Until Remediated
SUFSD-0070	2082	Kitchen	Kitchen Faucet (Cold)	Non-Potable	1/14/2021	24	Placarded for Non-Drinking Use Until Remediated
SUFSD-0068	2082	Serving Area Left	Hand Wash Only	Non-Potable	1/14/2021	16	Placarded for Non-Drinking Use Until Remediated
SUFSD-0045	2125	Boy's Bathroom	Bathroom Faucet	Non-Potable	1/14/2021	18	Placarded for Non-Drinking Use Until Remediated
SUFSD-0025	2161	Room 102	Water Fountain-No Chiller	Potable	1/14/2021	36	Removed From Service, Pending Remediation

Seaford Union Free School District

19-45336

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Seaford Manor Elementary School							
SUFSD-0563	2114	Kitchen	Pasta Pot/Steam Kettle	Potable	1/20/2021	16	Removed From Service, Pending Remediation
SUFSD-0552	2023	Room 21B	Water Fountain-No Chiller	Potable	1/20/2021	23	Removed From Service, Pending Remediation
SUFSD-0467	2010	Room 28C	Water Fountain-No Chiller	Potable	1/20/2021	24	Removed From Service, Pending Remediation
SUFSD-0465	2008	Room 30C	Water Fountain-No Chiller	Potable	1/20/2021	57	Removed From Service, Pending Remediation