



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : #8970 North Arlington, North Arlington HS, 222 Ridge Rd, North Arlington, NJ 07301

PAS Project ID : P24-08636

Matrix : Drinking Water

Report Date : 8/20/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-08636-01	NAHS-1-S-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:30	8/12/24 10:32
P24-08636-02	NAHS-1-DS-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:30	8/12/24 10:36
P24-08636-03	NAHS-1-S-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:33	8/12/24 10:40
P24-08636-04	NAHS-1-S-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:34	8/12/24 10:44
P24-08636-05	NAHS-1-IM-01	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:36	8/12/24 10:56
P24-08636-06	NAHS-1-S-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:37	8/12/24 11:00
P24-08636-07	NAHS-1-PF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:39	8/12/24 11:04
P24-08636-08	NAHS-1-WC-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:42	8/12/24 11:09
P24-08636-09	NAHS-1-BF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:42	8/12/24 11:13
P24-08636-10	NAHS-1-WC-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:46	8/12/24 11:17
P24-08636-11	NAHS-1-BF-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:46	8/12/24 11:21
P24-08636-12	NAHS-1-BF-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:48	8/12/24 11:25
P24-08636-13	NAHS-1-WC-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:51	8/12/24 11:29
P24-08636-14	NAHS-1-BF-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:52	8/12/24 11:45
P24-08636-15	NAHS-1-S-15A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/1/24 02:57	8/12/24 11:57
P24-08636-16	NAHS-1-S-08A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 02:59	8/12/24 12:01
P24-08636-17	NAHS-1-DH-02A	Lead	3.88	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:00	8/12/24 12:13
P24-08636-18	NAHS-1-S-07A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:02	8/12/24 12:37
P24-08636-19	NAHS-1-S-06A	Lead	2.41	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:04	8/12/24 12:41
P24-08636-20	NAHS-1-S-09A	Lead	49.0	ug/L	5	10.0	4.50	15.0 *	SM 3113 B	8/1/24 03:14	8/12/24 13:12
P24-08636-21	NAHS-1-B-01A	Lead	1.42 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:13	8/12/24 12:49
P24-08636-22	NAHS-1-DH-04A	Lead	4.62	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:14	8/12/24 12:53
P24-08636-23	NAHS-1-S-10A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:19	8/12/24 13:16
P24-08636-24	NAHS-1-DH-05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:20	8/12/24 13:20
P24-08636-25	NAHS-1-S-11A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:23	8/12/24 13:24
P24-08636-26	NAHS-1-DH-06A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:23	8/12/24 13:28
P24-08636-27	NAHS-1-S-05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:28	8/12/24 13:31
P24-08636-28	NAHS-2-WC-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:32	8/12/24 13:35
P24-08636-29	NAHS-2-WC-06A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:35	8/12/24 13:39
P24-08636-30	NAHS-3-WC-05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 03:39	8/12/24 13:43
P24-08636-31	NAHS-8-2-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 00:00	8/12/24 13:55

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: #8970 North Arlington: North Arlington HS
School Address: 222 Ridge Road, North Arlington, NJ 07301
Sampled By: Frank Obando
Print Name: Frank Obando
RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 8/2/2024 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Container s	Glass or Plastic	Analysis	LAB ID
NAHS-1-S-01A; Kitchen Rear Left	2:30pm	DW	Grab			1	250 ml Plastic	Lead	p24-0862601
NAHS-1-DS-01A; Kitchen Rear Left	2:30pm	DW	Grab			1	250 ml Plastic	Lead	02
NAHS-1-S-02A; Kitchen Rear Center	2:33pm	DW	Grab			1	250 ml Plastic	Lead	03
NAHS-1-S-03A; Kitchen Rear Right	2:34pm	DW	Grab			1	250 ml Plastic	Lead	04
NAHS-1-IM-01; Kitchen Rear	2:36pm	DW	Grab		y	1	250 ml Plastic	Lead	05
NAHS-1-S-04A; Kitchen Center Island	2:37pm	DW	Grab			1	250 ml Plastic	Lead	06
NAHS-1-PF-01A; Kitchen Center	2:39pm	DW	Grab			1	250 ml Plastic	Lead	07
NAHS-1-WC-01A; Cafeteria	2:42pm	DW	Grab		y	1	250 ml Plastic	Lead	08
NAHS-1-BF-01A; Cafeteria	2:42pm	DW	Grab		y	1	250 ml Plastic	Lead	09
NAHS-1-WC-02A; Hall Outside Cafeteria	2:46pm	DW	Grab		y	1	250 ml Plastic	Lead	10
NAHS-1-BF-02A; Hall Outside Cafeteria	2:46pm	DW	Grab		y	1	250 ml Plastic	Lead	11
NAHS-1-BF-04A; Weight Room	2:48pm	DW	Grab		y	1	250 ml Plastic	Lead	12
NAHS-1-WC-03A; Boy's Locker Room	2:51pm	DW	Grab		y	1	250 ml Plastic	Lead	13
NAHS-1-BF-03A; Boy's Locker Room	2:52pm	DW	Grab		y	1	250 ml Plastic	Lead	14
NAHS-1-S-15A; Room 110 Sink #1	2:57pm	DW	Grab			1	250 ml Plastic	Lead	15

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

PDF Std. PDF Reduce PDF Full EDD

Date/Time
Preserved with
HPLC

Page 1 of 3

Deliverables:

X

**MATRIX
CODES:**

GW = Ground Water, WW = Waste Water, SW = Surface Water,
DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge,
B = Blank, K = Solid (specify):

**PRESERVATION
VE
CODES:** 0 = Ice 1 = HCl
2 = H2SO4 3 = NaOH
4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Tara Ekiert	Tara Ekiert	GSE, Inc.	8/6/2024 @ 12:23pm
Received:	Rory Hargis	Rory Hargis	PAS	8/7/24 11:27
Relinquished:	Rory Hargis	Rory Hargis	PAS	8/7/24 16:44
Received:	Paul Mathews	Paul Mathews		8/9/24 11:40
Relinquished:				
Received:				

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: #8970 North Arlington: North Arlington HS

School Address: 222 Ridge Road, North Arlington, NJ 07301

Sampled By: Frank Obando

Print Name: Frank Obando

RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 8/2/2024 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Container s	Glass or Plastic	Analysis	LAB ID
NAHS-1-S-08A; Room 110 Sink #2	2:59pm	DW	Grab			1	250 ml Plastic	Lead	12
NAHS-1-DH-02A; Room 110 Sink #2	3:00pm	DW	Grab			1	250 ml Plastic	Lead	17
NAHS-1-S-07A; Room 110 Sink #3	3:02pm	DW	Grab			1	250 ml Plastic	Lead	18
NAHS-1-S-06A; Room 110 Sink #4	3:04pm	DW	Grab			1	250 ml Plastic	Lead	19
NAHS-1-S-09A; Nurse's Office	3:14pm	DW	Grab			1	250 ml Plastic	Lead	20
NAHS-1-B-01A; Nurse's Office	3:13pm	DW	Grab			1	250 ml Plastic	Lead	21
NAHS-1-DH-04A; Nurse's Office	3:14pm	DW	Grab			1	250 ml Plastic	Lead	22
NAHS-1-S-10A; Superintendent's Office	3:19pm	DW	Grab			1	250 ml Plastic	Lead	23
NAHS-1-DH-05A; Superintendent's Office	3:20pm	DW	Grab			1	250 ml Plastic	Lead	24
NAHS-1-S-11A; BOE Office	3:23pm	DW	Grab			1	250 ml Plastic	Lead	25
NAHS-1-DH-06A; BOE Office	3:23pm	DW	Grab			1	250 ml Plastic	Lead	26
NAHS-1-S-05A; Room 110 Sink #5	3:28pm	DW	Grab			1	250 ml Plastic	Lead	27
NAHS-2-WC-04A; Hall Near Room 211	3:32pm	DW	Grab		y	1	250 ml Plastic	Lead	28
NAHS-2-WC-06A; Hall Near Room 219	3:35pm	DW	Grab		y	1	250 ml Plastic	Lead	29
NAHS-3-WC-05A; Hall Near Room 310	3:39pm	DW	Grab		y	1	250 ml Plastic	Lead	30

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 2 of 3

Deliverables: PDF Std. X PDF Reduce PDF Full EDD Date/Time Preserved with: (H)(+)

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Tara Ekiert	Tara Ekiert	GSE, Inc.	8/6/2024 @ 12:23pm
Received:	Rory Hedges	Rory Hedges	GSE	8/7/24 11:27
Relinquished:	Rory Hedges	Rory Hedges	GSE	8/7/24 16:02
Received:				
Relinquished:				
Received:				

Customer: Garden State Environmental
Address: 555 S. Broad St
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: #8970 North Arlington: North Arlington HS
School Address: 222 Ridge Road, North Arlington, NJ 07301
Sampled By: Frank Obando
Print Name: Frank Obando
RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 8/2/2024 Time Sampled	Matrix Code	Grab or Comp	Flux Sample	Filter Present	# Container #	Glass or Plastic	Analysis	LAB ID
NAHS-8-2-FBA; Field Blank	NA	DW	Grab			1	250 ml Plastic	Lead	P-1111-1000 21
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 3 of 3

Deliverables: PDF Std. X PDF Reduce PDF Full EDD Date/Time Preserved with HNO3:

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Tara Ekiert	Tara Ekiert	GSE, Inc.	8/6/2024 @ 12:23pm
Received:	Perry Hodges	Perry Hodges	OAS	8/7/24 1127
Relinquished:	Perry Hodges	Perry Hodges	PKS	8/7/24 1604
Received:				
Relinquished:				
Received:				



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : #8970 North Arlington, Frank Roosevelt ES, 50 Webster St, North Arlington, NJ 07301

PAS Project ID : P24-08632

Matrix : Drinking Water

Report Date : 8/21/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-08632-01	NAFR-1-S-01A	Lead	1.32 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 01:21	8/13/24 13:02
P24-08632-02	NAFR-1-SP-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 01:21	8/13/24 13:06
P24-08632-03	NAFR-1-WC-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 01:25	8/13/24 13:24
P24-08632-04	NAFR-1-BF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 01:25	8/13/24 13:28
P24-08632-05	NAFR-1-WC-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 01:30	8/13/24 13:32
P24-08632-06	NAFR-1-WC-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 01:30	8/13/24 13:36
P24-08632-07	NAFR-1-BF-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 01:30	8/13/24 13:40
P24-08632-08	NAFR-8-2-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 00:00	8/13/24 13:44

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: #8970 North Arlington: Franklin Roosevelt ES
School Address: 50 Webster Street, North Arlington, NJ 07301
Sampled By: Frank Obando
Print Name: Frank Obando
RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 8/2/2024 Time Sampled	Matrix Code	Grab or Comp	Fluor Sample	Filter Percent	# Container s	Glass or Plastic	Analysis	LAB ID
NAFR-1-S-01A; Faculty Room	1:21pm	DW	Grab			1	250 ml Plastic	Lead	024-0305
NAFR-1-SP-01A; Faculty Room	1:21pm	DW	Grab			1	250 ml Plastic	Lead	
NAFR-1-WC-01A; Next to Main Office	1:25pm	DW	Grab		y	1	250 ml Plastic	Lead	
NAFR-1-BF-01A; Next to Main Office	1:25pm	DW	Grab		y	1	250 ml Plastic	Lead	
NAFR-1-WC-02A; Next to Gym, Right	1:30pm	DW	Grab		y	1	250 ml Plastic	Lead	
NAFR-1-WC-03A; Next to Gym, Left	1:30pm	DW	Grab		y	1	250 ml Plastic	Lead	
NAFR-1-BF-02A; Next to Gym, Left	1:30pm	DW	Grab		y	1	250 ml Plastic	Lead	
NAFR-8-2-FBA; Field Blank	NA	DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

PDF Std. PDF Reduce PDF Full EDD

Date/Time
Preserved with
(HCl)

8/8/24
16:55

Page 1 of

Deliverables:

MATRIX CODES:
GW = Ground Water, WW = Waste Water, SW = Surface Water,
DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge,
B = Blank, K = Solid (specify):

PRESERVATIVE CODES:
0 = Ice 1 = HCl
2 = H2SO4 3 = NaOH
4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Tara Ekiert	Tara Ekiert	GSE, Inc.	8/6/2024 @ 12:17pm
Received:	Remy Hoopes	Remy Hoopes	PAS	8/6/24 1127
Relinquished:	Remy Hoopes	Remy Hoopes	PAS	8/7/24 1044
Received:	Kate Matthews	K. Matthews		8/9/24 11am
Relinquished:				
Received:				



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : #8970 North Arlington, North Arlington Field House, 155 River Rd, North Arlington, NJ 07301

PAS Project ID : P24-08635

Matrix : Drinking Water

Report Date : 8/20/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-08635-01	NAFH-WC-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 07:32	8/12/24 09:44
P24-08635-02	NAFH-S-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 07:36	8/12/24 10:00
P24-08635-03	NAFH-SP-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 07:36	8/12/24 10:12
P24-08635-04	NAFH-IM-02	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 07:45	8/12/24 10:16
P24-08635-05	NAFH-SP-02A	Lead	2.41	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 07:50	8/12/24 10:20
P24-08635-06	NAFH-S-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 07:50	8/12/24 10:24
P24-08635-07	NAFH-8-2-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 00:00	8/12/24 10:28

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: #8970 North Arlington: North Arlington Field House
School Address: 155 River Road, North Arlington, NJ 07301
Sampled By: Frank Obando
Print Name: Frank Obando
RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 8/2/2024 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Fiber Present	# Container s	Glass or Plastic	Analysis	LAB ID
NAFH-WC-02A; Outside LR, Right	7:32pm	DW	Grab		y	1	250 ml Plastic	Lead	724-082-41
NAFH-S-01A; Kitchen/Concession Stand	7:36pm	DW	Grab			1	250 ml Plastic	Lead	127
NAFH-SP-01A; Kitchen/Concession Stand	7:36pm	DW	Grab			1	250 ml Plastic	Lead	012
NAFH-IM-02; Storage Room	7:45pm	DW	Grab		y	1	250 ml Plastic	Lead	014
NAFH-SP-02A; Storage Room	7:50pm	DW	Grab			1	250 ml Plastic	Lead	015
NAFH-S-02A; Storage Room	7:50pm	DW	Grab			1	250 ml Plastic	Lead	016
NAFH-8-2-FBA; Field Blank	NA	DW	Grab			1	250 ml Plastic	Lead	017
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

PDF Std. PDF Reduce PDF Full EDD
Deliverables: X

Page 1 of 1

MATRIX CODES:
GW = Ground Water, WW = Waste Water, SW = Surface Water,
DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge,
B = Blank, K = Solid (specify):

PRESERVATION CODES:
0 = Ice 1 = HCl
2 = H2SO4 3 = NaOH
4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Tara Ekiert	Tara Ekiert	GSE, Inc.	8/6/2024 @ 12:55pm
Received:	Terry Harrison	Terry Harrison	PAS	8/7/24 11:21
Relinquished:			PAS	+ 8/7/24 16:00
Received:				
Relinquished:	Kate Matthews	K. Matthews		8/9/24 11:00am
Received:				



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : # 8970 North Arlington, Susan B Anthony ES, 45 Beech St, North Arlington, NJ 07301
PAS Project ID : P24-08630

Matrix : Drinking Water
Report Date : 8/20/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-08630-01	NAMS-1-WC-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:25	8/12/24 16:00
P24-08630-02	NAMS-1-WC-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:33	8/12/24 16:04
P24-08630-03	NAMS-1-BF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:34	8/12/24 16:09
P24-08630-04	NAMS-2-WC-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:40	8/12/24 16:13
P24-08630-05	NAMS-2-S-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:43	8/12/24 16:18
P24-08630-06	NAMS-3-WC-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:48	8/12/24 16:22
P24-08630-07	NAMS-8-2-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:48	8/12/24 16:27

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: #8970 North Arlington: Susan B. Anthony ES

School Address: 45 Beech Street, North Arlington, NJ 07301

Sampled By: Frank Obando

Print Name: Frank Obando

RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 8/2/2024 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Container s	Glass or Plastic	Analysis	LAB ID
NAMS-1-WC-01A; Main Office	8:25am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24-0825
NAMS-1-WC-02A; Near Boiler Room	8:33am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24-0833
NAMS-1-BF-01A; Near Boiler Room	8:34am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24-0834
NAMS-2-WC-03A; Near Room 203	8:40am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24-0840
NAMS-2-S-01A; Nurse's Office	8:43am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24-0843
NAMS-3-WC-04A; Near Room 304	8:48am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24-0848
NAMS-8-2-FBA; Field Blank	NA	DW	Grab			1	250 ml Plastic	Lead	8/2/24-0848
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

PDF
Std.

PDF
Reduce

PDF
Full

EDD

Date/Time
Preserved with
HDD

Page 1 of 1

Deliverables:

X

MATRIX
CODES:

GW = Ground Water, WW = Waste Water, SW = Surface Water,
DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge,
B = Blank, K = Solid (specify):

PRESERVATION
VE
CODES: 0 = Ice 1 = HCl
2 = H2SO4 3 = NaOH
4 = HNO3 5 = Other

Print Name:

Signature:

Company

Date + Time

Relinquished:	Tara Ekiert	<i>Tara Ekiert</i>	GSE, Inc.	8/6/2024 @ 11:52am
Received:	<i>Terry Hargis</i>	<i>Terry Hargis</i>	8/5/24	11:27
Relinquished:	<i>Terry Hargis</i>	<i>Terry Hargis</i>	8/5/24	11:41
Received:	<i>late matthews</i>	<i>H. Matthews</i>	8/6/2024	11:04
Relinquished:				
Received:				



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : # 8970 North Arlington, Susan B Anthony ES, 45 Beech St, North Arlington, NJ 07301
PAS Project ID : P24-08630

Matrix : Drinking Water
Report Date : 8/20/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-08630-01	NAMS-1-WC-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:25	8/12/24 16:00
P24-08630-02	NAMS-1-WC-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:33	8/12/24 16:04
P24-08630-03	NAMS-1-BF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:34	8/12/24 16:09
P24-08630-04	NAMS-2-WC-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:40	8/12/24 16:13
P24-08630-05	NAMS-2-S-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:43	8/12/24 16:18
P24-08630-06	NAMS-3-WC-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:48	8/12/24 16:22
P24-08630-07	NAMS-8-2-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 08:48	8/12/24 16:27

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: #8970 North Arlington: Susan B. Anthony ES
School Address: 45 Beech Street, North Arlington, NJ 07301
Sampled By: Frank Obando
Print Name: Frank Obando
RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 8/2/2024 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Percent	# Container s	Glass or Plastic	Analysis	LAB ID
NAMS-1-WC-01A; Main Office	8:25am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 10:30
NAMS-1-WC-02A; Near Boiler Room	8:33am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 10:30
NAMS-1-BF-01A; Near Boiler Room	8:34am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 10:30
NAMS-2-WC-03A; Near Room 203	8:40am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 10:30
NAMS-2-S-01A; Nurse's Office	8:43am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 10:30
NAMS-3-WC-04A; Near Room 304	8:48am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 10:30
NAMS-8-2-FBA; Field Blank	NA	DW	Grab			1	250 ml Plastic	Lead	8/2/24 10:30
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

PDF Std. PDF Reduce PDF Full EDD

8/8/24
10:55

Page 1 of 1

Deliverables:

X

MATRIX CODES:
GW = Ground Water, WW = Waste Water, SW = Surface Water,
DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge,
B = Blank, K = Solid (specify):

PRESERVATION CODES:
0 = Ice 1 = HCl
2 = H2SO4 3 = NaOH
4 = HNO3 5 = Other

Print Name:

Signature:

Company

Date + Time

Relinquished:	Tara Ekiert		GSE, Inc.	8/6/2024 @ 11:52am
Received:	Terry Hargis		8/7/24	11:27
Relinquished:	Terry Hargis		8/7/24	16:42
Received:				
Relinquished:	Kate Matthews		8/8/24	11:00am
Received:				



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : #8970 North Arlington, Jefferson ES, 100 Prospect Ave, North Arlington, NJ 07301

PAS Project ID : P24-08631

Matrix : Drinking Water

Report Date : 8/20/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-08631-01	NAJ-1-S-01A	Lead	2.15	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 10:04	8/12/24 16:31
P24-08631-02	NAJ-1-WC-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 10:07	8/12/24 17:03
P24-08631-03	NAJ-1-BF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 10:07	8/12/24 17:08
P24-08631-04	NAJ-2-S-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 10:10	8/12/24 17:12
P24-08631-05	NAJ-2-WC-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 10:12	8/12/24 17:17
P24-08631-06	NAJ-2-WC-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 10:21	8/12/24 17:21
P24-08631-07	NAJ-3-WC-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 10:29	8/12/24 17:26
P24-08631-08	NAJ-3-S-03A	Lead	2.15	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 10:24	8/12/24 17:30
P24-08631-09	NAJ-8-2-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 10:24	8/12/24 17:44

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: #8970 North Arlington: Jefferson ES
School Address: 100 Prospect Avenue, North Arlington, NJ 07301
Sampled By: Frank Obando
Print Name: Frank Obando
RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 8/2/2024 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Container s	Glass or Plastic	Analysis	LAB ID
NAJ-1-S-01A; Main Office Mail Room	10:04am	DW	Grab			1	250 ml Plastic	Lead	104186-01
NAJ-1-WC-01A; Hall Ground Floor	10:07am	DW	Grab		y	1	250 ml Plastic	Lead	
NAJ-1-BF-01A; Hall Ground Floor	10:07am	DW	Grab		y	1	250 ml Plastic	Lead	
NAJ-2-S-02A; Nurse	10:10am	DW	Grab			1	250 ml Plastic	Lead	
NAJ-2-WC-02A; Hall by Room 1	10:12am	DW	Grab		y	1	250 ml Plastic	Lead	
NAJ-2-WC-03A; Hall by Room 6	10:21am	DW	Grab		y	1	250 ml Plastic	Lead	
NAJ-3-WC-04A; Hall by Room 6/7	10:29am	DW	Grab		y	1	250 ml Plastic	Lead	
NAJ-3-S-03A; Teacher's Lounge	10:24am	DW	Grab			1	250 ml Plastic	Lead	
NAJ-8-2-FBA; Field Blank	NA	DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 1 of	Deliverables:	PDF Std.	PDF Reduce	PDF Full	EDD	Date/Time Preserved with (HRT)
		X				8/8/24 10:55

MATRIX CODES:
GW = Ground Water, WW = Waste Water, SW = Surface Water,
DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge,
B = Blank, K = Solid (specify):

PRESERVATION CODES:
0 = Ice 1 = HCl
2 = H2SO4 3 = NaOH
4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Tara Ekiert	Tara Ekiert	GSE, Inc.	8/6/2024 @ 11:55am
Received:	Jerry Hedges	Jerry Hedges		8/7/24 11:27
Relinquished:	Jerry Hedges	Jerry Hedges		8/7/24 11:44
Received:	Kate Matthews	K. Matthews		8/9/24 11:00am
Relinquished:				
Received:				



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : #8970 North Arlington, Washington ES, 175 Albert St, North Arlington, NJ 07301
PAS Project ID : P24-08633

Matrix : Drinking Water
Report Date : 8/20/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-08633-01	NAW-1-WC-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 10:53	8/12/24 14:47
P24-08633-02	NAW-1-B-04A	Lead	1.00 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 10:55	8/12/24 14:51
P24-08633-03	NAW-2-WC-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 11:01	8/12/24 14:55
P24-08633-04	NAW-2-BF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 11:01	8/12/24 15:09
P24-08633-05	NAW-2-WC-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 11:04	8/12/24 15:13
P24-08633-06	NAW-2-BF-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 11:04	8/12/24 15:18
P24-08633-07	NAW-2-B-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 11:06	8/12/24 15:22
P24-08633-08	NAW-2-WC-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 11:09	8/12/24 15:27
P24-08633-09	NAW-3-S-03A	Lead	2.84	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 11:13	8/12/24 15:31
P24-08633-10	NAW-3-WC-05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 11:23	8/12/24 15:36
P24-08633-11	NAW-8-2-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 00:00	8/12/24 15:40

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: #8970 North Arlington: Washington ES
School Address: 175 Albert Street, North Arlington, NJ 07301
Sampled By: Frank Obando
Print Name: Frank Obando
RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 8/2/2024 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Container s	Glass or Plastic	Analysis	LAB ID
NAW-1-WC-01A; Across 104 Boiler Room	10:53am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 10:53
NAW-1-B-04A; Room 101	10:55am	DW	Grab			1	250 ml Plastic	Lead	8/2/24 10:55
NAW-2-WC-03A; Lobby Left	11:01am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 11:01
NAW-2-BF-01A; Lobby Left	11:01am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 11:01
NAW-2-WC-04A; Lobby Right	11:04am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 11:04
NAW-2-BF-02A; Lobby Right	11:04am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 11:04
NAW-2-B-02A; Room 201	11:06am	DW	Grab			1	250 ml Plastic	Lead	8/2/24 11:06
NAW-2-WC-02A; b/w 208/207	11:09am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 11:09
NAW-3-S-03A; Faculty Room	11:13am	DW	Grab			1	250 ml Plastic	Lead	8/2/24 11:13
NAW-3-WC-05A; Faculty Room	11:23am	DW	Grab		y	1	250 ml Plastic	Lead	8/2/24 11:23
NAW-8-2-FBA; Field Blank	NA	DW	Grab			1	250 ml Plastic	Lead	8/2/24 11:23
		DW	Grab			1	250 ml Plastic	Lead	8/2/24 11:23
		DW	Grab			1	250 ml Plastic	Lead	8/2/24 11:23
		DW	Grab			1	250 ml Plastic	Lead	8/2/24 11:23
		DW	Grab			1	250 ml Plastic	Lead	8/2/24 11:23

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

PDF Std. ☒ PDF Reduce ☐ PDF Full ☐ EDD ☐

10/8/24
10:55

Page 1 of 1

Deliverables:

**MATRIX
CODES:**

GW = Ground Water, WW = Waste Water, SW = Surface Water,
DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge,
B = Blank, K = Solid (specify):

**PRESERVATION
CODES:** 0 = Ice 1 = HCl
2 = H2SO4 3 = NaOH
4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Tara Ekiert	Tara Ekiert	GSE, Inc.	8/6/2024 @ 12:04pm
Received:	Rory Hodges	Rory Hodges		8/6/24 11:22
Relinquished:	Rory Hodges	Rory Hodges		8/7/24 1:44
Received:	Rory Hodges	Rory Hodges		8/9/24 11:30am
Relinquished:	Rory Hodges	Rory Hodges		
Received:	Rory Hodges	Rory Hodges		



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : #8970 North Arlington, North Arlington MS, 191 Rutherford Place, North Arlington, NJ 07301
PAS Project ID : P24-08634

Matrix : Drinking Water
Report Date : 8/20/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-08634-01	NAQP-1-S-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 04:02	8/9/24 16:22
P24-08634-02	NAQP-1-S-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 04:04	8/9/24 16:26
P24-08634-03	NAQP-1-WC-05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 04:08	8/9/24 16:30
P24-08634-04	NAQP-1-BF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 04:08	8/9/24 16:34
P24-08634-05	NAQP-1-WC-09A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 04:09	8/9/24 16:38
P24-08634-06	NAQP-2-WC-23A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 04:17	8/9/24 16:50
P24-08634-07	NAQP-2-WC-15A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 04:19	8/9/24 16:55
P24-08634-08	NAQP-2-WC-14A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 04:23	8/9/24 16:59
P24-08634-09	NAQP-2-WC-24A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 04:25	8/9/24 17:03
P24-08634-10	NAQP-2-WC-20A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 04:29	8/9/24 17:07
P24-08634-11	NAQP-2-WC-26A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 04:32	8/9/24 17:11
P24-08634-12	NAQP-3-WC-21A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/1/24 04:36	8/9/24 17:15
P24-08634-13	NAQP-3-WC-22A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 04:49	8/9/24 17:19
P24-08634-14	NAQP-8-2-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/2/24 00:00	8/9/24 17:23

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: #8970 North Arlington: North Arlington MS

School Address: 191 Rutherford Place, North Arlington, NJ 07301

Sampled By: Frank Obando

Print Name: Frank Obando

RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 8/2/2024 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Container s	Glass or Plastic	Analysis	LAB ID
NAQP-1-S-01A; Kitchen Center Island	4:02pm	DW	Grab			1	250 ml Plastic	Lead	pot-08063410
NAQP-1-S-02A; Kichen 3 Comp.	4:04pm	DW	Grab			1	250 ml Plastic	Lead	02
NAQP-1-WC-05A; Hall Outside Boy's LR	4:08pm	DW	Grab		y	1	250 ml Plastic	Lead	03
NAQP-1-BF-01A; Hall Outside Boy's LR	4:08pm	DW	Grab		y	1	250 ml Plastic	Lead	04
NAQP-1-WC-09A; Hall by Custodial Closet	4:09pm	DW	Grab		y	1	250 ml Plastic	Lead	05
NAQP-2-WC-23A; Teacher's Lounge	4:17pm	DW	Grab		y	1	250 ml Plastic	Lead	06
NAQP-2-WC-15A; Teacher's Lounge	4:19pm	DW	Grab		y	1	250 ml Plastic	Lead	07
NAQP-2-WC-14A; Hall by Room 205	4:23pm	DW	Grab		y	1	250 ml Plastic	Lead	08
NAQP-2-WC-24A; Main Office	4:25pm	DW	Grab		y	1	250 ml Plastic	Lead	09
NAQP-2-WC-20A; Hall by Room 206	4:29pm	DW	Grab		y	1	250 ml Plastic	Lead	10
NAQP-2-WC-26A; Hall by Room 213	4:32pm	DW	Grab		y	1	250 ml Plastic	Lead	11
NAQP-3-WC-21A; Hall by Room 304	4:36pm	DW	Grab		y	1	250 ml Plastic	Lead	12
NAQP-3-WC-22A; Hall by Room 306	4:49pm	DW	Grab		y	1	250 ml Plastic	Lead	13
NAQP-8-2-FBA; Field Blank	NA	DW	Grab			1	250 ml Plastic	Lead	14
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 1 of 1	Deliverables:	PDF Std.	PDF Reduce	PDF Full	EDD	Date/Time Preserved with HNO ₃ :
	X					

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATIVE CODES: 0 = Ice, 1 = HCl, 2 = H₂SO₄, 3 = NaOH, 4 = HNO₃, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Tara Ekiert	Tara Ekiert	GSE, Inc.	8/6/2024 @ 12:48pm
Received:	Rory Hedges	Rory Hedges	PAS	8/7/24 11:27
Relinquished:	Rory Hedges	Rory Hedges	PAS	8/7/24 10:44
Received:	date Matthews	R. Matthews		8/9/24 11:00
Relinquished:				
Received:				