

Elmsford Union Free School District  
Annual SED Fire Safety Inspection  
November 8, 2023

**Facility: Alexander Hamilton High School 9 Points**

<u>Violation</u>	<u>Description</u>
3B-1	Boiler inspection certificates not present
9C-1	Disorderly storage – Auditorium balcony
10B-2	Safety Data Sheets (SDS) are complete and available on the premises.
10D-1	Records of hazardous material inventory statements are provided.
12D-2	Records of inspection, testing, and maintenance of emergency and standby power systems are maintained on-premises and are available for inspection
14A-2	Fire resistance rating maintained – Smoke/Fire doors at stairwell were removed*

**Facility: Grady 9 Points**

<u>Violation</u>	<u>Description</u>
10B-2	Safety Data Sheets (SDS) are complete and available on premises.
10D-1	Records of hazardous material inventory statements are provided.
12D-2	Records of inspection, testing, and maintenance of emergency and standby power systems are maintained on-premises and are available for inspection
14A-2	Fire resistance rating maintained – Smoke/Fire doors at stairwell were removed*
14A-2	Instruction is not permitted in corridors. Remove tables and chairs
17B-2	3 sets of exit doors have one door inoperable

**Facility: Dixon 3 Points**

<u>Violation</u>	<u>Description</u>
3B-1	Boiler inspection certificates not present
12E-1	GFCI required – Nurse’s Office
14E-1	Fire/Smoke doors do not close and latch – Corridor by 106

**Facility: Dixon Annex**

<u>Violation</u>	<u>Description</u>
NONE	

**Facility: Alexander Hamilton High School - Garage - DISCOVERED**

<u>Violation</u>	<u>Description</u>
None	

Elmsford Union Free School District  
Annual SED Fire Safety Inspection  
November 8, 2023

**Facility:** Alexander Hamilton High School – Freezer - DISCOVERED

Violation      Description  
None

**Facility:** Alexander Hamilton High School – Shed - DISCOVERED

Violation      Description  
NONE

**Facility:** Alexander Hamilton High School – Equipment Bldg. - DISCOVERED

Violation      Description  
None

- Need clarification from your architect regarding the two sets of missing fire/smoke doors that protect the stairways in the high school and Grady.

John Convey  
NYS Code Enforcement Official  
NYSDOS Reg 0613-0130

