

The Purpose of this Addendum is to **provide the answers to the questions that have been submitted and extend the closing date of the above RFP. The new closing date will be Thursday, November 7, 2024, at 2:00 pm CST.**

1. What are the temperature ranges required for the sensors?  
**Sensors should be able to detect and report temperatures in the range of -5 °C and +70 °C.**
2. How many Installation sites are there? The pricing schedule suggests it is a few sites, not the entire school district.  
**The installation sites include all 227 school cafeterias, the main Food Services facility, and the “D Café” at the main Administration Building (229 sites, total).**
3. Would the school district be interested in a “Self-Installed” system or only a system installed by our team?  
**A vendor-installed turn-key solution is the preferred method of deployment but we encourage all vendors to participate and provide details and pricing on products and services.**
4. Will there be an opportunity for an individual meeting to discuss the project and the varying options we have?  
**The vendor will submit written specifications of their product software capabilities and functions. You must demonstrate products and services online (Teams or Zoom) or in person. Demonstrations will be after evaluations and vendors will be determined at that time.**
5. Are there any costs associated with using the District’s cellular data plans?  
**The product currently in use does not utilize the District’s cellular data plan but we are open to different methods of ensuring system up-time.**
6. On Page 3, Requirement 11 specifies that "The handheld tool should authenticate with LDAP to pull down user information. The handheld should also pull from the FCNS Software flat file or otherwise." However, our devices do not include a handheld tool. Could you clarify if this is relevant to this RFP?  
**Please disregard Requirement 11, handheld devices are not relevant to this RFP.**
7. To accurately estimate the cost of uninstalling existing devices, could you please provide details such as the make, model, and photos of the devices currently in place?  
**This RFP does not require a price for uninstalling, price should be included with the installation of a new unit and removing the previous one. The make, model, and photos of the equipment in place will be provided to the awarded vendor.**
8. Our sensors can be placed directly inside the walk-in units without the need for drilling. Given this, is it necessary to remove the old devices, or can they remain in place?  
**Yes, old devices need to be removed to eliminate confusion for the end-users as well as provide an orderly environment.**



- 9. Based on the School Equipment List, it appears there are fewer unique addresses than the total school count. However, the RFQ on Page 3 lists 227 schools. Could you confirm the total number of walk-in freezers, walk-in coolers, and reach-in refrigerators and freezers?

There is a total of **229 sites**, which includes 227 schools plus 2 administrative sites. Those 229 sites contain a minimum of 478 devices to be monitored (a combination of Walk-in and reach-in coolers and freezers)

The information in this Addendum is hereby incorporated and made part of any contract awarded pursuant to this solicitation.

**Please sign this addendum and submit it along with your copies of the proposal. ALL OTHER PROVISIONS AND OTHER TERMS AND CONDITIONS REMAIN UNCHANGED. BIDDERS ARE REQUIRED TO ACKNOWLEDGE AND RETURN/SUBMIT A COPY OF THIS ADDENDUM WITH THEIR PROPOSAL.**

Company Name:	_____	Submitter's Name/Title:	_____
Address:	_____	City, State, and Zip Code:	_____
Email Address:	_____		_____
Submitter's Signature:	_____	Telephone No.	_____
Fax No.	_____	800 # (if available)	_____
Date:	_____		_____

END OF ADDENDUM