

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
76	10/16/2024 05:26	10/23/2024 13:12	70318118001	Lead	<1.0	5	ug/L
77	10/16/2024 05:27	10/23/2024 13:22	70318118002	Lead	7.9	5	ug/L
78	10/16/2024 05:28	10/23/2024 13:26	70318118003	Lead	3.6	5	ug/L
93	10/16/2024 05:30	10/23/2024 13:28	70318118004	Lead	3.0	5	ug/L
109	10/16/2024 05:33	10/23/2024 13:30	70318118005	Lead	<1.0	5	ug/L
110	10/16/2024 05:34	10/23/2024 13:31	70318118006	Lead	<1.0	5	ug/L
111	10/16/2024 05:35	10/23/2024 13:33	70318118007	Lead	<1.0	5	ug/L
112	10/16/2024 05:37	10/23/2024 13:34	70318118008	Lead	<1.0	5	ug/L
113	10/16/2024 05:37	10/23/2024 13:36	70318118009	Lead	<1.0	5	ug/L
114	10/16/2024 05:39	10/23/2024 13:41	70318118010	Lead	<1.0	5	ug/L
115	10/16/2024 05:39	10/23/2024 13:46	70318118011	Lead	<1.0	5	ug/L
116	10/16/2024 05:40	10/23/2024 13:50	70318118012	Lead	4.4	5	ug/L
120	10/16/2024 05:42	10/23/2024 14:11	70318118013	Lead	17.6	5	ug/L
121	10/16/2024 05:43	10/23/2024 14:13	70318118014	Lead	<1.0	5	ug/L
122	10/16/2024 05:44	10/23/2024 14:14	70318118015	Lead	<1.0	5	ug/L
125	10/16/2024 05:45	10/23/2024 14:19	70318118016	Lead	3.1	5	ug/L
126	10/16/2024 05:46	10/23/2024 14:21	70318118017	Lead	3.6	5	ug/L
127	10/16/2024 05:48	10/23/2024 14:22	70318118018	Lead	<1.0	5	ug/L
128	10/16/2024 05:48	10/23/2024 14:24	70318118019	Lead	<1.0	5	ug/L
129	10/16/2024 05:50	10/23/2024 14:25	70318118020	Lead	5.2	5	ug/L
131	10/16/2024 05:52	10/23/2024 14:27	70318118021	Lead	<1.0	5	ug/L
132	10/16/2024 05:53	10/23/2024 14:29	70318118022	Lead	<1.0	5	ug/L
133	10/16/2024 05:55	10/23/2024 14:33	70318118023	Lead	<1.0	5	ug/L
134	10/16/2024 05:56	10/23/2024 14:41	70318118024	Lead	<1.0	5	ug/L
138	10/16/2024 05:57	10/23/2024 14:09	70318118025	Lead	6.0	5	ug/L
139	10/16/2024 05:59	10/23/2024 14:08	70318118026	Lead	3.1	5	ug/L
143	10/16/2024 06:00	10/23/2024 14:06	70318118027	Lead	6.5	5	ug/L
148	10/16/2024 06:10	10/23/2024 14:05	70318118028	Lead	2.7	5	ug/L
151	10/16/2024 06:14	10/23/2024 14:03	70318118029	Lead	<1.0	5	ug/L
153	10/16/2024 06:20	10/23/2024 14:01	70318118030	Lead	7.7	5	ug/L
153A	10/16/2024 06:22	10/23/2024 14:00	70318118031	Lead	<1.0	5	ug/L
153B	10/16/2024 06:23	10/23/2024 13:55	70318118032	Lead	2.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb