



ORANGE COUNTY PUBLIC SCHOOLS
200 Dailey Dr, Orange, VA 22960, United States
Phone: 1-540-661-4550

ADDENDUM-03
OCTOBER 28, 2024

REFERENCE: GORDON-BARBOUR ELEMENTARY SCHOOL DINING ADDITION
500 W Baker Street Gordonsville, VA 22942. Architect Project Number 177920025

This addendum includes revisions or clarifications to the bidding documents.
All other bidding documents, terms, and conditions not included in this addendum remain unchanged.

THIS ADDENDUM IS ONE (1) PAGE AND MAY INCLUDE ATTACHMENTS.

- The bid date and time remains UNCHANGED and is still OCTOBER 31, 2024, @ 2:00 P.M.

1. ATTACHED REVISIONS OR CLARIFICATIONS.

- N/A

2. GENERAL REVISIONS OR CLARIFICATIONS.

- Clarification from Addendum-02.

BAS control company is Johnson Controls.

Other information below is unchanged.

Vendor is ABM.

See also SECTION 254002 - BUILDING AUTOMATION SYSTEM (BAS). Control products, communication media, connectors, repeaters, hubs, and routers shall comprise a BACnet internetwork. Controller and operator interface communication shall conform to ANSI/ASHRAE Standard 135, BACnet.

3. REVISIONS OR CLARIFICATIONS BASED ON QUESTIONS PER THE INVITATION FOR BID.

- N/A

END ADDENDUM.