

School Name: **Oak-Land Middle School (OMS)**Date: **11/15/2023**

Floor	Room Number	Location	Sample ID	Type S = Sink WC = Water Cooler BF = Bottle Filler K=Kettle SP = Sprayer	Lead Result (ppb)	Copper Result (ppb)
First Floor	-	Kitchen	1-OMS-Kit-S	S	2.85	71.7
First Floor	-	Kitchen	2-OMS-Kit-S	S	1.89	60.4
First Floor	-	Kitchen	3-OMS-Kit-S	S	1.75	91.9
First Floor	-	Kitchen	4-OMS-Kit-SP	SP	2.85	69.6
First Floor	-	Kitchen	5-OMS-Kit-SP	SP	2.41	87.2
First Floor	-	Kitchen	6-OMS-Kit-SP	SP	4.24	84.1
First Floor	-	Kitchen	7-OMS-Kit-K	K	253	4620
First Floor	-	Dish Room	8-OMS-Dish-SP	SP	1.09	158
First Floor	-	Dish Room	9-OMS-Dish-SP	SP	0.89	64.5
First Floor	-	Cafeteria	10-OMS-Café-WCL	WC	<0.5	26.1
First Floor	-	Cafeteria	11-OMS-Café-BF	BF	<0.5	21.9
First Floor	-	Cafeteria	12-OMS-Café-WCR	WC	<0.5	18.8
First Floor	-	Weight Room	13-OMS-Wt.RM-WC	WC	0.88	141
First Floor	-	Hallway	14-OMS-Hall 134-WCL	WC	<0.5	22.1
First Floor	-	Hallway	15-OMS-Hall 134-BF	BF	<0.5	22.9
First Floor	-	Hallway	16-OMS-Hall 134-WCR	WC	<0.5	19.4
First Floor	134D	Classroom	17-OMS-134D-S	S	4.73	105
First Floor	-	Hallway	18-OMS-Hall 195-WCL	WC	<0.5	37
First Floor	-	Hallway	19-OMS-Hall 195-BF	BF	<0.5	39.6
First Floor	-	Hallway	20-OMS-Hall 195-WCR	WC	<0.5	37.2
First Floor	-	Girls Locker Room	21-OMS-GirlsLocker-WC	WC	0.83	134
First Floor	-	Pool	22-OMS-Pool-WCL	WC	<0.5	13.2
First Floor	-	Pool	23-OMS-Pool-WCR	WC	<0.5	9.91
First Floor	-	Pool	24-OMS-Pool-BF	BF	<0.5	12.3
First Floor	-	Hallway	25-OMS-Hall 116C-WCL	WC	<0.5	36.9
First Floor	-	Hallway	26-OMS-Hall 116C-BF	BF	<0.5	35.6
First Floor	-	Hallway	27-OMS-Hall 116C-WCR	WC	<0.5	43.6
First Floor	108C	Classroom	28-OMS-108C-S	S	5.2	110
First Floor	-	Band Storage	29-OMS-Band Storage-S	S	18.3	113
First Floor	147	Classroom	30-OMS-147-WC	WC	5.09	139
First Floor	136	Classroom	31-OMS-136-S	S	6.51	158
First Floor	106A	Classroom	32-OMS-106A-S	S	<0.5	48.2
First Floor	-	Hallway	33-OMS-Hall 101A-WCL	WC	<0.5	29.8
First Floor	-	Hallway	34-OMS-Hall 101A-BF	BF	<0.5	30.3
First Floor	-	Hallway	35-OMS-Hall 101A-WCR	WC	<0.5	27.7
First Floor	134	Classroom	36-OMS-134-S	S	16.1	203
First Floor	-	Nurse	37-OMS-Nurse-S	S	1.71	125
First Floor	-	Office Work Room	38-OMS-Office Work RM-S	S	0.61	92.5
First Floor	-	Nurse	39-OMS-Nurse RR-S	S	11.3	234
First Floor	-	Staff Restroom	40-OMS-Staff RR-WCL	WC	<0.5	96.1
First Floor	-	Staff Restroom	41-OMS-Staff RR-WCR	WC	<0.5	91.1
First Floor	-	Hallway	42-OMS-Hall 101B-WCL	WC	<0.5	44.2
First Floor	-	Hallway	43-OMS-Hall 101B-BF	BF	<0.5	83.1
First Floor	-	Hallway	44-OMS-Hall 101B-WCR	WC	<0.5	36.6
First Floor	114B	Classroom	45-OMS-114B-S	S	3.9	84.1
First Floor	-	Hallway	46-OMS-Hall 149-WCL	WC	<0.5	21.5
First Floor	-	Hallway	47-OMS-Hall 149-BF	BF	<0.5	21.8
First Floor	-	Hallway	48-OMS-Hall 149-WCR	WC	<0.5	19.4
First Floor	149	Classroom	49-OMS-149-S	S	4.62	215

# Oak-Land Middle School Lead in Drinking Water Project #23127



First Draw Sampling (2023)

- ◆ Lead  $\leq$  20 ppb
- ◆ Lead  $>$  20 ppb

