

IRIS ENVIRONMENTAL LABORATORIES

INSPECTION REPORT

WWW.IRISLABORATORIES.COM



CALL NOW TO

LEARN MORE ABOUT IRIS
ENVIRONMENTAL LABORATORIES
FRANCHISE OPPORTUNITY



October 2nd, 2024

Watchung Borough School District
50 Valleyview Road
Watchung, NJ 07069

IRIS Environmental Laboratories was retained on September 13, 2024 to collect and analyze water samples for Lead and Copper according to 40 CFR Parts 141/142/143, NJ Safe Drinking Water regulations N.J.A.C. 7:10-1 et seq.

Based on the results, no samples exceeded the Lead in Water criteria.

Sincerely,

A handwritten signature in blue ink, appearing to read "Rick Eustaquio", with a horizontal line extending to the right.

Rick Eustaquio
Project Coordinator

Job Description

Project No.	COC# 24-09-03341
Subject	Lead in Drinking Water
Report Date:	October 2nd, 2024
Building:	Commercial
Job Site:	Valley View Middle School 50 Valley View Road Watchung, NJ 07069
Prepared for:	Watchung Borough School District
Prepared by:	IRIS Environmental Laboratories 2333 Route 22 West Union, NJ 07083
Analyzed by:	Accurate Analytical Testing LLC
NJ DEP	20044
Lead Inspector	Rick Eustaquio
NJDOH Inspector Permit/ID No.	038090
Contractor Licenses:	00738-E

3. Company Disclaimer

The work completed has been on behalf of, and exclusive for the use of the client. IRIS Environmental Laboratories warrants that its services are performed within the limits prescribed by the client, with the usual thoroughness and competence of the Environmental Consulting and Testing profession. No other warranty or representation, either expressed or implied is included. The judgmental consideration necessary for the performance of this work has been made by trained professionals, in accordance with generally accepted practices of Engineers and Scientists undertaking duties and performing similar projects. Based on the nature of the work conducted, the results of this survey should not be extrapolated to include areas not specifically mentioned.

4. Analytical Results

See the analytical results below

Lead in Drinking Water Analysis Report

Client: Watchung Borough School District
1 Dr. Parenty Way
Watchung, NJ 07069

Report Number: 24-09-03341

Received Date: 09/19/2024

Reported Date: 10/02/2024

Sampled By:

Tech Certification #:

Project/Test Address: 76542; 038090; Valley View Middle School; Watchung, NJ

Client Number:

202404

Fax Number:

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-09-03341-001	01	09/16/2024	ROOM 101 E SINK	<1.00	09/29/2024	
24-09-03341-002	02	09/16/2024	HALL ROOM 101 WATER COOLER	<1.00	09/26/2024	
24-09-03341-003	03	09/16/2024	GYM BOTTLE FILLER	<1.00	09/29/2024	
24-09-03341-004	04	09/16/2024	GYM WATER COOLER	<1.00	09/29/2024	
24-09-03341-005	05	09/16/2024	NURSE BUBBLER	1.06	09/29/2024	
24-09-03341-006	06	09/16/2024	SAT KITCHEN SINK	2.20	09/29/2024	
24-09-03341-007	07	09/16/2024	ROOM 144 BUBBLER	2.63	09/26/2024	
24-09-03341-008	08	09/16/2024	HALL ROOM 148 WATER COOLER	<1.00	09/29/2024	
24-09-03341-009	09	09/16/2024	ROOM 136 BUBBLER	<1.00	09/29/2024	
24-09-03341-010	10	09/16/2024	ROOM 134 BUBBLER	<1.00	09/29/2024	
24-09-03341-011	11	09/16/2024	ROOM 132 BUBBLER	5.93	09/29/2024	
24-09-03341-012	12	09/16/2024	HALL ROOM 238 WATER COOLER	<1.00	09/29/2024	
24-09-03341-013	13	09/16/2024	KITCHEN BUBBLER	<1.00	09/29/2024	

Client Number: 202404
Project/Test Address: 76542; 038090; Valley View Middle School; Watchung, NJ

Report Number: 24-09-03341

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-09-03341-014	14	09/16/2024	FACULTY ROOM SINK	<1.00	09/26/2024	
24-09-03341-015	15	09/16/2024	STEM 115	1.98	09/26/2024	
24-09-03341-016	16	09/16/2024	COMPUTER ROOM 224	1.22	09/29/2024	
24-09-03341-017	17	09/16/2024	WATER COOLER HALL ROOM 201	<1.00	09/29/2024	
24-09-03341-018	18	09/16/2024	AQ CONTROL QC	<1.00	09/29/2024	

Method: EPA 200.8
Analyst: Nicole Lyle
Accreditation #: NJ VA008

Reviewed By Authorized Signatory: *Melissa Kanode*


Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from IRIS/Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



ENVIRONMENTAL LABORATORIES

IRIS Environmental Labs
2333 US Highway 22 West
Union, NJ 07083

(800)908-86679


Website: irislaboratories.com

Email: support@irislaboratories.com



SUBMITTING COMPANY

24-09-03341



Due Date:

10/03/2024

(Thursday)

AE

P

PROJECT NUMBER: 76542

SAMPLING DATE: 9/16/2024

PROJECT ADDRESS: Valley View Middle School

Waterway: NS

PERSON COLLECTING the SAMPLES: 038090

REQUESTED ANALYSIS

Drinking Water

- LEAD
- COPPER
- BOTH

TURNAROUND TIME (please check one)

24 Hour () 48 Hour ()

72 Hour () 5 Days ()

If no TAT is indicated, default is 5 Days

10 days

LAB ID #	CLIENT SAMPLE ID	DESCRIPTION	SAMPLE TYPE or PURPOSE *	TIME	VOLUME	CLIENT COMMENTS
	#01	Room 101 E. Sink	Compliance	900	250ml	SAMPLES SHIPPED SAMPLES ACIDIFIED Y N
	#02	HALL ROOM 101 WATER COOLER				
	#03	GYM BOTTLE FILLER				
	#04	GYM WATER COOLER				
	#05	NURSE BUBBLE				
	#06	SAT KITCHEN SINK				
	#07	ROOM 144 BUBBLER				
	#08	HALL ROOM 148 WATER COOLER				
	#09	ROOM 136 BUBBLER				
	#10	ROOM 134 BUBBLER				
	#11	ROOM 133 BUBBLER				
	#12	HALL ROOM 238 WATER COOLER				
	#13	KITCHEN BUBBLER				
	#14	FACULTY ROOM SINK				
	#15	STEM 115				
	#16	COMPUTER ROOM 224				
	#17	WATER COOLER HALL ROOM 201				
	#18	AIR central AC				
SAMPLES RELINQUISHED BY			SAMPLES RECEIVED BY			
			SAPRISTANS			
LAB PROJECT NUMBER		DATE		TIME		
		9/19/24		1:33 AM		PM
				AM		PM

By submitting samples to IRIS, the client agrees to AAT's terms and conditions.
IRIS is not responsible for shipping delays

* Sample Type or Purpose -- Key: Routine Distribution (RD) Check Sample (CS) Raw Water (RW) Process Water (PW) Investigation Number (IN)

VV = Valley View

10/1