



REQUEST FOR QUOTATIONS

AMENDMENT # 1

Description: Catch Basin Repairs at Multiple Locations
Quotation #: 2025-015
Date of Amendment: November 14, 2024
Quotations will be received until: November 20, 2024
Quotations may be returned to: D5bids@lexrich5.org
Telephone No. (803) 476-8140
Quotations may also be delivered to: Purchasing Department
 School District 5 of Lexington & Richland Counties
 1020 Dutch Fork Road
 Irmo, SC 29063

Vendor Name _____ Fax No. _____

Mailing Address _____ Email Address _____

City-State-Zip Code _____

Telephone Number _____

Federal I.D. or Social Security No. _____

ACKNOWLEDGEMENT OF AMENDMENTS:					
Offerors acknowledge receipt of amendments by indicating amendment number and its date of issue					
Amendment #	Amendment Issue Date	Amendment #	Amendment Issue Date	Amendment #	Amendment Issue date

I certify that this quotation is made without prior understanding, agreement or connection with any corporation, firm, or person submitting a quotation for the same services, materials, supplies or equipment, and is in all respects fair and without collusion or fraud. I agree to abide by all conditions of this quotation and certify that I am authorized to sign this quotation for the bidder.

Authorized Signature: _____

Name (typed or printed): _____

AMENDMENT #1

CATCH BASIN REPAIRS AT MULTIPLE LOCATIONS

SOLICITATION # 2025-015

The Solicitation may be amended at any time prior to opening. Submitters shall acknowledge receipt of any amendment to this solicitation (1) by signing and returning the amendment, (2) by identifying the amendment number and date in the space provided for this purpose on Page Two, (3) by letter, or (4) by submitting a bid that indicates in some way that the bidder received the amendment. (c) If this solicitation is amended, then all terms and conditions which are not modified remain unchanged.

THE SOLICITATION IS AMENDED AS PROVIDED HEREIN. INFORMATION OR CHANGES RESULTING FROM QUESTIONS WILL BE SHOWN IN A QUESTION-AND-ANSWER FORMAT. ALL QUESTIONS RECEIVED HAVE BEEN REPRINTED BELOW. THE QUESTIONS ARE INCLUDED SOLELY TO PROVIDE A CROSS-REFERENCE TO THE POTENTIAL OFFEROR THAT SUBMITTED THE QUESTION. QUESTIONS DO NOT FORM A PART OF THE CONTRACT; THE "DISTRICT'S RESPONSE" DOES. ANY RESTATEMENT OF PART OR ALL OF AN EXISTING PROVISION OF THE SOLICITATION IN AN ANSWER DOES NOT MODIFY THE ORIGINAL PROVISION EXCEPT AS FOLLOWS: UNDERLINED TEXT IS ADDED TO THE ORIGINAL PROVISION. ~~STRICKEN~~ TEXT IS DELETED.

QUESTIONS:

1. **QUESTION:** Under the Scope Of Work, #5 says to backfill the soil every one-foot lift, expose existing, and replace with #57 stone. Are we to use 57 stone or soil for backfill?

DISTRICT'S RESPONSE: The contractor shall remove and properly dispose of off-site existing soil for the catch basins at Spring Hill High School and replace with number fifty-seven (#57) stone. For the catch basins at Chapin High School, the contractor shall use the existing soil. Should the contractor find that the soil conditions at Chapin High School are unsuitable, the district reserves the right to negotiate a fair and reasonable price with the contractor to dispose of the unsuitable soil and replace it with number fifty-seven (#57) stone.