

CERTIFICATION OF COMPLIANCE

PUBLIC NOTIFICATION

Public Water System Name: Killingly High School & Agricultural Ctr

Public Water System Town: Killingly

Public Water System ID: CT0691243


Water System Facility: Distribution System

Notification Type: Copper Action Level Exceedance

Compliance Period: January 1, 2024 to December 31, 2024

The public water system indicated above hereby affirms that public notice has been provided to consumers in accordance with the delivery, content, and format requirements of Section 19-13-B102(i) of the Regulations of Connecticut State Agencies.

- Consultation with Department of Public Health (if required) on _____
- Notice posted by School Web site on 11/13/24
- Notice distributed by _____ on _____
- Notice published in _____ on _____
(newspaper or newsletter)



Signature of owner or operator

11/13/24

Date

PUBLIC NOTIFICATION
Important Information About Your Drinking Water

COPPER ACTION LEVEL EXCEEDANCE

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

Date: 11/13/24
PWS ID: CT0691243
To: The Customers/Residents of Killingly High School & Agricultural Ctr, Killingly
From: _____
Compliance Period: January 1, 2024 to December 31, 2024

Our public water system recently exceeded a drinking water action level. As our customers, you have a right to know what happened and what we are doing to correct this situation. We routinely monitor for drinking water contaminants. The results of routine water quality samples indicate a 90th percentile copper level of 3.4 mg/L. This level exceeds the copper action level of 1.3 mg/L.

What should I do?

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor. EPA has set the 90th percentile action level for copper at 1.3 mg/L to reduce the risk of these adverse health effects. Drinking water that meets this action level is associated with little or none of this risk and should be considered safe with respect to copper.

If you have been diagnosed with copper intolerance due to a genetic deficiency, please inform your physician that the 90th percentile level of copper in our water is 3.4 mg/L.

All customers should consider drinking alternative water sources until copper levels in the public water system have been reduced. You should also consider using an alternative source of water for cooking. Parents with infants should use an alternative water source for preparing infant formula. You may continue to use the water for bathing, showering, and laundry.

What is being done?

The following area(s) have been affected:
several sample sites within the school

The following steps are being taken to correct this violation:
Followup samples collected on 10/4/2024 show that no sites failed the action level for copper. We have made adjustments to the chemical feed system and will be proposing a treatment change to DPH.

We expect to return to compliance or resolve the situation by If you 11/14/24
(date)
have any questions, please contact Paul LaFramboise at 800-624-2327 or
(owner, operator or designee) (phone #)
by mail at PO Box 303, Thompson, CT, 06281
(Street) (Town) (State) (Zip Code)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.