



**CONTRACTOR’S REQUEST FOR INFORMATION**

**BID 2425-003 AQUATIC CENTER MODERNIZATION  
AT BURBANK HIGH SCHOOL**

**From:**

California Commercial Pools, Inc	<b>+</b>	Brett Smith
Company		Contact
(909) 394-1280	10/11/24	
Phone	Date	Urgency

Question:

Plan sheet MR.1 note 7 and spec section 13 11 06 note 2.09 A - say as follows "verify current chemical controller is in working order, and replace if needed. This should have already been tested and determined prior to bid, this should be determined by the designer not the bidder contractor. The documents need direct us to use existing or to replace with a new controller. Or an allowance should be carried to make sure that all bidders have included the cost of the new item, to be utilized if it is required.

Proposed Solution:

Response from Owner:

Current chemical controller to be replaced and should be included in bid price. Per spec section 13 11 06 note 2.09A "provide ethernet connection to BecSys CS-BECSYS7-BP-E water chemistry controller. Provide complete system control package. "Bec Sys 7", 'Impact', 'Wallace & Tiernan' or equal."

Reviewed by: Steve Reyna and Scott Gaudineer - F&M - 10/21/2024

By: Flewelling & Moody Date: 10/21/24

**Questions must be emailed to Dennis Maxwell,  
[dennismaxwell@burbankusd.org](mailto:dennismaxwell@burbankusd.org) by 12:00 pm, Friday, October 18, 2024**