

# Lead in School Drinking Water Report

## Grainger Elementary School



### EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov).

## DEFINITIONS

Fixture Housing  
Location

Room/space where  
fixture is located  
(i.e. room number,  
gym, playground)

Fixture Housing Type

Structure that contains  
the individual fixtures  
where water samples  
were collected from.  
Fixture housing may  
contain one or more  
individual fixture for  
sampling.

Fixture Location  
Details

Location within a  
room or space where  
fixture housing is  
located, starting to the  
left of the entrance and  
rotating clockwise, of  
the total number of  
fixture housings in a  
room or space  
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water  
Fountain, Water Bottle  
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2024-10-08, 2024-10-09

Date(s) analyzed: 2024-10-28

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	398792	Kindergarten Building	Fountain/Tap Combo	Preschool Rm.3	1 of 1	Water Fountain	right	168
2	398796	Kindergarten Building	Fountain/Tap Combo	Preschool Rm.4	1 of 1	Water Fountain	right	26
3	398782	Kindergarten Building	Fountain/Tap Combo	Preschool Room 2	1 of 1	Water Fountain	right	17
4	398794	Kindergarten Building	Fountain/Tap Combo	Preschool Rm.4	1 of 1	Tap	left	15
5	398800	Main Building	Fountain/Tap Combo	Resource Rm.110	1 of 1	Water Fountain	right	9
6	398933	Main Building	Sink - Multi-Compartment	Baseball Feild Concessions	1 of 1	Tap	center	7
7	398815	Main Building	Fountain/Tap Combo	Rm.322	1 of 1	Tap	left	6
8	398786	Kindergarten Building	Fountain/Tap Combo	Preschool Rm.1	1 of 1	Water Fountain	right	5
9	398787	Main Building	Fountain/Tap Combo	Rm.314	1 of 1	Water Fountain	right	5
10	398790	Kindergarten Building	Fountain/Tap Combo	Preschool Rm.3	1 of 1	Tap	left	5

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	398818	Main Building	Fountain/Tap Combo	Rm.419	1 of 1	Water Fountain	right	5
12	398854	Main Building	Fountain/Tap Combo	Rm.214	1 of 1	Water Fountain	right	5
13	398805	Main Building	Fountain/Tap Combo	Rm.317	1 of 1	Water Fountain	right	4
14	398809	Main Building	Fountain/Tap Combo	Rm.318	1 of 1	Water Fountain	right	4
15	398810	Main Building	Fountain/Tap Combo	Rm.417	1 of 1	Water Fountain	right	4
16	398838	Main Building	Fountain/Tap Combo	Rm.211	1 of 1	Water Fountain	right	4
17	398846	Main Building	Fountain/Tap Combo	Rm.209	1 of 1	Water Fountain	right	4
18	398850	Main Building	Fountain/Tap Combo	Rm.213	1 of 1	Water Fountain	right	4
19	398858	Main Building	Fountain/Tap Combo	Rm.207	1 of 1	Water Fountain	right	4
20	398791	Main Building	Fountain/Tap Combo	Rm.313	1 of 1	Water Fountain	right	3
21	398797	Main Building	Fountain/Tap Combo	Rm.316	1 of 1	Water Fountain	right	3

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	398811	Main Building	Fountain/Tap Combo	Rm.319	1 of 1	Tap	left	3
23	398812	Main Building	Fountain/Tap Combo	Rm.418	1 of 1	Tap	left	3
24	398814	Main Building	Fountain/Tap Combo	Rm.418	1 of 1	Water Fountain	right	3
25	398822	Main Building	Fountain/Tap Combo	Rm.320	1 of 1	Tap	left	3
26	398832	Main Building	Fountain/Tap Combo	Rm.212	1 of 1	Water Fountain	right	3
27	398842	Main Building	Fountain/Tap Combo	Rm.210	1 of 1	Water Fountain	right	3
28	398780	Kindergarten Building	Fountain/Tap Combo	Preschool Room 2	1 of 1	Tap	left	2
29	398798	Main Building	Fountain/Tap Combo	Resource Rm.110	1 of 1	Tap	left	2
30	398801	Main Building	Fountain/Tap Combo	Rm.315	1 of 1	Water Fountain	right	2
31	398806	Main Building	Fountain/Tap Combo	Rm.416	1 of 1	Water Fountain	right	2
32	398808	Main Building	Fountain/Tap Combo	Rm.417	1 of 1	Tap	left	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	398817	Main Building	Fountain/Tap Combo	Rm.322	1 of 1	Water Fountain	right	2
34	398820	Main Building	Fountain/Tap Combo	Rm.321	1 of 1	Water Fountain	right	2
35	398836	Main Building	Fountain/Tap Combo	Rm.211	1 of 1	Tap	left	2
36	398852	Main Building	Fountain/Tap Combo	Rm.214	1 of 1	Tap	left	2
37	398856	Main Building	Fountain/Tap Combo	Rm.207	1 of 1	Tap	left	2
38	398785	Main Building	Fountain/Tap Combo	Rm.314	1 of 1	Tap	left	1
39	398803	Main Building	Fountain/Tap Combo	Rm.317	1 of 1	Tap	left	1
40	398813	Main Building	Fountain/Tap Combo	Rm.319	1 of 1	Water Fountain	right	1
41	398816	Main Building	Fountain/Tap Combo	Rm.419	1 of 1	Tap	left	1
42	398819	Main Building	Fountain/Tap Combo	Rm.321	1 of 1	Tap	left	1
43	398823	Main Building	Fountain	Baseball Field	1 of 1	Water Fountain	center	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
44	398830	Main Building	Fountain/Tap Combo	Rm.212	1 of 1	Tap	left	1
45	398844	Main Building	Fountain/Tap Combo	Rm.209	1 of 1	Tap	left	1
46	398848	Main Building	Fountain/Tap Combo	Rm.213	1 of 1	Tap	left	1
47	398781	Main Building	Fountain	Bathroom Water Fountain	1 of 1	Water Fountain	center	<1
48	398783	Main Building	Sink	Staff Lounge Rm.415	1 of 1	Tap	center	<1
49	398784	Kindergarten Building	Fountain/Tap Combo	Preschool Rm. 1	1 of 1	Tap	left	<1
50	398788	Kindergarten Building	Sink - Multi-Compartment	Commons	1 of 1	Tap	center	<1
51	398789	Main Building	Fountain/Tap Combo	Rm. 313	1 of 1	Tap	left	<1
52	398793	Main Building	Fountain	300 Wing Bathroom Water Fountain	1 of 1	Water Fountain	right	<1
53	398795	Main Building	Fountain/Tap Combo	Rm.316	1 of 1	Tap	left	<1
54	398799	Main Building	Fountain/Tap Combo	Rm.315	1 of 1	Tap	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
55	398802	Main Building	Fountain	Gym/Commons	1 of 1	Water Fountain	center	<1
56	398804	Main Building	Fountain/Tap Combo	Rm.416	1 of 1	Tap	left	<1
57	398807	Main Building	Fountain/Tap Combo	Rm.318	1 of 1	Tap	left	<1
58	398821	Main Building	Fountain	Softball Field	1 of 1	Water Fountain	center	<1
59	398824	Main Building	Fountain/Tap Combo	Rm.320	1 of 1	Water Fountain	right	<1
60	398826	Main Building	Sink	Library	1 of 1	Tap	center	<1
61	398828	Main Building	Sink	Health 216	1 of 1	Tap	center	<1
62	398834	Main Building	Fountain	200 Wing Bathroom Water Fountain	1 of 1	Water Fountain	center	<1
63	398840	Main Building	Fountain/Tap Combo	Rm.210	1 of 1	Tap	left	<1