

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012433603  
**LIMS Reference ID:** AC33603  
**EMSL Customer ID:** COAS80

**Attention:** Cathy Ledden  
 Coastal Environmental Compliance, LLC [COAS80]  
 PO Box 167  
 Hammonton, NJ 08037-0167  
 (609) 820-9312  
 coastalenvironmental@hotmail.com

**Project Name:** Shawnee HS Pb/H2O Non-Compliant Water Testing 2024

**Customer PO:**  
**EMSL Sales Rep:** Josh Silverman  
**Received:** 10/09/2024 12:00  
**Reported:** 10/24/2024 16:15

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: 1-SHAW-POE/Pump House</b>									
				<b>Lims Reference ID:</b>	<b>AC33603-01</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 10/09/24 05:00:00</b>	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:44	10/23/24 15:08	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 2-SHAW-DW/Sink B102</b>									
				<b>Lims Reference ID:</b>	<b>AC33603-02</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 10/09/24 05:01:00</b>	
<b>Metals</b>									
Lead	2.66		1	1.00	µg/L	10/22/24 16:44	10/23/24 15:13	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 4-SHAW-EC/Sink-1 B101 Home Ec</b>									
				<b>Lims Reference ID:</b>	<b>AC33603-03</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 10/09/24 05:02:00</b>	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:44	10/23/24 15:15	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 5-SHAW-EC/Sink-2 B101 Home Ec</b>									
				<b>Lims Reference ID:</b>	<b>AC33603-04</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 10/09/24 05:03:00</b>	
<b>Metals</b>									
Lead	3.26		1	1.00	µg/L	10/22/24 16:44	10/23/24 15:17	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 6-SHAW-EC/Sink-3 B101 Home Ec</b>									
				<b>Lims Reference ID:</b>	<b>AC33603-05</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 10/09/24 05:04:00</b>	
<b>Metals</b>									
Lead	2.75		1	1.00	µg/L	10/22/24 16:44	10/23/24 15:19	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 7-SHAW-EC/Sink-4 B101 Home Ec</b>									
				<b>Lims Reference ID:</b>	<b>AC33603-06</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 10/09/24 05:05:00</b>	
<b>Metals</b>									
Lead	2.04		1	1.00	µg/L	10/22/24 16:44	10/23/24 15:49	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 8-SHAW-EC/Sink-5 B101 Home Ec</b>									
				<b>Lims Reference ID:</b>	<b>AC33603-07</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 10/09/24 05:06:00</b>	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:44	10/23/24 15:52	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 9-SHAW-EC/Sink-1 B100</b>									
				<b>Lims Reference ID:</b>	<b>AC33603-08</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 10/09/24 05:07:00</b>	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:44	10/23/24 15:54	PL	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 10-SHAW-EC/Sink-2 B100</b>									
				<b>Lims Reference ID:</b>	<b>AC33603-09</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 10/09/24 05:08:00</b>	
<b>Metals</b>									
Lead	1.21		1	1.00	µg/L	10/22/24 16:44	10/23/24 15:56	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012433603  
**LIMS Reference ID:** AC33603  
**EMSL Customer ID:** COAS80

**Attention:** Cathy Ledden  
 Coastal Environmental Compliance, LLC [COAS80]  
 PO Box 167  
 Hammonton, NJ 08037-0167  
 (609) 820-9312  
 coastalenvironmental@hotmail.com

**Project Name:** Shawnee HS Pb/H2O Non-Compliant Water Testing 2024

**Customer PO:**  
**EMSL Sales Rep:** Josh Silverman  
**Received:** 10/09/2024 12:00  
**Reported:** 10/24/2024 16:15

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 11-SHAW-EC/Sink-3 B100 Lims Reference ID: AC33603-10 Matrix: Drinking Water Sampled: 10/09/24 05:09:00									
<b>Metals</b>									
Lead	2.06		1	1.00	µg/L	10/22/24 16:44	10/23/24 15:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-SHAW-EC/Sink-4 B100 Lims Reference ID: AC33603-11 Matrix: Drinking Water Sampled: 10/09/24 05:10:00									
<b>Metals</b>									
Lead	1.61		1	1.00	µg/L	10/22/24 16:44	10/23/24 16:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 13-SHAW-DW/Sink Cust Break Rm Near Receiving Lims Reference ID: AC33603-12 Matrix: Drinking Water Sampled: 10/09/24 05:11:00									
<b>Metals</b>									
Lead	1.40		1	1.00	µg/L	10/22/24 16:44	10/23/24 16:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 15-SHAW-WC/Main Cafe BF Right Lims Reference ID: AC33603-13 Matrix: Drinking Water Sampled: 10/09/24 05:12:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:44	10/23/24 16:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 17-SHAW-FP/Prep Sink 1 Kitchen Lims Reference ID: AC33603-14 Matrix: Drinking Water Sampled: 10/09/24 05:13:00									
<b>Metals</b>									
Lead	3.95		1	1.00	µg/L	10/22/24 16:44	10/23/24 16:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 18-SHAW-FP/Prep Sink 2 Kitchen Lims Reference ID: AC33603-15 Matrix: Drinking Water Sampled: 10/09/24 05:14:00									
<b>Metals</b>									
Lead	11.8		1	1.00	µg/L	10/22/24 16:44	10/23/24 16:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 19-SHAW-IM/Ice Machine Kitchen Lims Reference ID: AC33603-16 Matrix: Drinking Water Sampled: 10/09/24 05:15:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:44	10/23/24 16:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 20-SHAW-FP/Coffee Maker 1 Left Kitchen Lims Reference ID: AC33603-17 Matrix: Drinking Water Sampled: 10/09/24 05:16:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:44	10/23/24 16:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 21-SHAW-FP/Coffee Maker 2 Right Kitchen Lims Reference ID: AC33603-18 Matrix: Drinking Water Sampled: 10/09/24 05:17:00									
<b>Metals</b>									
Lead	1.04		1	1.00	µg/L	10/22/24 16:44	10/23/24 16:22	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012433603  
**LIMS Reference ID:** AC33603  
**EMSL Customer ID:** COAS80

**Attention:** Cathy Ledden  
 Coastal Environmental Compliance, LLC [COAS80]  
 PO Box 167  
 Hammonton, NJ 08037-0167  
 (609) 820-9312  
 coastalenvironmental@hotmail.com

**Project Name:** Shawnee HS Pb/H2O Non-Compliant Water Testing 2024  
**Customer PO:**  
**EMSL Sales Rep:** Josh Silverman  
**Received:** 10/09/2024 12:00  
**Reported:** 10/24/2024 16:15

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 22-SHAW-FP/Steamer Kitchen Lims Reference ID: AC33603-19 Matrix: Drinking Water Sampled: 10/09/24 05:18:00									
<b>Metals</b>									
Lead	1.34		1	1.00	µg/L	10/22/24 16:44	10/23/24 16:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 24-SHAW-TL/Sink B101-10 Faculty Dining Lims Reference ID: AC33603-20 Matrix: Drinking Water Sampled: 10/09/24 05:19:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:44	10/23/24 16:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 26-SHAW-DW/Sink A109 Lims Reference ID: AC33603-21 Matrix: Drinking Water Sampled: 10/09/24 05:20:00									
<b>Metals</b>									
Lead	2.03		1	1.00	µg/L	10/22/24 16:46	10/23/24 16:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 27-SHAW-DW/Eyewash A109 Lims Reference ID: AC33603-22 Matrix: Drinking Water Sampled: 10/09/24 05:21:00									
<b>Metals</b>									
Lead	2.81		1	1.00	µg/L	10/22/24 16:46	10/23/24 16:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 28-SHAW-DW/Sink A111 Lims Reference ID: AC33603-23 Matrix: Drinking Water Sampled: 10/09/24 05:22:00									
<b>Metals</b>									
Lead	4.03		1	1.00	µg/L	10/22/24 16:46	10/23/24 16:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 29-SHAW-DW/Sink A112 Lims Reference ID: AC33603-24 Matrix: Drinking Water Sampled: 10/09/24 05:23:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:46	10/23/24 16:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 30-SHAW-DW/Eyewash A112 Lims Reference ID: AC33603-25 Matrix: Drinking Water Sampled: 10/09/24 05:24:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:46	10/23/24 16:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 31-SHAW-DW/Sink A106 Lims Reference ID: AC33603-26 Matrix: Drinking Water Sampled: 10/09/24 05:25:00									
<b>Metals</b>									
Lead	3.20		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 32-SHAW-DW/BF - Main Hallway Near Entrance Lims Reference ID: AC33603-27 Matrix: Drinking Water Sampled: 10/09/24 05:26:00									
<b>Metals</b>									
Lead	1.09		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:05	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012433603  
**LIMS Reference ID:** AC33603  
**EMSL Customer ID:** COAS80

**Attention:** Cathy Ledden  
 Coastal Environmental Compliance, LLC [COAS80]  
 PO Box 167  
 Hammonton, NJ 08037-0167  
 (609) 820-9312  
 coastalenvironmental@hotmail.com

**Project Name:** Shawnee HS Pb/H2O Non-Compliant Water Testing 2024

**Customer PO:**  
**EMSL Sales Rep:** Josh Silverman  
**Received:** 10/09/2024 12:00  
**Reported:** 10/24/2024 16:15

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 33-SHAW-DW/Sink Main Off Work Rm      Lims Reference ID: AC33603-28 Matrix: Drinking Water      Sampled: 10/09/24 05:27:00									
<b>Metals</b>									
Lead	3.26		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 34-SHAW-IM/Ice Maker Nurse      Lims Reference ID: AC33603-29 Matrix: Drinking Water      Sampled: 10/09/24 05:28:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 35-SHAW-NS/Sink Nurse      Lims Reference ID: AC33603-30 Matrix: Drinking Water      Sampled: 10/09/24 05:29:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 36-SHAW-NS/Sink 2 Nurse      Lims Reference ID: AC33603-31 Matrix: Drinking Water      Sampled: 10/09/24 05:30:00									
<b>Metals</b>									
Lead	1.30		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 37-SHAW-NS/Sink 3 Nurse      Lims Reference ID: AC33603-32 Matrix: Drinking Water      Sampled: 10/09/24 05:31:00									
<b>Metals</b>									
Lead	6.97		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 38-SHAW-DW/Sink Cst Room      Lims Reference ID: AC33603-33 Matrix: Drinking Water      Sampled: 10/09/24 05:32:00									
<b>Metals</b>									
Lead	1.67		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 40-SHAW-DW/Sink A103      Lims Reference ID: AC33603-34 Matrix: Drinking Water      Sampled: 10/09/24 05:33:00									
<b>Metals</b>									
Lead	4.22		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 41-SHAW-DW/Sink A102 Art Room Left      Lims Reference ID: AC33603-35 Matrix: Drinking Water      Sampled: 10/09/24 05:34:00									
<b>Metals</b>									
Lead	2.06		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 42-SHAW-DW/Sink A102 Art Room Center      Lims Reference ID: AC33603-36 Matrix: Drinking Water      Sampled: 10/09/24 05:35:00									
<b>Metals</b>									
Lead	2.34		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:32	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012433603  
**LIMS Reference ID:** AC33603  
**EMSL Customer ID:** COAS80

**Attention:** Cathy Ledden  
 Coastal Environmental Compliance, LLC [COAS80]  
 PO Box 167  
 Hammonton, NJ 08037-0167  
 (609) 820-9312  
 coastalenvironmental@hotmail.com

**Project Name:** Shawnee HS Pb/H2O Non-Compliant Water Testing 2024

**Customer PO:**  
**EMSL Sales Rep:** Josh Silverman  
**Received:** 10/09/2024 12:00  
**Reported:** 10/24/2024 16:15

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 43-SHAW-DW/Sink A102 Art Room Right Lims Reference ID: AC33603-37 Matrix: Drinking Water Sampled: 10/09/24 05:36:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 45-SHAW-WC/BF Right Music Hall Lims Reference ID: AC33603-38 Matrix: Drinking Water Sampled: 10/09/24 05:37:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 46-SHAW-DW/Sink F113 Band Room Lims Reference ID: AC33603-39 Matrix: Drinking Water Sampled: 10/09/24 05:38:00									
<b>Metals</b>									
Lead	14.7		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 48-SHAW-WC/BF Auditorium Atrium Hall Lims Reference ID: AC33603-40 Matrix: Drinking Water Sampled: 10/09/24 05:39:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:46	10/23/24 17:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 50-SHAW-WC/BF F Hallway BF Lims Reference ID: AC33603-41 Matrix: Drinking Water Sampled: 10/09/24 05:40:00									
<b>Metals</b>									
Lead	1.87		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 51-SHAW-DW/Sink Left Room F114 Lims Reference ID: AC33603-42 Matrix: Drinking Water Sampled: 10/09/24 05:41:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 52-SHAW-DW/Sink Middle Room F114 Lims Reference ID: AC33603-43 Matrix: Drinking Water Sampled: 10/09/24 05:42:00									
<b>Metals</b>									
Lead	1.88		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 53-SHAW-DW/Sink Right Room F114 Lims Reference ID: AC33603-44 Matrix: Drinking Water Sampled: 10/09/24 05:43:00									
<b>Metals</b>									
Lead	1.19		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 54-SHAW-DW/Sink F115 Lims Reference ID: AC33603-45 Matrix: Drinking Water Sampled: 10/09/24 05:44:00									
<b>Metals</b>									
Lead	3.78		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:19	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012433603  
**LIMS Reference ID:** AC33603  
**EMSL Customer ID:** COAS80

**Attention:** Cathy Ledden  
 Coastal Environmental Compliance, LLC [COAS80]  
 PO Box 167  
 Hammonton, NJ 08037-0167  
 (609) 820-9312  
 coastalenvironmental@hotmail.com

**Project Name:** Shawnee HS Pb/H2O Non-Compliant Water Testing 2024

**Customer PO:**  
**EMSL Sales Rep:** Josh Silverman  
**Received:** 10/09/2024 12:00  
**Reported:** 10/24/2024 16:15

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 57-SHAW-WC/BF Lower D Hall Near Planning Ctr Lims Reference ID: AC33603-46 Matrix: Drinking Water Sampled: 10/09/24 05:46:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 60-SHAW-WC/BF Rm D112 Esport D-Hall Lims Reference ID: AC33603-47 Matrix: Drinking Water Sampled: 10/09/24 05:47:00									
<b>Metals</b>									
Lead	1.56		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 62-SHAW-WC/BF Lower D Hall Near Bathrooms Lims Reference ID: AC33603-48 Matrix: Drinking Water Sampled: 10/09/24 05:48:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 65-SHAW-DW/Sink C130-1 Lower Media Ctr Off Lims Reference ID: AC33603-49 Matrix: Drinking Water Sampled: 10/09/24 05:49:00									
<b>Metals</b>									
Lead	2.78		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 66-SHAW-DW/BF Gym Hall Near Girls Locker Lims Reference ID: AC33603-50 Matrix: Drinking Water Sampled: 10/09/24 05:50:00									
<b>Metals</b>									
Lead	3.38		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 72-SHAW-WC/BF Girls Locker Vestibul Lims Reference ID: AC33603-51 Matrix: Drinking Water Sampled: 10/09/24 05:51:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 74-SHAW-IM/Ice Maker Girl Gym Side Storage Lims Reference ID: AC33603-52 Matrix: Drinking Water Sampled: 10/09/24 05:52:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 75-SHAW-WC/BF Boys Gym Back Vestibul Lims Reference ID: AC33603-53 Matrix: Drinking Water Sampled: 10/09/24 05:53:00									
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:42	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012433603  
**LIMS Reference ID:** AC33603  
**EMSL Customer ID:** COAS80

**Attention:** Cathy Ledden  
 Coastal Environmental Compliance, LLC [COAS80]  
 PO Box 167  
 Hammonton, NJ 08037-0167  
 (609) 820-9312  
 coastalenvironmental@hotmail.com

**Project Name:** Shawnee HS Pb/H2O Non-Compliant Water Testing 2024  
**Customer PO:**  
**EMSL Sales Rep:** Josh Silverman  
**Received:** 10/09/2024 12:00  
**Reported:** 10/24/2024 16:15

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 79-SHAW-DW/BF Gym Hall Near Football Off									
			Lims Reference ID:		AC33603-54	Matrix: Drinking Water		Sampled: 10/09/24 05:54:00	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 80-SHAW-WC/BF B107 Cardio Room									
			Lims Reference ID:		AC33603-55	Matrix: Drinking Water		Sampled: 10/09/24 05:55:00	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 81-SHAW-DW/Sink B106 Trainer									
			Lims Reference ID:		AC33603-56	Matrix: Drinking Water		Sampled: 10/09/24 05:56:00	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 82 - SHAW-IM/Ice Maker Trainer									
			Lims Reference ID:		AC33603-57	Matrix: Drinking Water		Sampled: 10/09/24 05:57:00	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 83-SHAW-TL/Sink B104 - Faculty Lounge									
			Lims Reference ID:		AC33603-58	Matrix: Drinking Water		Sampled: 10/09/24 05:58:00	
<b>Metals</b>									
Lead	2.02		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 84-SHAW-DW/Sink C228-2 Upper Media Off									
			Lims Reference ID:		AC33603-59	Matrix: Drinking Water		Sampled: 10/09/24 05:59:00	
<b>Metals</b>									
Lead	1.71		1	1.00	µg/L	10/22/24 16:48	10/23/24 22:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 86-SHAW-WC/BF Upper D Wing Near Bathrooms									
			Lims Reference ID:		AC33603-60	Matrix: Drinking Water		Sampled: 10/09/24 06:00:00	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 16:48	10/23/24 23:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 89-SHAW-WC/BF Upper D Wing Near PC7									
			Lims Reference ID:		AC33603-61	Matrix: Drinking Water		Sampled: 10/09/24 06:01:00	
<b>Metals</b>									
Lead	ND		1	1.00	µg/L	10/22/24 17:01	10/23/24 21:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 92-SHAW-FP/Sink Guest Side Concession									
			Lims Reference ID:		AC33603-62	Matrix: Drinking Water		Sampled: 10/09/24 06:02:00	
<b>Metals</b>									
Lead	1.69		1	1.00	µg/L	10/22/24 17:01	10/23/24 21:31	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012433603  
**LIMS Reference ID:** AC33603  
**EMSL Customer ID:** COAS80

**Attention:** Cathy Ledden  
 Coastal Environmental Compliance, LLC [COAS80]  
 PO Box 167  
 Hammonton, NJ 08037-0167  
 (609) 820-9312  
 coastalenvironmental@hotmail.com

**Project Name:** Shawnee HS Pb/H2O Non-Compliant Water Testing 2024

**Customer PO:**  
**EMSL Sales Rep:** Josh Silverman  
**Received:** 10/09/2024 12:00  
**Reported:** 10/24/2024 16:15

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: 92-SHAW-FP/Sink Guest Side Concession (Continued) Lims Reference ID: AC33603-62 Matrix: Drinking Water Sampled: 10/09/24 06:02:00

**Metals (Continued)**

Sample: 93-SHAW-FP/Sink Left Home Side Concession Lims Reference ID: AC33603-63 Matrix: Drinking Water Sampled: 10/09/24 06:03:00

**Metals**

Lead	1.39		1	1.00	µg/L	10/22/24 17:01	10/23/24 21:33	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 93-1-SHAW-FP/Sink Right Home Side Concession Lims Reference ID: AC33603-64 Matrix: Drinking Water Sampled: 10/09/24 06:04:00

**Metals**

Lead	ND		1	1.00	µg/L	10/22/24 17:01	10/23/24 21:39	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 94-SHAW-IM/Ice Maker Home Side Concession Lims Reference ID: AC33603-65 Matrix: Drinking Water Sampled: 10/09/24 06:05:00

**Metals**

Lead	ND		1	1.00	µg/L	10/22/24 17:01	10/23/24 21:41	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 95-SHAW-FP/Coffee Maker Home Side Concession Lims Reference ID: AC33603-66 Matrix: Drinking Water Sampled: 10/09/24 06:06:00

**Metals**

Lead	ND		1	1.00	µg/L	10/22/24 17:01	10/23/24 21:43	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SHAW-Blank/Coffee Maker Home Side Concession Lims Reference ID: AC33603-67 Matrix: Drinking Water Sampled: 10/09/24 00:00:00

**Metals**

Lead	ND		1	1.00	µg/L	10/22/24 17:01	10/23/24 21:45	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
Telephone: 856-858-4800 Fax:856-786-5974  
EMSL-CIN-01

**EMSL Order ID:** 012433603  
**LIMS Reference ID:** AC33603  
**EMSL Customer ID:** COAS80

**Attention:** Cathy Ledden  
Coastal Environmental Compliance, LLC [COAS80]  
PO Box 167  
Hammonton, NJ 08037-0167  
(609) 820-9312  
coastalenvironmental@hotmail.com

**Project Name:** Shawnee HS Pb/H2O Non-Compliant Water Testing 2024

**Customer PO:**  
**EMSL Sales Rep:** Josh Silverman  
**Received:** 10/09/2024 12:00  
**Reported:** 10/24/2024 16:15

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	NJDEP

**List of Certifications**

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2024
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	01/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
Telephone: 856-858-4800 Fax:856-786-5974  
EMSL-CIN-01

**EMSL Order ID:** 012433603  
**LIMS Reference ID:** AC33603  
**EMSL Customer ID:** COAS80

**Attention:** Cathy Ledden  
Coastal Environmental Compliance, LLC [COAS80]  
PO Box 167  
Hammonton, NJ 08037-0167  
(609) 820-9312  
coastalenvironmental@hotmail.com

**Project Name:** Shawnee HS Pb/H2O Non-Compliant Water Testing 2024

**Customer PO:**  
**EMSL Sales Rep:** Josh Silverman  
**Received:** 10/09/2024 12:00  
**Reported:** 10/24/2024 16:15

**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC. TESTING LABS • PRODUCTS • TRAINING

### Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

AC 33603

Customer Information	Customer ID: COAS80	Billing Information	Billing ID:
	Company Name: Coastal Environmental Compliance		Company Name: Same
	Contact Name: Cathy Ledden		Billing Contact:
	Street Address: PO Box 167		Street Address:
	City, State, Zip: Hammonton, NJ 08037		Country:
	Phone: 609-820-9312		Country:
Email(s) for Report: coastalenvironmental@hotmail.com		Email(s) for Invoice:	

Project Information		
Project Name/No: SHAWNEE HS Pb/H2O Non-Compliant Water Testing 2024	Purchase Order:	
EMSL LIMS Project ID: (If applicable, EMSL will provide)	US State where samples collected: NJ	State of Connecticut (CT) must select project location: <input type="checkbox"/> Commercial (Taxable) <input type="checkbox"/> Residential (Non-Taxable)
Sampled By Name: Cathy Ledden	Sampled By Signature: <i>Cathy Ledden</i>	No. of Samples in Shipment

Turn-Around-Time (TAT)

3 Hour  
 6 Hour  
 24 Hour  
 32 Hour  
 48 Hour  
 72 Hour  
 96 Hour  
 1 Week  
 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. \*32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS* <input type="checkbox"/> % by wt. <input type="checkbox"/> ppm (mg/kg) <input type="checkbox"/> mg/cm <sup>2</sup> <small>*Chips reporting Limit based on a minimum 0.25g sample weight. Not appropriate for Ceramic Tiles - XRF is recommended.</small>	SW 846-7000B	Flame Atomic Absorption	-0.008% -80 ppm -mg/cm <sup>2</sup> - RL is Variable	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	-0.0004% -40 ppm -mg/cm <sup>2</sup> - RL is Variable	<input type="checkbox"/>
AIR	NIOSH 7082	Flame Atomic Absorption	4µg/filter	<input type="checkbox"/>
	NIOSH 7303M	ICP-OES	1.0µg/filter	<input type="checkbox"/>
	NIOSH 7303M	ICP-MS	0.05µg/filter	<input type="checkbox"/>
WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM <small>*If no box is checked, non-ASTM Wipe is assumed</small>	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	1.0µg/wipe	<input type="checkbox"/>
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
SPLP	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
STLC	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
Soil	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
Wastewater Unpreserved <input type="checkbox"/> Preserved with HNO3 <input type="checkbox"/> PH<2	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
Drinking Water Unpreserved <input checked="" type="checkbox"/> Preserved with HNO3 <input type="checkbox"/> PH<2	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input type="checkbox"/>
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	<input type="checkbox"/>
Other:				<input type="checkbox"/>

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1-SHAW-POE	PUMP HOUSE		10/9/24 500
2-SHAW-DW	SINK B102		501
4-SHAW-EC	SINK-1 B101 HOME EC		502
5-SHAW-EC	SINK-2 B101 HOME EC		503
6-SHAW-EC	SINK-3 B101 HOME EC		504

Method of Shipment:	Sample Condition Upon Receipt:
Relinquished by: <i>Cathy Ledden</i>	Received by: <i>M. Murnighan</i>
Date/Time: 10/9/24	Date/Time: 10/09/24 12pm
Relinquished by:	Received by:
Date/Time:	Date/Time:

Controlled Document COC-25 Lead R19 08/19/2024

\*6010C Available Upon Request

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

*Preserved 10:50*





# Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.  
TESTING LABS • PRODUCTS • TRAINING

AC33603

PHONE: (800) 220-3675


EMAIL: CinnaminsonLeadLab@emsl.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

NEED Excell Results Form

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
7-SHAW-EC	SINK4 B101 HOME EC		10/9/24 505
8-SHAW-EC	SINK5 B101 HOME EC		506
9-SHAW-EC	SINK1 B100		507
10-SHAW-EC	SINK2 B100		508
11-SHAW-EC	SINK3 B100		509
12-SHAW-EC	SINK4 B100		510
13-SHAW-DW	SINK CUST BREAK RM NEAR RECEIVING		511
15-SHAW-WC	MAIN CAFE BF RIGHT		512
17-SHAW-FP	PREP SINK 1 KITCHEN		513
18-SHAW-FP	PREP SINK 2 KITCHEN		514
19-SHAW-IM	ICE MACHINE KITCHEN		515
20-SHAW-FP	COFFEE MAKER 1 LEFT KITCHEN		516
21-SHAW-FP	COFFEE MAKE 2 RIGHT KITCHEN		517
22-SHAW-FP	STEAMER KITCHEN		518
24-SHAW-TL	SINK B101-10 FACULTY DINING		519
26-SHAW-DW	SINK A109		520
27-SHAW-DW	EYE WASH A109		521
28-SHAW-DW	SINK A111		522
29-SHAW-DW	SINK A112		523
30-SHAW-DW	EYE WASH A112		524
31-SHAW-DW	SINK A106		525
32-SHAW-DW	BF - MAIN HALLWAY NEAR ENTERANCE		526
33-SHAW-DW	SINK MAIN OFF WORK RM		527
34-SHAW-IM	ICE MAKER NURSE		528
35-SHAW-NS	SINK NURSE		529



Method of Shipment:

Sample Condition Upon Receipt:

Relinquished by:

Date/Time:

Received by:

Date/Time:

*Stornely*

10/09/24 12pm

Relinquished by:

Date/Time:

Received by:

Date/Time:

Controlled Document COC-25 Lead R19 08/19/2024



AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.





### Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

EMSL ANALYTICAL, INC.  
TESTING LABS • PRODUCTS • TRAINING

AC33603

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
36-SHAW-NS	SINK 2 NURSE		10/9/24 530
37-SHAW-NS	SINK 3 NURSE		531
38-SHAW-DW	SINK CST ROOM		532
40-SHAW-DW	SINK A103		533
41-SHAW-DW	SINK A102 ART ROOM LEFT		534
42-SHAW-DW	SINK A102 ART ROOM CENTER		535
43-SHAW-DW	SINK A102 ART ROOM RIGHT		536
45-SHAW-WC	BF RIGHT MUSIC HALL		537
46-SHAW-DW	SINK F113 BAND ROOM		538
48-SHAW-WC	BF AUDITORIUM ATRIUM HALL		539
50-SHAW-WC	BF - F HALLWAY		540
51-SHAW-DW	SINK LEFT ROOM F114		541
52-SHAW-DW	SINK MIDDLE ROOM F114		542
53-SHAW-DW	SINK RIGHT ROOM F114		543
54-SHAW-DW	SINK F115		544
55-SHAW-DW	SINK SCENE SHOP		545
57-SHAW-WC	BF LOWER D HALL NEAR PLANNING CTR		546
60-SHAW-WC	BF RM D112 ESPORT D-HALL		547
62-SHAW-WC	BF LOWER D HALL NEAR BATHROOMS		548
65-SHAW-DW	SINK C130-1 LOWER MEDIA CTR OFF		549
66-SHAW-DW	BF GYM HALL NEAR GIRLS LOCKER		550
72-SHAW-WC	BF GIRLS LOCKER VESTIBUL		551
74-SHAW-IM	ICE MAKER GIRL GYM SIDE STORAGE		552
75-SHAW-WC	BF BOYS GYM BACK VESTIBUL		553
79-SHAW-DW	BF GYM HALL NEAR FOOTBALL OFF		554

Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by:	Date/Time:	Received by: <i>Stonelly</i>	Date/Time: 10/09/24 12pm
Relinquished by:	Date/Time:	Received by:	Date/Time:

Controlled Document COC-25 Lead R19 08/19/2024

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



# Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.  
TESTING LABS • PRODUCTS • TRAINING

AC33603

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
80-SHAW-WC	BF B107 CARDIO ROOM		10/9/24 555
81-SHAW-DW	SINK B106 TRAINER		556
82-SHAW-IM	ICE MAKER TRAINER		557
83-SHAW-TL	SINK B104 - FACULTY LOUNGE		558
84-SHAW-DW	SINK C228-2 UPPER MEDIA OFF		559
86-SHAW-WC	BF UPPER D WING NEAR BATHROOMS		600
89-SHAW-WC	BF UPPER D WING NEAR PC7		601
92-SHAW-FP	SINK GUEST SIDE CONCESSION		602
93-SHAW-FP	SINK LEFT HOME SIDE CONCESSION		603
93-1-SHAW-FP	SINK RIGHT HOME SIDE CONCESSION		604
94-SHAW-IM	ICE MAKER HOME SIDE CONCESSION		605
95-SHAW-FP	COFFEE MAKER HOME SIDE CONCESSION		606
Blank			

Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by:	Date/Time:	Received by: <i>[Signature]</i>	Date/Time: 10/09/24 12pm
Relinquished by:	Date/Time:	Received by:	Date/Time:

Controlled Document COC-25 Lead R19 08/19/2024

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.