

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012433463
LIMS Reference ID: AC33463
EMSL Customer ID: COAS80

Attention: Cathy Ledden
 Coastal Environmental Compliance, LLC [COAS80]
 PO Box 167
 Hammonton, NJ 08037-0167
 (609) 820-9312
 coastalenvironmental@hotmail.com

Project Name: Cherokee HS - South - PB/H2O Non-Compliant Water Test 2024
Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/10/2024 09:30
Reported: 10/25/2024 17:22

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1-CHSS-POE POE CC111 Cust. Break Room Lims Reference ID: AC33463-01 Matrix: Drinking Water Sampled: 10/10/24 05:40:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:36	10/24/24 20:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3-CHSS-DW Sink CC117 Kitchen Break room Lims Reference ID: AC33463-02 Matrix: Drinking Water Sampled: 10/10/24 05:41:00									
Metals									
Lead	2.07		1	1.00	µg/L	10/23/24 16:36	10/24/24 20:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5-CHSS-KC Sink CC120 Kitchen Lims Reference ID: AC33463-03 Matrix: Drinking Water Sampled: 10/10/24 05:42:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:36	10/24/24 20:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6-CHSS-KC Sink CC120 Kitchen Lims Reference ID: AC33463-04 Matrix: Drinking Water Sampled: 10/10/24 05:43:00									
Metals									
Lead	1.67		1	1.00	µg/L	10/23/24 16:36	10/24/24 20:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7-CHSS-KC Sink CC120 Kitchen Lims Reference ID: AC33463-05 Matrix: Drinking Water Sampled: 10/10/24 05:44:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:36	10/24/24 20:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8-CHSS-KC Sink Left CC120 Kitchen Lims Reference ID: AC33463-06 Matrix: Drinking Water Sampled: 10/10/24 05:45:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:36	10/24/24 20:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8A-CHSS-KC Sink Right CC120 Kitchen Lims Reference ID: AC33463-07 Matrix: Drinking Water Sampled: 10/10/24 05:46:00									
Metals									
Lead	1.15		1	1.00	µg/L	10/23/24 16:36	10/24/24 20:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 9-CHSS-IM Ice Maker CC120 Kitchen Lims Reference ID: AC33463-08 Matrix: Drinking Water Sampled: 10/10/24 05:47:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:36	10/24/24 20:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 10-CHSS-FP Coffee Maker Left CC120 Kitchen Lims Reference ID: AC33463-09 Matrix: Drinking Water Sampled: 10/10/24 05:48:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:36	10/24/24 20:55	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012433463
LIMS Reference ID: AC33463
EMSL Customer ID: COAS80

Attention: Cathy Ledden
 Coastal Environmental Compliance, LLC [COAS80]
 PO Box 167
 Hammonton, NJ 08037-0167
 (609) 820-9312
 coastalenvironmental@hotmail.com

Project Name: Cherokee HS - South - PB/H2O Non-Compliant Water Test 2024
Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/10/2024 09:30
Reported: 10/25/2024 17:22

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: 10-CHSS-FP Coffee Maker Left CC120 Kitchen (Continued) Lims Reference ID: AC33463-09 Matrix: Drinking Water Sampled: 10/10/24 05:48:00

Metals (Continued)

Sample: 11-CHSS-FP Coffee Maker Right CC120 Kitchen Lims Reference ID: AC33463-10 Matrix: Drinking Water Sampled: 10/10/24 05:49:00

Metals

Lead	6.24	1	1.00	µg/L	10/23/24 16:36	10/24/24 20:57	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 14-CHSS-Fp Steam Oven CC100 Kitchen Lims Reference ID: AC33463-11 Matrix: Drinking Water Sampled: 10/10/24 05:51:00

Metals

Lead	1.77	1	1.00	µg/L	10/23/24 16:36	10/24/24 20:59	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 15-CHSS-WC Fountain CC100 S Cafe Left Lims Reference ID: AC33463-12 Matrix: Drinking Water Sampled: 10/10/24 05:52:00

Metals

Lead	ND	1	1.00	µg/L	10/23/24 16:36	10/24/24 21:05	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 19-CHSS-WC BF Hall Near DD 107 A/B Lims Reference ID: AC33463-13 Matrix: Drinking Water Sampled: 10/10/24 05:54:00

Metals

Lead	ND	1	1.00	µg/L	10/23/24 16:36	10/24/24 21:07	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 20-CHSS-DW Sink DD109 (In Room DD108) Lims Reference ID: AC33463-14 Matrix: Drinking Water Sampled: 10/10/24 05:55:00

Metals

Lead	8.76	1	1.00	µg/L	10/23/24 16:36	10/24/24 21:13	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 21-CHSS-DW Sink EE101 Lims Reference ID: AC33463-15 Matrix: Drinking Water Sampled: 10/10/24 05:56:00

Metals

Lead	2.06	1	1.00	µg/L	10/23/24 16:36	10/24/24 21:14	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 22-CHSS-DW Sink EE101 Lims Reference ID: AC33463-16 Matrix: Drinking Water Sampled: 10/10/24 05:57:00

Metals

Lead	ND	1	1.00	µg/L	10/23/24 16:36	10/24/24 21:16	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 23-CHSS-DW Sink EE101 Lims Reference ID: AC33463-17 Matrix: Drinking Water Sampled: 10/10/24 05:58:00

Metals

Lead	ND	1	1.00	µg/L	10/23/24 16:36	10/24/24 21:18	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012433463
LIMS Reference ID: AC33463
EMSL Customer ID: COAS80

Attention: Cathy Ledden
 Coastal Environmental Compliance, LLC [COAS80]
 PO Box 167
 Hammonton, NJ 08037-0167
 (609) 820-9312
 coastalenvironmental@hotmail.com

Project Name: Cherokee HS - South - PB/H2O Non-Compliant Water Test 2024
Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/10/2024 09:30
Reported: 10/25/2024 17:22

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 24-CHSS-EC Sink EE103 Lims Reference ID: AC33463-18 Matrix: Drinking Water Sampled: 10/10/24 05:59:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:36	10/24/24 21:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 25-CHSS-EC Sink EE103 Lims Reference ID: AC33463-19 Matrix: Drinking Water Sampled: 10/10/24 06:00:00									
Metals									
Lead	1.26		1	1.00	µg/L	10/23/24 16:36	10/24/24 21:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 26-CHSS-EC Sink EE103 Lims Reference ID: AC33463-20 Matrix: Drinking Water Sampled: 10/10/24 06:01:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:36	10/24/24 21:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 27-CHSS-EC Sink EE103 Lims Reference ID: AC33463-21 Matrix: Drinking Water Sampled: 10/10/24 06:02:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 21:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 28-CHSS-EC Sink EE103 Lims Reference ID: AC33463-22 Matrix: Drinking Water Sampled: 10/10/24 06:03:00									
Metals									
Lead	1.81		1	1.00	µg/L	10/23/24 16:39	10/24/24 21:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 29-CHSS-EC Sink EE103 Lims Reference ID: AC33463-23 Matrix: Drinking Water Sampled: 10/10/24 06:04:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 21:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 30-CHSS-DW Fountain EE105 Lims Reference ID: AC33463-24 Matrix: Drinking Water Sampled: 10/10/24 06:05:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 21:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 32-CHSS-WC BF EE106 A-B Hall Right Lims Reference ID: AC33463-25 Matrix: Drinking Water Sampled: 10/10/24 06:06:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 21:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 33-CHSS-WC Fountain FF102 Lims Reference ID: AC33463-26 Matrix: Drinking Water Sampled: 10/10/24 06:07:00									
Metals									
Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:00	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012433463
LIMS Reference ID: AC33463
EMSL Customer ID: COAS80

Attention: Cathy Ledden
 Coastal Environmental Compliance, LLC [COAS80]
 PO Box 167
 Hammonton, NJ 08037-0167
 (609) 820-9312
 coastalenvironmental@hotmail.com

Project Name: Cherokee HS - South - PB/H2O Non-Compliant Water Test 2024
Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/10/2024 09:30
Reported: 10/25/2024 17:22

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: 35-CHSS-WC Fountain EE 208 A-B Hall Right Lims Reference ID: AC33463-27 Matrix: Drinking Water Sampled: 10/10/24 06:08:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:02	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 36-CHSS-DW Sink DD105 Adaptive DP Phys Ed Lims Reference ID: AC33463-28 Matrix: Drinking Water Sampled: 10/10/24 06:09:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:04	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 38-CHSS-WC FB GG110 A-B Lims Reference ID: AC33463-29 Matrix: Drinking Water Sampled: 10/10/24 06:10:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:05	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 40-CHSS-WC BF GG208 A-B Right Lims Reference ID: AC33463-30 Matrix: Drinking Water Sampled: 10/10/24 06:11:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:07	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 41-CHSS-WC Fountain DD213 A-B Right Lims Reference ID: AC33463-31 Matrix: Drinking Water Sampled: 10/10/24 06:12:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:09	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 46-CHSS-DW Sink CC 103 Teachers Room Lims Reference ID: AC33463-32 Matrix: Drinking Water Sampled: 10/10/24 06:13:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:15	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-CHSS-NS Sink AA 143 S Nurse Lims Reference ID: AC33463-33 Matrix: Drinking Water Sampled: 10/10/24 06:14:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:17	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 48-CHSS-NS Sink AA 143 S Nurse Lims Reference ID: AC33463-34 Matrix: Drinking Water Sampled: 10/10/24 06:15:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:23	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 49-CHSS-NS Sink AA 143 S Nurse Lims Reference ID: AC33463-35 Matrix: Drinking Water Sampled: 10/10/24 06:16:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:25	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012433463
LIMS Reference ID: AC33463
EMSL Customer ID: COAS80

Attention: Cathy Ledden
 Coastal Environmental Compliance, LLC [COAS80]
 PO Box 167
 Hammonton, NJ 08037-0167
 (609) 820-9312
 coastalenvironmental@hotmail.com

Project Name: Cherokee HS - South - PB/H2O Non-Compliant Water Test 2024
Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/10/2024 09:30
Reported: 10/25/2024 17:22

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: 49-CHSS-NS Sink AA 143 S Nurse (Continued) Lims Reference ID: AC33463-35 Matrix: Drinking Water Sampled: 10/10/24 06:16:00

Metals (Continued)

Sample: 50-CHSS-IM Ice Maker AA 143 S Nurse Lims Reference ID: AC33463-36 Matrix: Drinking Water Sampled: 10/10/24 06:17:00

Metals

Lead	9.43		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:27	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 52-CHSS-WC BF AA 142 A-B Lims Reference ID: AC33463-37 Matrix: Drinking Water Sampled: 10/10/24 06:18:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:29	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 53-CHSS-DW Sink AA 139 Media Work Room Lims Reference ID: AC33463-38 Matrix: Drinking Water Sampled: 10/10/24 06:19:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:31	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 54-CHSS-FP Sink Main Office Work Room AA102 Lims Reference ID: AC33463-39 Matrix: Drinking Water Sampled: 10/10/24 06:20:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:33	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 55-CHSS-DW Sink AA 129 Trainer Room Lims Reference ID: AC33463-40 Matrix: Drinking Water Sampled: 10/10/24 06:21:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:39	10/24/24 22:35	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 56-CHSS-WC Ice Maker AA 129 Trainer Room Lims Reference ID: AC33463-41 Matrix: Drinking Water Sampled: 10/10/24 06:22:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:41	10/25/24 00:03	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHSS-WC BF HH 101 A-B Lims Reference ID: AC33463-42 Matrix: Drinking Water Sampled: 10/10/24 06:23:00

Metals

Lead	ND		1	1.00	µg/L	10/23/24 16:41	10/25/24 00:09	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: BLANK Lims Reference ID: AC33463-43 Matrix: Drinking Water Sampled: 10/10/24 00:00:00

Metals



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012433463
LIMS Reference ID: AC33463
EMSL Customer ID: COAS80

Attention: Cathy Ledden
Coastal Environmental Compliance, LLC [COAS80]
PO Box 167
Hammonton, NJ 08037-0167
(609) 820-9312
coastalenvironmental@hotmail.com

Project Name: Cherokee HS - South - PB/H2O Non-Compliant Water Test 2024

Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/10/2024 09:30
Reported: 10/25/2024 17:22

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: BLANK (Continued)

Lims Reference ID: AC33463-43 Matrix: Drinking Water

Sampled: 10/10/24 00:00:00

Metals (Continued)

Lead	ND		1	1.00	µg/L	10/23/24 16:41	10/25/24 10:30	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012433463
LIMS Reference ID: AC33463
EMSL Customer ID: COAS80

Attention: Cathy Ledden
 Coastal Environmental Compliance, LLC [COAS80]
 PO Box 167
 Hammonton, NJ 08037-0167
 (609) 820-9312
 coastalenvironmental@hotmail.com

Project Name: Cherokee HS - South - PB/H2O Non-Compliant Water Test 2024

Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/10/2024 09:30
Reported: 10/25/2024 17:22

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2024
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	01/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012433463
LIMS Reference ID: AC33463
EMSL Customer ID: COAS80

Attention: Cathy Ledden
Coastal Environmental Compliance, LLC [COAS80]
PO Box 167
Hammonton, NJ 08037-0167
(609) 820-9312
coastalenvironmental@hotmail.com

Project Name: Cherokee HS - South - PB/H2O Non-Compliant Water Test 2024

Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/10/2024 09:30
Reported: 10/25/2024 17:22

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead Chain of Custody
EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

AC 33463

Customer Information	Customer ID: COAS80		Billing Information	Billing ID:	
	Company Name: COASTAL ENVIRONMENTAL COMPLIANCE			Company Name: SAME	
	Contact Name: CATHY LEDDEN			Billing Contact:	
	Street Address: PO BOX 167			Street Address:	
	City, State, Zip: HAMMONTON NJ	Country:		City, State, Zip:	Country:
	Phone: 609-820-9312			Phone:	
Email(s) for Report: coastalenvironmentalcompliance@hotmail.com		Email(s) for Invoice:			

Project Information		
Project Name/No: Cherokee HS - South - PB/H2O Non-Compliant Water Test 2024	Purchase Order:	
EMSL LIMS Project ID: <small>(If applicable, EMSL will provide)</small>	US State where samples collected: NJ	State of Connecticut (CT) must select project location: <input type="checkbox"/> Commercial (Taxable) <input type="checkbox"/> Residential (Non-Taxable)
Sampled By Name: Cathy Ledden	Sampled By Signature:	No. of Samples in Shipment

Turn-Around-Time (TAT)

3 Hour
 6 Hour
 24 Hour
 32 Hour
 48 Hour
 72 Hour
 96 Hour
 1 Week
 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION	
CHIPS* <input type="checkbox"/> % by wt. <input type="checkbox"/> ppm (mg/kg) <input type="checkbox"/> mg/cm ² <small>*Chips reporting Limit based on a minimum 0.25g sample weight. Not appropriate for Ceramic Tiles - XRF is recommended.</small>	SW 846-7000B	Flame Atomic Absorption	<small>*Please select reporting limit on left.</small> -0.008% -80 ppm -mg/cm ² - RL is Variable	<input type="checkbox"/>	
	SW 846-6010D*	ICP-OES	<small>*Please select reporting limit on left.</small> -0.0004% -40 ppm -mg/cm ² - RL is Variable	<input type="checkbox"/>	
AIR	NIOSH 7082	Flame Atomic Absorption	4µg/filter	<input type="checkbox"/>	
	NIOSH 7303M	ICP-OES	1.0µg/filter	<input type="checkbox"/>	
	NIOSH 7303M	ICP-MS	0.05µg/filter	<input type="checkbox"/>	
	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	<input type="checkbox"/>	
WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM <small>*If no box is checked, non-ASTM Wipe is assumed</small>	SW 846-6010D*	ICP-OES	1.0µg/wipe	<input type="checkbox"/>	
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>	
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>	
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>	
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>	
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>	
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>	
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>	
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>	
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>	
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>	
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>	
	Unpreserved <input type="checkbox"/> PH<2 <input type="checkbox"/>	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
Drinking Water	Preserved with HNO3 <input type="checkbox"/> PH<2 <input type="checkbox"/>	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
	Unpreserved <input checked="" type="checkbox"/> PH<2 <input type="checkbox"/>	Preserved with HNO3 <input type="checkbox"/> PH<2 <input type="checkbox"/>	EPA 200.8	ICP-MS	0.001 mg/L (ppm)
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	<input type="checkbox"/>	
Other:				<input type="checkbox"/>	

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1-CHSS-POE	POE CC111 CUST. BREAK ROOM		10/10/24 540
3-CHSS-DW	SINK CC117 KITCHEN BREAK RM		541
5-CHSS-KC	SINK CC120 KITCHEN		542
6-CHSS-KC	SINK CC120 KITCHEN		543
7-CHSS-KC	SINK CC120 KITCHEN		544

Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by: <i>Cathy Ledden</i>	Date/Time: 10/10/24	Received by: <i>[Signature]</i>	Date/Time: 10/10/24 9:30a
Relinquished by:	Date/Time:	Received by:	Date/Time:



Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

AC 33463

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

~~Excell Results Form Needed~~

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
8-CHSS-KC	SINK LEFT CC120 KITCHEN		10/10/24 545
8a-CHSS-KC	SINK RIGHT CC120 KITCHEN		546
9-CHSS-IM	ICE MAKER CC120 KITCHEN		547
10-CHSS-FP	COFFEE MAKER LEFT CC120 KITCHEN		548
11-CHSS-FP	COFFEE MAKER RIGHT CC120 KITCHEN		549
13-CHSS-FP	FAUCET STEAM KETTLE CC120 KITCHEN		550
14-CHSS-FP	STEAM OVEN cc100 KITCHEN		551
15-CHSS-WC	FOUNTAIN CC100 S CAFE LEFT		552
17-CHSS-DW	HOT BEVERAGE MAKER CC100 S CAFE		553
19-CHSS-WC	BF HALL NEAR DD 107 A/B		554
20-CHSS-DW	SINK DD109 -(IN ROOM DD108)		555
21-CHSS-DW	SINK EE101		556
22-CHSS-DW	SINK EE101		557
23-CHSS-DW	SINK EE101		558
24-CHSS-EC	SINK EE103		559
25-CHSS-EC	SINK EE103		600
26-CHSS-EC	SINK EE103		601
27-CHSS-EC	SINK EE103		602
28-CHSS-EC	SINK EE103		603
29-CHSS-EC	SINK EE103		604
30-CHSS-DW	FOUNTAIN EE105		605
32-CHSS-WC	BF EE106 A-B HALL RIGHT		606
33-CHSS-WC	FOUNTAIN FF102		607
35-CHSS-WC	FOUNTAIN EE 208 A-B HALL RIGHT		608
36-CHSS-DW	SINK DD105 ADAPTIVE DP PHYS ED		609

Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by:	Date/Time:	Received by: <i>[Signature]</i>	Date/Time: 10/10/24 9:30am
Relinquished by:	Date/Time:	Received by:	Date/Time:

Controlled Document COC-25 Lead R19 08/19/2024

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

AC 33463

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
38-CHSS-WC	BF GG110 A-B		10/10/24 610
40-CHSS-WC	BF GG208 A-B RIGHT		611
41-CHSS-WC	FOUNTAIN DD213 A-B RIGHT		612
46-CHSS-DW	SINK CC 103 TEACHERS RM		613
47-CHSS-NS	SINK AA 143 S NURSE		614
48-CHSS-NS	SINK AA 143 S NURSE		615
49-CHSS-NS	SINK AA 143 S NURSE		616
50-CHSS-IM	ICE MAKER AA 143 S NURSE		617
52-CHSS-WC	BF AA142 A-B		618
53-CHSS-DW	SINK AA 139 MEDIA WORK RM		619
54-CHSS-FP	SINK MAIN OFFICE WORK RM AA102		620
55-CHSS-DW	SINK AA 129 TRAINER RM		621
56-CHSS-WC	ICE MAKER AA 129 TRAINER RM		622
58-CHSS-WC	BF HH 101 A-B		623
	Blank		

Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by:	Date/Time:	Received by: <i>[Signature]</i> WF	Date/Time: 10/10/24 930
Relinquished by:	Date/Time:	Received by:	Date/Time:

Controlled Document COC-25 Lead R19 08/19/2024

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.