



Lead in Drinking Water Report

North Plainfield Board of Education

33 Mountain Avenue North
Plainfield, NJ 07060

North Plainfield School District

November, 2024

Prepared for:


North Plainfield Board of Education

33 Mountain Avenue
North Plainfield, New Jersey 07060

Prepared by:

New Wave Engineering, LLC

**PO Box 4124
Wayne, New Jersey
07474**



New Wave Environmental Engineering Solutions

November 14, 2024

Mrs. Pamela Hinman-Graziano
Business Administrator
North Plainfield Board of
Education 33 Mountain Avenue
North Plainfield, NJ 07060

Re: Lead in Drinking Water Services per NJAC 6A:26

North Plainfield School District:

North Plainfield High School, Field House and Concession Stand, North Plainfield Middle School, Harrison School, East End School, Stony Brook School, Somerset School, West End School, Watchung Board Office

Dear Mrs. Hinman-Graziano,

New Wave is pleased to submit this Lead in Drinking Water Report for the North Plainfield Board of Education. This report outlines the methods and findings of the comprehensive lead testing services conducted in compliance with New Jersey state regulations (amendments to N.J.A.C. 6A:26 Educational Facilities) at the North Plainfield Board of Education locations , located at the addresses referenced above. The inspection was completed on October 11, 2024.

Best Regards,

Nadine Bello

Nadine Bello, MS, RPIH, CIEC, AST
New Wave Engineering, LLC

Table of Content

SUMMARY.....	Page 1
1.0 PROJECT BACKGROUND.....	Page 2
2.0 LEAD IN DRINKING WATER.....	Page 2
3.0 DRINKING WATER SAMPLING METHODOLOGY.....	Page 3
4.0 DRINKING WATER ANALYSIS RESULTS.....	Page 4
5.0 CONCLUSIONS & RECOMMENDATIONS.....	Page 8
6.0 DISCLAIMER.....	Page 8
7.0 CLOSING.....	Page 9

APPENDICES

APPENDIX A Chain of Custody and Lab Results

APPENDIX B Inspector's Certifications

Executive Summary of Lead in Drinking Water Services

November 2024

New Wave Engineering was retained to conduct a first-draw "lead in drinking water sampling" at the school buildings within the North Plainfield Board of Education in October 2024. Water samples were collected from designated drinking water outlets at the following schools:

All samples were collected in compliance with the regulatory guidelines specified in the amendments to N.J.A.C. 6A:26: Educational Facilities (July 2016) and its supporting documentation.

- **North Plainfield High School**
- **West End School**
- **North Plainfield Middle School**
- **Somerset School**
- **Field House/Concession Stand**
- **Harrison School**
- **Stony Brook School**
- **East End School**
- **Watchung Board Office**

First-draw sample results indicated that none of the water sources sampled at the above-mentioned schools exhibited lead levels above the regulatory action level of 15 ppb. All potable drinking water sources tested can continue regular usage. The next required testing of drinking water sources in New Jersey schools will need to be completed in three (3) years, unless any plumbing changes are made to the water system.

1.0 PROJECT BACKGROUND

New Wave Engineering was engaged by the North Plainfield Board of Education (the "Client") to conduct lead-in-drinking-water sampling to determine lead content in drinking water sources across the school facilities. Additionally, in compliance with state regulations, New Wave was contracted to update a Quality Assurance Project Plan (QAPP) and a Sampling Plan (SP), which included a Drinking Water Outlet Inventory, Filter Inventory, and Outlet Location Schematic, in collaboration with the District's Buildings and Grounds Director.

The purpose of lead-in-drinking-water sampling is to determine whether any sampled drinking water sources exceed the regulatory action level of 15 parts per billion (ppb) for lead. Sampled points included any water sources that may reasonably be used by students, staff, or faculty for drinking, cooking, or beverage preparation. These sources included, but were not limited to, water coolers/bubblers, kitchen faucets, Nurse's Office faucets, and Faculty/Staff lounge faucets.

For additional information on the guidance protocols and action levels followed, please refer to the following documents: The EPA's Revised Technical Guidance - "3Ts for Reducing Lead in Drinking Water in Schools" and NJDEP Division of Water Supply and Geoscience's Guidance Document - "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water."

2.0 LEAD IN DRINKING WATER

Lead is a toxic substance that poses significant health risks, especially to children, whose nervous systems are not yet fully developed and are therefore more susceptible to its harmful effects. Lead exposure can occur through various sources, including food, soil, deteriorating lead-based paint, and drinking water. In drinking water, lead can leach from plumbing materials such as pipes, solder, and brass fixtures. For this investigation, planning, preparation, methodology, sampling, and follow-up actions were conducted according to technical guidance from the State of New Jersey following the adoption of amendments to N.J.A.C. 6A:26: "Educational Facilities," which require lead sampling in school drinking water.

3.0 DRINKING WATER SAMPLING METHODOLOGY

New Wave collected drinking water samples from outlets throughout each school building. At each sampling location, a 250-milliliter (ml) wide-mouth high-density polyethylene (HDPE) sample collection bottle was filled from the designated water source. Samples were taken after the water in each building had remained unused for a minimum of 8 hours, but no more than 48 hours. The initial sample at each location is known as the first-draw sample, representing water from the end point of the source (e.g., bubbler, bottle filler, or tap).

A field blank, prepared with lead-free laboratory reagent water, was collected at each facility during the sampling event to rule out any contamination during sample collection and transport. All samples were documented using proper chain-of-custody forms and were couriered to Garden State Laboratory (NJ Lab ID #20044), a New Jersey-certified laboratory located in Hillside, NJ, for analysis following EPA Method 200.80.

During the initial sampling event on October 11, 2024, New Wave collected the following number of samples the North Plainfield Board of Education Buildings:

North Plainfield High School

- 1) 1 Field Blank Sample
- 2) 30 First Draw Samples

West End School

- 1) 1 Field Blank Sample
- 2) 14 First Draw Samples

Concession Stand/Athletic Field House

- 1) 1 Field Blank Sample
- 2) 4 First Draw Sample

Stony Brook

- 1) 1 Field Blank Sample
- 2) 8 First Draw Samples

Watchung Board Office

- 1) 1 Field Blank
- 2) 1 First Draw Sample

North Plainfield Middle School

- 1) 1 Field Blank Sample
- 2) 10 First Draw Samples

Somerset School

- 1) 1 Field Blank Sample
- 2) 10 First Draw Samples

Harrison School

- 1) 1 Field Blank Sample
- 2) 2 First Draw Sample

East End School

- 1) 1 Field Blank Sample
- 2) 8 First Draw Samples

The first-draw sampling results indicate that no location produced lead levels above 15 ppb. Since no location exceeded the action level, no further action is required.

For a complete inventory of drinking water outlets and sampling location diagrams for each facility, please refer to the Sampling Plan dated May 2017. Any updates to this documentation are available in the Field Log Book for each facility.

4.0 DRINKING WATER ANALYSIS RESULTS

The analytical “lead in drinking water results” for each first draw sample is listed in Tables below:

Table 1: Analytical Lead Results for First Draw Water Samples Collected from
North Plainfield High School- October 11, 2024

Sample I.D.	Type of Collection Point	Lead	Above Regulatory Action
NPHS-24-01	BF by 129	0.00122 mg/l	No
NPHS-24-02	BF by Café	<0.00100 mg/l	No
NPHS-24-03	Sink Center Kitchen	<0.00100 mg/l	No
NPHS-24-04	Sink by Washing Machine	<0.00100 mg/l	No
NPHS-24-05	Vegetable Sink	<0.00100 mg/l	No
NPHS-24-06	Teacher Room Sink	<0.00100 mg/l	No
NPHS-24-07	BF by Exit 2	<0.00100 mg/l	No
NPHS-24-08	Nurse's Sink	<0.00100 mg/l	No
NPHS-24-09	BF by Exit 27	<0.00100 mg/l	No
NPHS-24-10	BF by Girls Locker	<0.00100 mg/l	No
NPHS-24-11	BF in Girls Locker	<0.00100 mg/l	No
NPHS-24-12	BF by Boy's Locker	<0.00100 mg/l	No
NPHS-24-13	BF by Boy's Locker	<0.00100 mg/l	No
NPHS-24-15	WF by Room 157	<0.00100 mg/l	No
NPHS-24-16	WF by Room 152	<0.00100 mg/l	No
NPHS-24-18	BF by Gym	<0.00100 mg/l	No
NPHS-24-19	BF by 249	<0.00100 mg/l	No
NPHS-24-20	BF by 237	<0.00100 mg/l	No

NPHS-24-21	Sink by 226	<0.00100 mg/l	No
NPHS-24-22	BF by 229	<0.00100 mg/l	No
NPHS-24-23	HE Teacher's Sink	<0.00100 mg/l	No
NPHS-24-24	HE Sink RT Door	<0.00100 mg/l	No
NPHS-24-25	HE Sink RT Center	<0.00100 mg/l	No
NPHS-24-26	HE Sink RT Rear	<0.00100 mg/l	No
NPHS-24-27	HE Sink RT Center	<0.00100 mg/l	No
NPHS-24-28	HE Sink 1st Window	<0.00100 mg/l	No
NPHS-24-29	HE Sink Left Front	<0.00100 mg/l	No
NPHS-24-30	Kitchen Ice Machine	<0.00100 mg/l	No
NPHS-24-31	Trainer's Ice Machine	<0.00100 mg/l	No
NPHS-24-32	WF by Exit 4	<0.00100 mg/l	No
NPHS-24-33	Field Blank	<0.00100 mg/l	No

Table 2: Analytical Lead Results for First Draw Water Samples Collected from **West End School-** October 11, 2024

Sample I.D.	Type of Collection Point	Lead	Above Regulatory Action
NPWE-24-1	Kitchen Sink	<0.00100 mg/l	No
NPWE-24-2	BF in Cafe	<0.00100 mg/l	No
NPWE-24-3	Bubbler in 15	<0.00100 mg/l	No
NPWE-24-4	Bubbler in 16	<0.00100 mg/l	No
NPWE-24-5	Bubbler in 14	<0.00100 mg/l	No
NPWE-24-6	Bubbler by Gym	<0.00100 mg/l	No
NPWE-24-7	Nurse Sink	<0.00100 mg/l	No
NPWE-24-8	WF by Library	<0.00100 mg/l	No
NPWE-24-9	BF by Room 24	<0.00100 mg/l	No
NPWE-24-10	WF by Room 29	<0.00100 mg/l	No
NPWE-24-11	Teacher's Room Sink	<0.00100 mg/l	No
NPWE-24-12	WF by Room 36	<0.00100 mg/l	No
NPWE-24-13	WF in Trailer	<0.00100 mg/l	No
NPWE-24-14	BF in Trailer	<0.00100 mg/l	No
NPWE-24-15	Field Blank	<0.00100 mg/l	No

BF= Bottle Filler Station WF=Water Fountain Bub=Bubbler

**Table 3: Analytical Lead Results for First Draw Water Samples Collected
from North Plainfield Middle School- October 11, 2024**

Sample I.D.	Type of Collection Point	Lead	Above Regulatory Action
NPMS-24-1	BF by Room 222	<0.00100 mg/l	No
NPMS-24-2	BF by Room 201	<0.00100 mg/l	No
NPMS-24-3	Teacher's Room Sink	<0.00100 mg/l	No
NPMS-24-4	BF by 104	<0.00100 mg/l	No
NPMS-24-5	BF by Room 112	<0.00100 mg/l	No
NPMS-24-6	Nurse's Sink	<0.00100 mg/l	No
NPMS-24-7	BF by 118 Left	<0.00100 mg/l	No
NPMS-24-8	Bubbler by 118 Right	<0.00100 mg/l	No
NPMS-24-9	BF Right Trailer	<0.00100 mg/l	No
NPMS-24-10	WF Left Trailer	<0.00100 mg/l	No
NPMS-24-11	Field Blank	<0.00100 mg/l	No

BF= Bottle Filler Station WF=Water Fountain Bub=Bubbler

**Table 4: Analytical Lead Results for First Draw Water Samples Collected
from Somerset School- October 11, 2024**

Sample I.D.	Type of Collection Point	Lead	Above Regulatory Action
NPSS-24-1	Kitchen Sink	<0.00100 mg/l	No
NPSS-24-2	BF Main Entrance	<0.00100 mg/l	No
NPSS-24-3	Sink Main Office	<0.00100 mg/l	No
NPSS-24-4	Sink Conf 102	<0.00100 mg/l	No
NPSS-24-5	Sink Child Study 105	<0.00100 mg/l	No
NPSS-24-6	Sink Neutral	<0.00100 mg/l	No
NPSS-24-7	WF by 202 Left	<0.00100 mg/l	No
NPSS-24-8	Sink 202	<0.00282 mg/l	No
NPSS-24-9	BF 3rd Floor	<0.00100 mg/l	No
NPSS-24-10	Sink Family	<0.00100 mg/l	No
NPSS-24-11	Field Blank	<0.00100 mg/l	No

Table 5: Analytical Lead Results for First Draw Water Samples Collected from **Concession Stand** October 11, 2024

Sample I.D.	Type of Collection Point	Lead	Above Regulatory Action
NPCS-24-1	Field House BF	<0.00100 mg/l	No
NPCS-24-2	Field House Ice Machine	<0.00100 mg/l	No
NPCS-24-3	Field House WF Outside	<0.00100 mg/l	No
NPCS-24-4	Concession Sink	<0.00100 mg/l	No
NPCS-24-5	Field Blank	<0.00100 mg/l	No

BF= Bottle Filler Station WF=Water Fountain Bub=Bubbler

Table 6: Analytical Lead Results for First Draw Water Samples Collected from **Harrison School-** October 11, 2024

Sample I.D.	Type of Collection Point	Lead	Above Regulatory Action
NPHS-24-1	BF by Room 3	<0.00100 mg/l	No
NPHS-24-2	BF by Room 5	<0.00100 mg/l	No
NPHS-24-2	Field Blank	<0.00100 mg/l	No

BF= Bottle Filler Station WF=Water Fountain Bub=Bubbler

**Table 7: Analytical Lead Results for First Draw Water Samples Collected
from **Stony Brook School**- October 11, 2024**

Sample I.D.	Type of Collection Point	Lead	Above Regulatory Action
NPSB-24-1	Kitchen Sink	<0.00100 mg/l	No
NPSB-24-2	BF by Café	<0.00100 mg/l	No
NPSB-24-3	WF by Cafe	<0.00100 mg/l	No
NPSB-24-4	Faculty Room Sink	<0.00100 mg/l	No
NPSB-24-5	Nurse's Room Sink	<0.00100 mg/l	No
NPSB-24-6	WF by Principal's Office	<0.00100 mg/l	No
NPSB-24-7	BF by 21	<0.00100 mg/l	No
NPSB-24-8	WF Left 2nd Floor	<0.00100 mg/l	No
NPSB-24-9	Field Blank	<0.00100 mg/l	No

**Table 8: Analytical Lead Results for First Draw Water Samples Collected
from **East End School**- October 11, 2024**

Sample I.D.	Type of Collection Point	Lead	Above Regulatory Action
NPEE-24-1	Kitchen Sink	0.00223 mg/l	No
NPEE-24-2	BF Café	<0.00100 mg/l	No
NPEE-24-3	WF by Faculty	<0.00100 mg/l	No
NPEE-24-4	Teacher's Sink	<0.00100 mg/l	No
NPEE-24-5	Nurse's Sink	<0.00100 mg/l	No
NPEE-24-7	Copy Room Sink	<0.00100 mg/l	No
NPEE-24-9	Bubbler Room 5	<0.00227 mg/l	No
NPEE-24-10	WF by 24	<0.00100 mg/l	No
NPEE-24-13	Field Blank	<0.00100 mg/l	No

BF= Bottle Filler Station WF=Water Fountain Bub=Bubbler

**Table 9: Analytical Lead Results for First Draw Water Samples Collected from
Watchung Board Office- 33 Mountain Avenue -October 11, 2024**

Sample I.D.	Type of Collection Point	Lead	Above Regulatory Action
NPWBO-24-1	Front Hall	0.00100 mg/l	No
NPWBO-24-2	Field Blank	0.00100 mg/l	No

BF= Bottle Filler Station WF=Water Fountain Bub=Bubbler

All laboratory analytical results for first-draw samples were compared to the NJDEP's regulatory action level of 15.0 ppb for lead. Analysis of lead levels in the first-draw drinking water samples indicated that, at the time of sampling, no samples exceeded the action level of 15.0 ppb.

5.0 CONCLUSIONS & RECOMMENDATIONS

New Wave collected first-draw samples from drinking water sources throughout the North Plainfield Board of Education school facilities.

Results indicated **that no** samples exceeded the regulatory action level of 15.0 ppb.

- **Continue regular monitoring of lead levels in drinking water:** In compliance with New Jersey state regulations, testing for lead in drinking water is required every three (3) years.
- **Implement an aerator cleaning maintenance program:** Regular cleaning helps prevent debris buildup behind the aerator screen, which may contribute to elevated lead levels.
- **Log all maintenance activities and plumbing updates:** Enter filter and aerator maintenance, plumbing repairs/changes, and any other pertinent information into the Field Log Book for each school's water source location.
- **Use only cold water for food and beverage preparation:** Hot water is more likely to contribute to the corrosion of plumbing materials and may therefore contain higher levels of contaminants.

6.0 DISCLAIMER

This investigation focused exclusively on lead in drinking water; no other heavy metals or contaminants were sampled or analyzed. Note: Lead concentrations in water may vary as water moves through the system.

Each sample was a "grab sample," representing lead concentrations only at the specific time of collection, which may vary based on water usage within the facility. Interpretation of these results is only valid if the facility is serviced by a municipal water supplier or utility.

Our lead sampling event was conducted in response to recent amendments to N.J.A.C. 6A:26, Educational Facilities, dated July 13, 2016, which mandate testing for lead in drinking water in public and charter school districts.

The Lead Hazard Assessment has limitations concerning the identification of actual health and environmental issues. It is restricted to the items listed in the report, and all findings reflect the conditions at the time of the assessment.

New Wave Engineering, LLC warrants that the contents of this report provide an informed discussion of the assessment conducted at the subject property and are prepared exclusively for the client noted above. New Wave Engineering, LLC assumes no liability regarding the use of this information or any decisions made about the subject properties. It is at the discretion of the North Plainfield School District to use their best judgment, based on the results and information in this report, to determine any appropriate course of action.

7.0 CLOSING

The drinking water in the North Plainfield Public Schools is below the action level of 15 ppb, allowing for the normal use of all potable drinking water sources to continue as usual.

Thank you for choosing New Wave to assist with this project. Please do not hesitate to reach out if you have any questions regarding this report or any other environmental health and safety concerns.

APPENDIX A
CHAIN OF CUSTODY
AND
LAB RESULTS



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: North Plainfield School District - NW
33 Mountain Ave

North Plainfield, NJ 07060

Laboratory Director:

Attention: Jerry Bello

Client Number: NOR12

Report Date: 10/24/2024

Sample ID: North Plainfield Middle School
34 Wilson Ave/ NP-MS-24-01-
B/F BY 222

Lab Sample ID: 241011057-01

Site: Collection Date/Time: 10/11/2024 07:28

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 14:43	

Sample ID: North Plainfield Middle School
34 Wilson Ave/ NP-MS-24-02-
B/F BY 201

Lab Sample ID: 241011057-02

Site: Collection Date/Time: 10/11/2024 07:29

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 14:49	

Sample ID: North Plainfield Middle School
34 Wilson Ave/ NP-MS-24-03-
TEACHERS SINK

Lab Sample ID: 241011057-03

Site: Collection Date/Time: 10/11/2024 07:30

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 14:57	

Sample ID: North Plainfield Middle School
34 Wilson Ave/ NP-MS-24-04-
B/F BY 104

Lab Sample ID: 241011057-04

Site: Collection Date/Time: 10/11/2024 07:30

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 15:00	



Garden State Laboratories, Inc.

Sample ID: North Plainfield Middle School
34 Wilson Ave/ NP-MS-24-05-
B/F 112

Lab Sample ID: 241011057-05

Site: Collection Date/Time: 10/11/2024 07:31

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 15:03	

Sample ID: North Plainfield Middle School
34 Wilson Ave/ NP-MS-24-06-
NURSES SINK

Lab Sample ID: 241011057-06

Site: Collection Date/Time: 10/11/2024 07:32

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 15:06	

Sample ID: North Plainfield Middle School
34 Wilson Ave/ NP-MS-24-07-
B/F BY 118 LEFT

Lab Sample ID: 241011057-07

Site: Collection Date/Time: 10/11/2024 07:33

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/19/24 13:01	

Sample ID: North Plainfield Middle School
34 Wilson Ave/ NP-MS-24-08-
BUBBLER BY 118 RIGHT

Lab Sample ID: 241011057-08

Site: Collection Date/Time: 10/11/2024 07:34

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/19/24 13:04	

Sample ID: North Plainfield Middle School
34 Wilson Ave/ NP-MS-24-09-
B/F RIGHT TRAILER

Lab Sample ID: 241011057-09

Site: Collection Date/Time: 10/11/2024 07:35

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/19/24 13:12	



Garden State Laboratories, Inc.

Sample ID: North Plainfield Middle School
34 Wilson Ave/ NP-MS-24-10-
W/F LEFT TRAILER

Lab Sample ID: 241011057-10

Site: Collection Date/Time: 10/11/2024 07:36

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/19/24 13:15	

Sample ID: North Plainfield Middle School-
NP-MS-24-11-FIELD BLANK

Lab Sample ID: 241011057-11

Site: Collection Date/Time: 10/11/2024 07:40

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/19/24 13:18	

*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit,
MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

Page of

GSL CLIENT # **NOR12**

MICRO #

CHEM. # **241011057-01-05**

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Plainfield school District** Contact/Authorized by: **Cindy Henry**
 Mailing Address: **33 Mountain Avenue** Phone: **908-769-6058**
 City/State/Zip: **NORTH Plainfield, NJ 07060** Email: **JERRY@newpave.com**

SAMPLE INFORMATION

SAMPLE TYPE: **DW**
 SAMPLE LOCATION: **NORTH Plainfield Middle School 34 Wilson Ave**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION			
			Date	Time	AM	PM		No.	Type*	Size	Pres.*
X		NRMS-24-01 B/F by 222	10/11-24	7:28	X	57	LEAD FIRST DRAW 01	1	P	250ml	A
X		NRMS-24-02 B/F by 201	10-11-24	7:29	X	57	LEAD FIRST Draw 02	1	P	250ml	A
X		NRMS-24-03 Teacher's smk	10-11-24	7:30	X	57	LEAD-FIRST Draw 03	1	P	250ml	A
X		NRMS-24-04 B/F by 104	10-11-24	7:30	X	57	LEAD FIRST DRAW 04	1	P	250ml	A
X		NRMS-24-05 B/F by 112	10-11-24	7:31	X	57	LEAD-FIRST Draw 05	1	P	250ml	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

☐ SUBCONTRACTED WORK

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$
 Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello	Signature: <i>Jerry Bello</i>	Date/Time: 10-11-24
Client/Client's Representative (PRINT): JERRY Bello	Signature: <i>Jerry Bello</i>	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): SALON MACH	Signature: <i>S. Mach</i>	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

Page of

GSL CLIENT # NOR 12

MICRO #

CHEM. # 241011057-06-10

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District Contact/Authorized by: CINDY Henry

Mailing Address: 33 Mountain Ave Phone: 908-769-6058

City/State/Zip: NORTH Plainfield, NJ 07060 Email: Jerry@NewWave

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: NORTH Plainfield Middle School 34 Wilson Ave

Grab	Comp.	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NI-MS-24-06 Nurse's Sink	10-11-24	7:32	X	57	LEAD - FIRST DRAW	06	1	P	250mL	A
X		NP-MS-24-07 B/F by 118 left	10-11-24	7:33	X	57	LEAD - FIRST DRAW	07	1	P	250mL	A
X		NR-MS-24-08 Bubble by 118 right	10-11-24	7:34	X	57	LEAD - FIRST DRAW	08	1	P	250mL	A
X		NP-MS-24-09 B/F right Trench	10-11-24	7:35	X	57	LEAD - FIRST DRAW	09	1	P	250mL	A
X		NP-MS-24-10 B/F left Trench	10-11-24	7:36	X	57	LEAD - FIRST DRAW	10	1	P	250mL	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

☐ SUBCONTRACTED WORK

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello	Signature: J. Bello	Date/Time: 10-11-24
Client/Client's Representative (PRINT): JERRY Bello	Signature: J. Bello	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): Jordon March	Signature: J. March	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

Page of

GSL CLIENT # **NOR12**

MICRO #

CHEM. # **241011057-11**

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Plainfield School District** Contact/Authorized by: **Cindy Henry**
 Mailing Address: **33 Mountain Ave** Phone: **908-769-6058**
 City/State/Zip: **North Plainfield NJ 07068** Email: **Henry@northplainschools.com**

SAMPLE INFORMATION

SAMPLE TYPE: **DW**
 SAMPLE LOCATION: **NORTH Plainfield Middle School**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
☒		NPMS24-11 Field Blvd	10-11-24	7:40	☒		Lead First Draw 57-11		1	P	250ml	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

☐ SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Jelly Belts	Signature: [Signature]	Date/Time: 10-11-24
Client/Client's Representative (PRINT): Jelly Belts	Signature: [Signature]	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): Jalon Noel	Signature: [Signature]	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: North Plainfield School District - NW
33 Mountain Ave

North Plainfield, NJ 07060

Laboratory Director:

Attention: Jerry Bello

Client Number: NOR12

Report Date: 10/17/2024

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-01-BF
BY 129

Lab Sample ID: 241011056-01

Site: Collection Date/Time: 10/11/2024 06:49

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:30	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-02-BF
BY CAFE

Lab Sample ID: 241011056-02

Site: Collection Date/Time: 10/11/2024 06:49

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:33	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-03-SINK
CENTER KITCHEN

Lab Sample ID: 241011056-03

Site: Collection Date/Time: 10/11/2024 06:50

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:35	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-04-SINK
BY WASHING MACHINE

Lab Sample ID: 241011056-04

Site: Collection Date/Time: 10/11/2024 06:51

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:44	



Garden State Laboratories, Inc.

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-05-SINK
VEGETABLE

Lab Sample ID: 241011056-05

Site: Collection Date/Time: 10/11/2024 06:51

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:47	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-06-
TEACHER'S SINK

Lab Sample ID: 241011056-06

Site: Collection Date/Time: 10/11/2024 06:55

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:49	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-07-B/F
BY EXIT 2

Lab Sample ID: 241011056-07

Site: Collection Date/Time: 10/11/2024 06:59

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:52	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-08-
NURSE'S SINK

Lab Sample ID: 241011056-08

Site: Collection Date/Time: 10/11/2024 07:00

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:55	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-09-B/F
BY EXIT 27

Lab Sample ID: 241011056-09

Site: Collection Date/Time: 10/11/2024 07:01

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:58	



Garden State Laboratories, Inc.

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-10-W/F
BY GIRLS LOCKER

Lab Sample ID: 241011056-10

Site: Collection Date/Time: 10/11/2024 07:03

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:01	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-11-W/F
IN GIRLS LOCKER

Lab Sample ID: 241011056-11

Site: Collection Date/Time: 10/11/2024 07:06

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:03	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-12-B/F
BY BOYS LOCKER

Lab Sample ID: 241011056-12

Site: Collection Date/Time: 10/11/2024 07:07

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:06	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-13-W/F
BY BOYS LOCKER

Lab Sample ID: 241011056-13

Site: Collection Date/Time: 10/11/2024 07:07

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:09	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-15-W/F
IN ROOM 157

Lab Sample ID: 241011056-14

Site: Collection Date/Time: 10/11/2024 07:08

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:20	



Garden State Laboratories, Inc.

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-16- W/F
IN ROOM 152

Lab Sample ID: 241011056-15

Site: Collection Date/Time: 10/11/2024 07:09

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:23	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-18-BF
BY GYM

Lab Sample ID: 241011056-16

Site: Collection Date/Time: 10/11/2024 07:10

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:29	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-19-BF
BY 249

Lab Sample ID: 241011056-17

Site: Collection Date/Time: 10/11/2024 07:11

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:38	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-20-BF
BY 237

Lab Sample ID: 241011056-18

Site: Collection Date/Time: 10/11/2024 07:11

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:40	

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-21-SINK
BY 226

Lab Sample ID: 241011056-19

Site: Collection Date/Time: 10/11/2024 07:12

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:43	



Garden State Laboratories, Inc.

Sample ID: North Plainfield Highschool - 34
Wilson Ave/ NP-HS-24-22-B/F
BY 229

Lab Sample ID: 241011056-20

Site: Collection Date/Time: 10/11/2024 07:12

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:46	

Sample ID: North Plainfield Highschool/ NP-
HS-24-23-HE TEACHER'S
SINK

Lab Sample ID: 241011056-21

Site: Collection Date/Time: 10/11/2024 07:17

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:54	

Sample ID: North Plainfield Highschool/ NP-
HS-24-24-HE SINK RT DOOR

Lab Sample ID: 241011056-22

Site: Collection Date/Time: 10/11/2024 07:17

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 13:57	

Sample ID: North Plainfield Highschool/ NP-
HS-24-25-HE SINK RT
CENTER

Lab Sample ID: 241011056-23

Site: Collection Date/Time: 10/11/2024 07:18

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 14:00	

Sample ID: North Plainfield Highschool/ NP-
HS-24-26-HE SINK RT REAR

Lab Sample ID: 241011056-24

Site: Collection Date/Time: 10/11/2024 07:18

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 14:03	



Garden State Laboratories, Inc.

Sample ID: North Plainfield Highschool/ NP- HS-24-27-HE SINK CENTER Lab Sample ID: 241011056-25
Site: Collection Date/Time: 10/11/2024 07:19
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 14:06	

Sample ID: North Plainfield Highschool/ NP- HS-24-28-HE SINK 1ST WINDOW Lab Sample ID: 241011056-26
Site: Collection Date/Time: 10/11/2024 07:20
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 14:08	

Sample ID: North Plainfield Highschool/ NP- HS-24-29-HE SINK LEFT FRONT Lab Sample ID: 241011056-27
Site: Collection Date/Time: 10/11/2024 07:21
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 14:11	

Sample ID: North Plainfield Highschool/ NP- HS-24-30- KITCHEN ICE MACHINE Lab Sample ID: 241011056-28
Site: Collection Date/Time: 10/11/2024 07:25
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 14:14	

Sample ID: North Plainfield Highschool/ NP- HS-24-31- TRAINER'S ICE MACHINE Lab Sample ID: 241011056-29
Site: Collection Date/Time: 10/11/2024 07:27
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 14:17	



Garden State Laboratories, Inc.

Sample ID: North Plainfield Highschool/ NP- HS-24-32-W/F BY EXIT 4 Lab Sample ID: 241011056-30
Site: Collection Date/Time: 10/11/2024 07:28
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 14:20	

Sample ID: North Plainfield Highschool/ NP- HS-24-33- FIELD BLANK Lab Sample ID: 241011056-31
Site: Collection Date/Time: 10/11/2024 07:30
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 14:40	

*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit, MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

Page of

GSL CLIENT # NOR 12

MICRO #

CHEM. # 241011056-01-05

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP☐ PICK-UP AT DROP OFF LOCATION☐ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District Contact/Authorized by: Cindy Heavry
Mailing Address: 33 Mountain Avenue Phone: 908-769-6058
City/State/Zip: NORTH Plainfield, NJ 07060 Email: JERRY@newwave
environmental.com

SAMPLE INFORMATION

SAMPLE TYPE: DW
SAMPLE LOCATION: NORTH Plainfield High School - 34 Wilson Ave

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NR-HS-24-01-BF by 129	10/11/24	6:49	X		LEAD-FIRST Draw	56-01	1	P	250ml	A
X		NR-HS-24-02 BF by Cafe	10/11/24	6:49	X		LEAD-FIRST Draw	56-02	1	P	250ml	A
X		NP-HS-24-03 Sink Center Kitchen	10/11/24	6:50	X		LEAD-FIRST Draw	56-03	1	P	250ml	A
X		NP-HS-24-04 Sink by Washing Machine	10/11/24	6:51	X		LEAD-FIRST Draw	56-04	1	P	250ml	A
X		NP-HS-24-05 Sink-Vegetable	10/11/24	6:51	X		Lead-First Draw	56-05	1	P	250ml	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by:REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:☐ Standard Report + E2 PWS ID#:

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello	Signature: <i>J. Bello</i>	Date/Time: 10/11/24
Client/Client's Representative (PRINT): JERRY Bello	Signature: <i>J. Bello</i>	Date/Time: 10/11/24
1. Received/Relinquished by (PRINT): Jolton March	Signature: <i>J. March</i>	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

Page of

GSL CLIENT # **NOR 12**

MICRO #

CHEM. # **24101056-06-10**

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Plainfield School District** Authorized by: **Cindy Henry**
 Mailing Address: **33 Mountain Avenue** Phone: **908-769-6058**
 City/State/Zip: **NORTH Plainfield 07060** Email: **JERRY@newwave**
environmental.com

SAMPLE INFORMATION

SAMPLE TYPE: **DW**

SAMPLE LOCATION: **NORTH Plainfield High School - 34 Wilson Ave**

Grab/Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
		Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X	NP-HS-24-06 Teacher's Snk	10/11/24	6:55	X		LEAD FIRST DRAW 56-06		1	P	250ml	A
X	NP-HS-24-07 B/F by exit 2	10/11/24	6:59	X		LEAD FIRST DRAW 56-07		1	P	250ml	A
X	NP-HS-24-08 nurse's Snk	10/11/24	7:00	X		LEAD FIRST DRAW 56-08		1	P	250ml	A
X	NP-HS-24-09 B/F by exit 27	10/11/24	7:01	X		LEAD FIRST DRAW 56-09		1	P	250ml	A
X	NP-HS-24-10 W/F by girls locker	10/11/24	7:03	X		LEAD FIRST DRAW 56-10		1	P	250ml	A

⇒ *Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 ⇒ *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

☐ SUBCONTRACTED WORK

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

DATE/TIME:

☐ Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$
 Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): **JERRY Bello** Signature: **Jerry Bello** Date/Time: **10/11/24**
 Client/Client's Representative (PRINT): **JERRY Bello** Signature: **Jerry Bello** Date/Time: **10/11/24**
 1. Received/Relinquished by (PRINT): **Jaxon Mac** Signature: **Jaxon Mac** Date/Time: **10/11/24 16:11**
 2. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: _____

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

Page of

GSL CLIENT # **NOR12**

MICRO #

CHEM. # **241011056-11-15**

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Plainfield School District** Contact/Authorized by: **Cindy Henry**
 Mailing Address: **33 Mountain Ave** Phone: **908-769-6058**
 City/State/Zip: **NORTH Plainfield, NJ 07060** Email: **JERRY@new wave environmental.com**

SAMPLE INFORMATION

SAMPLE TYPE: **DW**

SAMPLE LOCATION: **NORTH Plainfield High School - 34 Wilson Ave**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NP-HS-24-10 W/F in Girls Locker	10/11/24	7:06	X				1	P	250mL	A
X		NP-HS-24-12 B/F by Boys Locker	10/11/24	7:07	X				1	P	250mL	A
X		NP-HS-24-13 W/F by Boys Locker	10/11/24	7:07	X				1	P	250mL	A
X		NP-HS-24-15 W/F in Room 157	10/11/24	7:08	X				1	P	250mL	A
X		NP-HS-24-16 W/F in Room 152	10/11/24	7:09	X				1	P	250mL	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello	Signature: <i>Jerry Bello</i>	Date/Time: 10/11/24
Client/Client's Representative (PRINT): JERRY Bello	Signature: <i>Jerry Bello</i>	Date/Time: 10/11/24
1. Received/Relinquished by (PRINT): Selon mach	Signature: <i>S. Mach</i>	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

Page of

GSL CLIENT # **NOR12**

MICRO #

CHEM. # **241011056-16-20**

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Plainfield School District** Contact/Authorized by: **Cindy Henry**
 Mailing Address: **33 Mountain AVE** Phone: **908-769-6058**
 City/State/Zip: **NORTH Plainfield New Jersey 07060** Email: **JERRY@newwave**
environmental.com

SAMPLE INFORMATION

SAMPLE TYPE: **DW**
 SAMPLE LOCATION: **NORTH Plainfield High School- 34 Wilson Ave**

Grab/Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
		Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X	NP-HS-24-18 BF by 6YM	10/11/24	7:10	X		LEAD FIRST DRAW	56-16	1	P	250mL	A
X	NP-HS-24-19 BF by 249	10/11/24	7:11	X		LEAD FIRST DRAW	56-17	1	P	250mL	A
X	NP-HS-24-20 BF by 237	10/11/24	7:11	X		LEAD FIRST DRAW	56-18	1	P	250mL	A
X	NP-HS-24-21 Sink by 226	10/11/24	7:12	X		LEAD FIRST DRAW	56-19	1	P	250mL	A
X	NP-HS-24-22 B/E by 229	10-11-24	7:12	X		LEAD FIRST DRAW	56-20	1	P	250mL	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

☐ SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$
 Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello	Signature: <i>J. Bello</i>	Date/Time: 10-11-24
Client/Client's Representative (PRINT): JERRY Bello	Signature: <i>J. Bello</i>	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): Salon maceh	Signature: <i>J. Maceh</i>	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

Page of

GSL CLIENT # **NOR12**

MICRO #

CHEM. # **241011056-21-25**

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Plainfield School District** Contact/Authorized by: **Cindy Henry**
Mailing Address: **33 Mountain Ave** Phone: **908-769-6058**
City/State/Zip: **North Plainfield NJ 07060** Email: **JERRY@newwar.com**

SAMPLE INFORMATION

SAMPLE TYPE: **DW**
SAMPLE LOCATION: **NORTH Plainfield High School**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NP-HS-24-23-HE Teacher Sink	10-11-24	7:17	X				1	P	250mL	A
X		NP-HS-24-24-HE Sink Rt Door	10-11-24	7:17	X				1	P	250mL	A
X		NP-HS-24-25-HE Sink Rt Center	10-11-24	7:18	X				1	P	250mL	A
X		NP-HS-24-26-HE Sink Rt Rear	10-11-24	7:18	X				1	P	250mL	A
X		NP-HS-24-27-HE Sink Center	10-11-24	7:19	X				1	P	250mL	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid

E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Jerry P. L...	Signature: <i>[Signature]</i>	Date/Time: 10-11-24
Client/Client's Representative (PRINT): Jerry P. L...	Signature: <i>[Signature]</i>	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): Jarlon Macch	Signature: <i>[Signature]</i>	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

Page of

GSL CLIENT # **NOR 12**

MICRO #

CHEM. # **241011056-26-30**

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Plainfield School District** Contact/Authorized by: **Cindy Henry**

Mailing Address: **33 Mountain Ave** Phone: **908-769-6850**

City/State/Zip: **NORTH Plainfield, NJ 07060** Email: **Jerry@newwaveenvironmental.com**

SAMPLE INFORMATION

SAMPLE TYPE: **DW**

SAMPLE LOCATION: **NORTH Plainfield HIGH School**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
☒		NRHS 24-28 - HE Sink left window	10-11-24	7:20	X		☒		1	P	250ml	A
☒		NRHS 24-29 - HE Sink left front	10-11-24	7:21	X		☒		1	P	250ml	A
☒		NRHS 24-30 Kitchen Ice Machine	10-11-24	7:25	X		☒		1	P	250ml	A
☒		NRHS 24-31 - Trainer's Ice Machine	10-11-24	7:27	X		☒		1	P	250ml	A
☒		NRHS 24-32 W/E by Exit 4	10-11-24	7:28	X		☒		1	P	250ml	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by: _____

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify: _____

☒ Standard Report + E2 PWS ID#: _____

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note: _____

☐ SUBCONTRACTED WORK

SEND TO: _____

DATE/TIME: _____

METHOD OF SHIPMENT: _____

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Rello	Signature: <i>Jerry Rello</i>	Date/Time: 10-11-24
Client/Client's Representative (PRINT): Jerry Rello	Signature: <i>Jerry Rello</i>	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): Sarah Macch	Signature: <i>S. Macch</i>	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20-2

Page of

GSL CLIENT # **NOR12**

MICRO #

CHEM. # **241011056-31**

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Plainfield School District**

Contact/Authorized by: **Cindy Henry**

Mailing Address: **33 Mountain Ave**

Phone: **908-769-6880**

City/State/Zip: **NORTH Plainfield NJ 07060**

Email: **JERRY@newjersey.com**

SAMPLE INFORMATION

SAMPLE TYPE: **DW**

SAMPLE LOCATION: **NORTH Plainfield High School**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
☒		NR HS 24-33 Field Blank	10-11-24	7:30		☒	LEAD FIRST DRAW	56-31	1	P	250mL	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

☐ SUBCONTRACTED WORK

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

DATE/TIME:

☐ Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): **JERRY BELLO**

Signature: **[Signature]**

Date/Time: **10-11-24**

Client/Client's Representative (PRINT): **JERRY BELLO**

Signature: **[Signature]**

Date/Time: **10-11-24**

1. Received/Relinquished by (PRINT): **SARAH MOORE**

Signature: **[Signature]**

Date/Time: **10/11/24 16:11**

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: North Plainfield School District - NW
33 Mountain Ave

North Plainfield, NJ 07060

Laboratory Director:

Report Date: 10/18/2024

Attention: Jerry Bello

Client Number: NOR12

Sample ID: Stony Brook School/NP-SB-24-01/Kitchen Sink

Lab Sample ID: 241011009-01

Site: Collection Date/Time: 10/11/2024 08:17

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:02	

Sample ID: Stony Brook School/NP-SB-24-02/B/F by Cafe

Lab Sample ID: 241011009-02

Site: Collection Date/Time: 10/11/2024 08:17

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:05	

Sample ID: Stony Brook School/NP-SB-24-03/W/F by Cafe

Lab Sample ID: 241011009-03

Site: Collection Date/Time: 10/11/2024 08:18

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:13	

Sample ID: Stony Brook School/NP-SB-24-04/Faculty Sink

Lab Sample ID: 241011009-04

Site: Collection Date/Time: 10/11/2024 08:19

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:16	



Garden State Laboratories, Inc.

Sample ID: Stony Brook School/NP-SB-24-05/Nurses Sink Lab Sample ID: 241011009-05
Site: Collection Date/Time: 10/11/2024 08:20
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:19	

Sample ID: Stony Brook School/NP-SB-24-06/W/F by Principal Office Lab Sample ID: 241011009-06
Site: Collection Date/Time: 10/11/2024 08:21
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:22	

Sample ID: Stony Brook School/NP-SB-24-07/B/F by 21 Lab Sample ID: 241011009-07
Site: Collection Date/Time: 10/11/2024 08:22
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:24	

Sample ID: Stony Brook School/NP-SB-24-08/W/F left 2nd fl Lab Sample ID: 241011009-08
Site: Collection Date/Time: 10/11/2024 08:23
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:27	

Sample ID: Stony Brook School/NP-SB-24-09/Field Blank Lab Sample ID: 241011009-09
Site: Collection Date/Time: 10/11/2024 08:24
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:30	

DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit,
MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

NOFOL

Page of

GSL CLIENT # NDR-12

MICRO #

CHEM. # 241011009-01-6

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District Contact/Authorized by: Cindy Henry

Mailing Address: 33 Mountain Avenue Phone: 908-769-6058

City/State/Zip: NORTH Plainfield, NJ 07060 Email: JERRY@newwave

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: STONY BROOK School

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NP-SB-24-01 Kitchen Sink	10-11-24	8:17	Y		LEAD FIRST DRAW	0901	1	P	250ml	A
X		NP-SB-24-02 B/K Ry Capt	10-11-24	8:17	Y		LEAD FIRST DRAW	0902	1	P	250ml	A
X		NP-SB-24-03 W/K Ry Capt	10-11-24	8:18	Y		LEAD FIRST DRAW	0903	1	P	250ml	A
X		NP-SB-24-04 Family Room	10-11-24	8:19	Y		LEAD FIRST DRAW	0904	1	P	250ml	A
X		NP-SB-24-05 Nurse's smn	10-11-24	8:20	Y		LEAD FIRST DRAW	0905	1	P	250ml	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

☐ SUBCONTRACTED WORK

TURNAROUND TIME: ☒ Standard ☐ Rush (or rush on request) Rush Due by: _____

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify: _____

☐ Standard Report + E2 PWS ID#: _____

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note: _____

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello	Signature: J. Bello	Date/Time: 10-11-24
Client/Client's Representative (PRINT): Jerry Bello	Signature: J. Bello	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): Salon Mael	Signature: J. Mael	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

NOEBC

Page of

GSL CLIENT # NOR12

MICRO #

CHEM. # 041011009-06-09

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District Contact/Authorized by: Andy Henry

Mailing Address: 33 Mountain Ave Phone: 908-769-6055

City/State/Zip: North Plainfield NJ 07066 Email: jerry@northplainschools.org

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: STONY BROOK School

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
✓		NP-SB-24-06 W/F by Primary	10/11/24	8:21	✓				1	P	250mL	✓
✓		NP-SB-24-07 b/E by 21	10/11/24	8:22	✓				1	P	250mL	✓
✓		NP-SB-24-08 W/F left 2nd fl	10-11-24	8:23	✓				1	P	250mL	✓
✓		NP-SB-24-09 Field Blank	10/11/24	8:24	✓				1	P	250mL	✓

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify:

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify:

☐ SUBCONTRACTED WORK

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED: Rush Due by:)

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT):	Signature: <i>[Signature]</i>	Date/Time: 10-11-24
Client/Client's Representative (PRINT):	Signature: <i>[Signature]</i>	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT):	Signature: <i>[Signature]</i>	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: North Plainfield School District - NW
33 Mountain Ave

North Plainfield, NJ 07060

Laboratory Director:

Attention: Jerry Bello

Client Number: NOR12

Report Date: 10/24/2024

Sample ID: Consession Stand/ Field House
/NP-CS-24-01-Field House B/F

Lab Sample ID: 241011029-01

Site: Collection Date/Time: 10/11/2024 07:45

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/19/24 13:21	

Sample ID: Consession Stand/ Field House
/NP-CS-24-02 Field House Ice Machine

Lab Sample ID: 241011029-02

Site: Collection Date/Time: 10/11/2024 07:46

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/19/24 13:29	

Sample ID: Consession Stand/ Field House
/NP-CS-24-03 Field House W/F outside

Lab Sample ID: 241011029-03

Site: Collection Date/Time: 10/11/2024 07:47

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/19/24 13:32	

Sample ID: Consession Stand/ Field House
/NP-CS-24-04 Consession Sink

Lab Sample ID: 241011029-04

Site: Collection Date/Time: 10/11/2024 07:50

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/19/24 13:35	



Garden State Laboratories, Inc.

Sample ID:

Consession Stand/ Field House
/NP-CS-24-05 Field Blank

Lab Sample ID:

241011029-05

Site:

Collection
Date/Time:

10/11/2024 07:51

Matrix:

Potable water

Sample Type:

Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/19/24 13:37	

*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit,
MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

NOPEC

Page of

GSL CLIENT # NOR 12

MICRO # 24101029-01-05

CHEM. # 241010029 MO 10/11/24

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District / Authorized by: CINDY HENRY

Mailing Address: 33 Mountain Ave Phone: 908-769-6058

City/State/Zip: NORTH Plainfield NJ 07060 Email: JERRY@newwam

SAMPLE INFORMATION

environmental.com

SAMPLE TYPE: DW

SAMPLE LOCATION: Concession STAND/Field House

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NP-CS-24-01-Field House B/F	10-11-24	7:45	X				1	P	250ml	A
X		NP-CS-24-02 Field House Ice machine	10-11-24	7:46	X				1	P	250ml	A
X		NP-CS-24-03 Field House W/F area	10-11-24	7:47	X				1	P	250ml	A
X		NP-CS-24-04 Concession Sink	10-11-24	7:50	X				1	P	250ml	A
X		NP-CS-24-05-Field House	10-11-24	7:51	X				1	P	250ml	A

⇒ Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
⇒ Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by: _____

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify: _____

☒ Standard Report + E2 PWS ID#: _____

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello	Signature: [Signature]	Date/Time: 10-11-24
Client/Client's Representative (PRINT): Jerry Bello	Signature: [Signature]	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): Sharon March	Signature: [Signature]	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: North Plainfield School District - NW
33 Mountain Ave

North Plainfield, NJ 07060

Laboratory Director:

Attention: Jerry Bello

Client Number: NOR12

Report Date: 10/18/2024

Sample ID: North Plainfield, West End
School/NP-WE-24-01 Kitchen
Sink

Lab Sample ID: 241011055-01

Site: Collection Date/Time: 10/11/2024 08:30

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:26	

Sample ID: North Plainfield, West End
School/NP-WE-24-02/ B/F in
Cafe

Lab Sample ID: 241011055-02

Site: Collection Date/Time: 10/11/2024 08:30

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:29	

Sample ID: North Plainfield, West End
School/NP-WE-24-03/Bubbler
Room 15

Lab Sample ID: 241011055-03

Site: Collection Date/Time: 10/11/2024 08:31

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:38	

Sample ID: North Plainfield, West End
School/NP-WE-24-04/Bubbler
Room 16

Lab Sample ID: 241011055-04

Site: Collection Date/Time: 10/11/2024 08:31

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:40	



Garden State Laboratories, Inc.

Sample ID: North Plainfield, West End School/NP-WE-24-05/Bubbler Room 14
Lab Sample ID: 241011055-05

Site: Collection Date/Time: 10/11/2024 08:32

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:43	

Sample ID: West End School/NP-WE-24-06/Bubbler BY GYM
Lab Sample ID: 241011055-06

Site: Collection Date/Time: 10/11/2024 08:33

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:46	

Sample ID: West End School/NP-WE-24-07/Nurses Sink
Lab Sample ID: 241011055-07

Site: Collection Date/Time: 10/11/2024 08:34

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:49	

Sample ID: West End School/NP-WE-24-08/W/F by Library
Lab Sample ID: 241011055-08

Site: Collection Date/Time: 10/11/2024 08:35

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:52	

Sample ID: West End School/NP-WE-24-09/B/F by Room 24
Lab Sample ID: 241011055-09

Site: Collection Date/Time: 10/11/2024 08:35

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:54	

Sample ID: West End School/NP-WE-24-10/W/F by Room 29
Lab Sample ID: 241011055-10

Site: Collection Date/Time: 10/11/2024 08:36

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:57	



Garden State Laboratories, Inc.

Sample ID: West End School/NP-WE-24-11/Teachers Sink Lab Sample ID: 241011055-11
Site: Collection Date/Time: 10/11/2024 08:37
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 17:00	

Sample ID: West End School/NP-WE-24-12/W/F By Room 36 Lab Sample ID: 241011055-12
Site: Collection Date/Time: 10/11/2024 08:38
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:13	

Sample ID: West End School/NP-WE-24-13/W/F in Trailer Lab Sample ID: 241011055-13
Site: Collection Date/Time: 10/11/2024 08:39
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:16	

Sample ID: West End School/NP-WE-24-14/B/F in Trailer Lab Sample ID: 241011055-14
Site: Collection Date/Time: 10/11/2024 08:40
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:24	

Sample ID: West End School/NP-WE-24-15/Field Blank Lab Sample ID: 241011055-15
Site: Collection Date/Time: 10/11/2024 08:41
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/16/24 12:27	

DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit,
MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

Page of

GSL CLIENT # NOR12

MICRO #

CHEM. # 241011055-0105

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP☐ PICK-UP AT DROP OFF LOCATION☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District Contact/Authorized by: CINDY HENRY
 Mailing Address: 33 Mountain Ave Phone: 908-769-6058
 City/State/Zip: NORTH Plainfield, NJ 07060 Email: JERRY@newwave
 environmental.com

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATION: NORTH Plainfield WESTEND School

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NP-WE-2401-Kitchen Sink	10/11/24	8:30	X		LEAD FIRST DRAW	5501	1	P	250mL	A
X		NP-WE-2402-B/F in Cafe	10-11-24	8:30	X		LEAD FIRST DRAW	5502	1	P	250mL	A
X		NP-WE-2403-bubbler Room 15	10-11-24	8:31	X		LEAD FIRST DRAW	5503	1	P	250mL	A
X		NP-WE-2404-bubbler Room 16	10-11-24	8:31	X		LEAD FIRST DRAW	5504	1	P	250mL	A
X		NP-WE-2405-bubbler Room 14	10-11-24	8:32	X		LEAD FIRST DRAW	5505	1	P	250mL	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

☐ SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello	Signature: <i>Jerry Bello</i>	Date/Time: 10/11/24
Client/Client's Representative (PRINT): JERRY Bello	Signature: <i>Jerry Bello</i>	Date/Time: 10/11/24
1. Received/Relinquished by (PRINT): Jason Macell	Signature: <i>J. Macell</i>	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

Page of

GSL CLIENT # **NOR12**

MICRO #

CHEM. # **241011055-06-10**

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Plainfield School District** Contact/Authorized by: **Cindy Henry**

Mailing Address: **33 Mountain Ave**

Phone: **908-769-6058**

City/State/Zip: **NORTH Plainfield NJ 07060**

Email: **Jerry@newwave**

environmental.com

SAMPLE INFORMATION

SAMPLE TYPE: **DW**

SAMPLE LOCATION: **WEST END School**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NR-WE-24-06-Bubbler by gym	10-11-24	8:33	X		LEAD FIRST DRAW	5506	1	P	250ml	A
X		NR-WE-24-07-Nurse's sink	10-11-24	8:34	X		LEAD FIRST Draw	5507	1	P	250ml	A
X		NR-WE-24-08 w/F by library	10-11-24	8:35	X		Lead First Draw	5508	1	P	250ml	A
X		NR-WE-24-09-B/F by Room 24	10-11-24	8:35	X		Lead First Draw	5509	1	P	250ml	A
X		NR-WE-24-10 w/F by Room 29	10-11-24	8:36	X		Lead First Draw	5510	1	P	250ml	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by: _____

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify: _____

☐ Standard Report + E2 PWS ID#: _____

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note: _____

☐ SUBCONTRACTED WORK

SEND TO: _____

DATE/TIME: _____

METHOD OF SHIPMENT: _____

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Jerry Bell	Signature: Jerry Bell	Date/Time: 10-11-24
Client/Client's Representative (PRINT): Jerry Bell	Signature: Jerry Bell	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): Sarah Moore	Signature: S. Moore	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

Page of

GSL CLIENT # NOR12

MICRO #

CHEM. # 241011055-11-15

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District

Contact/Authorized by: Cindy Henry

Mailing Address: 33 Mountain Ave

Phone: 908-769-6058

City/State/Zip: NORTH Plainfield NJ 07060

Email: JERRY@newwave

SAMPLE INFORMATION

environmental.com

SAMPLE TYPE: DW

SAMPLE LOCATION: WEST END School

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NP-WE-24-11 Teacher's Sink	10-11-24	8:37	X		LEAD First Draw	55-11	1	P	250 mL	A
X		NP-WE-24-12 w/FBY Room 36	10-11-24	8:38	X		LEAD First Draw	55-12	1	P	250 mL	A
X		NP-WE-24-13 w/F in Trailer	10-11-24	8:39	X		Lead First Draw	55-13	1	P	250 mL	A
X		NP-WE-24-14 BF in Trailer	10-11-24	8:40	X		Lead First Draw	55-14	1	P	250 mL	A
X		NP-WE-24-15 Field Blank	10-11-24	8:41	X		Lead First Draw	55-15	1	P	250 mL	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

☐ SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello	Signature: [Signature]	Date/Time: 10-11-24
Client/Client's Representative (PRINT): JERRY Bello	Signature: [Signature]	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): Jason March	Signature: [Signature]	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: North Plainfield School District - NW
33 Mountain Ave

North Plainfield, NJ 07060

Laboratory Director:

Report Date: 10/18/2024

Attention: Jerry Bello

Client Number: NOR12

Sample ID: Somerset School NP-SS-24-01
Kitchen Sink
Lab Sample ID: 241011054-01
Site:
Collection Date/Time: 10/11/2024 08:55
Matrix: Potable water
Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:33	

Sample ID: Somerset School NP-SS-24-02
B/F main Entrance
Lab Sample ID: 241011054-02
Site:
Collection Date/Time: 10/11/2024 08:56
Matrix: Potable water
Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:36	

Sample ID: Somerset School NP-SS-24-03
Sink main office
Lab Sample ID: 241011054-03
Site:
Collection Date/Time: 10/11/2024 08:57
Matrix: Potable water
Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:38	

Sample ID: Somerset School NP-SS-24-04
Sink Conf.102
Lab Sample ID: 241011054-04
Site:
Collection Date/Time: 10/11/2024 08:58
Matrix: Potable water
Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:50	



Garden State Laboratories, Inc.

Sample ID: Somerset School NP-SS-24-05 Sink Child Study 105
Site:
Matrix: Potable water
Lab Sample ID: 241011054-05
Collection Date/Time: 10/11/2024 09:00
Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 14:53	

Sample ID: Somerset School NP-SS-24-06 Sink neutral
Site:
Matrix: Potable water
Lab Sample ID: 241011054-06
Collection Date/Time: 10/11/2024 09:04
Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:04	

Sample ID: Somerset School NP-SS-24-07 W/F BY 202 left
Site:
Matrix: Potable water
Lab Sample ID: 241011054-07
Collection Date/Time: 10/11/2024 09:05
Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:07	

Sample ID: Somerset School NP-SS-24-08 Sink 202
Site:
Matrix: Potable water
Lab Sample ID: 241011054-08
Collection Date/Time: 10/11/2024 09:05
Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00282 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:10	

Sample ID: Somerset School NP-SS-24-09 B/F 3rd Floor
Site:
Matrix: Potable water
Lab Sample ID: 241011054-09
Collection Date/Time: 10/11/2024 09:07
Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:13	

Sample ID: Somerset School NP-SS-24-10 Sink Family
Site:
Matrix: Potable water
Lab Sample ID: 241011054-10
Collection Date/Time: 10/11/2024 09:08
Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:15	



Garden State Laboratories, Inc.

Sample ID: Somerset School NP-SS-24-11
Field Blank

Site:

Matrix: Potable water

Lab Sample ID: 241011054-11

Collection Date/Time: 10/11/2024 09:10

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:24	

Sample ID: EAST END SCHOOL NP-EE-24
-01- Kitchen Sink

Site:

Matrix: Potable water

Lab Sample ID: 241011054-12

Collection Date/Time: 10/11/2024 09:30

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:27	

Sample ID: EAST END SCHOOL NP-EE-24
-02 BF in Cafe

Site:

Matrix: Potable water

Lab Sample ID: 241011054-13

Collection Date/Time: 10/11/2024 09:30

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:29	

Sample ID: EAST END SCHOOL NP-EE-24
-03 W/F by Faculty

Site:

Matrix: Potable water

Lab Sample ID: 241011054-14

Collection Date/Time: 10/11/2024 09:31

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:32	

Sample ID: EAST END SCHOOL NP-EE-24
-04 Teachers Sink

Site:

Matrix: Potable water

Lab Sample ID: 241011054-15

Collection Date/Time: 10/11/2024 09:33

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:35	

Sample ID: EAST END SCHOOL NP-EE-24
-05 nurses Sink

Site:

Matrix: Potable water

Lab Sample ID: 241011054-16

Collection Date/Time: 10/11/2024 09:35

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:38	



Garden State Laboratories, Inc.

Sample ID: EAST END SCHOOL NP-EE-24 Lab Sample ID: 241011054-17
-07 Copy Rm Sink
Site: Collection Date/Time: 10/11/2024 09:37
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:41	

Sample ID: EAST END SCHOOL NP-EE-24 Lab Sample ID: 241011054-18
-09 Bubbler Rm5
Site: Collection Date/Time: 10/11/2024 09:40
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.0227 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:43	

Sample ID: EAST END SCHOOL NP-EE-24 Lab Sample ID: 241011054-19
-10 W/F by 24
Site: Collection Date/Time: 10/11/2024 09:41
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:46	

Sample ID: EAST END SCHOOL NP-EE-21 Lab Sample ID: 241011054-20
-13- Field Blank
Site: Collection Date/Time: 10/11/2024 09:42
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 15:49	

Sample ID: Harrison School NP-HS-24-01 Lab Sample ID: 241011054-21
B/F by Room 3
Site: Collection Date/Time: 10/11/2024 08:00
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:03	

Sample ID: Harrison School NP-HS-24-02 Lab Sample ID: 241011054-22
B/F by Room 5
Site: Collection Date/Time: 10/11/2024 08:01
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:06	



Garden State Laboratories, Inc.

Sample ID: Harrison School NP-HS-24-03 Lab Sample ID: 241011054-23
Field Blank
Site: Collection Date/Time: 10/11/2024 08:02
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:12	

Sample ID: Watchung Board Office-NP-WBO-24-01-FRONT HALL Lab Sample ID: 241011054-24
Site: Collection Date/Time: 10/11/2024 09:10
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:21	

Sample ID: Watchung Board Office-NP-WBO-24-02-Field Blank Lab Sample ID: 241011054-25
Site: Collection Date/Time: 10/11/2024 09:10
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/15/24 16:23	

*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit, MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

NOBEC

Page of

GSL CLIENT # NOR12

MICRO #

CHEM. # 241011054-01-05

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District Contact/Authorized by: CINDY HENRY
Mailing Address: 33 Mountain Avenue Phone: 908-769-6058
City/State/Zip: NORTH Plainfield, New Jersey 07060 Email: JERRY@newwave
environmental.com

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Somerset School

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NP-SS-24-01 Kitchen Smk	10-11-24	8:55	X		LEAD FIRST DRAW	054-01	1	P	250mL	A
X		NP-SS-24-02 B/A Main Entrance	10-11-24	8:56	X		LEAD FIRST DRAW	054-02	1	P	250mL	A
X		NP-SS-24-03 Smk main off	10-11-24	8:57	X		LEAD FIRST DRAW	054-03	1	P	250mL	A
X		NP-SS-24-04 Smk Conf. 102	10-11-24	8:58	X		LEAD FIRST DRAW	054-04	1	P	250mL	A
X		NP-SS-24-05 Smk Child Study	10-11-24	9:00	X		LEAD FIRST DRAW	054-05	1	P	205mL	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT):	JERRY Bello	Signature:	Jerry Bello	Date/Time:	10-11-24
Client/Client's Representative (PRINT):	JERRY Bello	Signature:	Jerry Bello	Date/Time:	10-11-24
1. Received/Relinquished by (PRINT):	JASON MCEL	Signature:	J. MCEL	Date/Time:	10/11/24 16:11
2. Received/Relinquished by (PRINT):		Signature:		Date/Time:	

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2
NO EXC

Page of

GSL CLIENT # NOR12

MICRO #

CHEM. # 24101054-06-10

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District Contact/Authorized by: CINDY Henry
Mailing Address: 33 Mountain Ave Phone: 908-769-6058
City/State/Zip: NORTH Plainfield NJ 07060 Email: JERRY@newwave
environmental.com

SAMPLE INFORMATION

SAMPLE TYPE: DW
SAMPLE LOCATION: Somerset School

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION			
			Date	Time	AM	PM		No.	Type*	Size	Pres.*
X		NP-SS-24-06 Sink nussel	10-11-24	9:04	X	05406	LEAD FIRST DRAW	1	P	250ml	A
X		NP SS 2407 W/Fky 202 left	10-11-24	9:05	X	05407					
X		NP SS 2408 Sink 202	10-11-24	9:05	X	05408					
X		NP SS 2409 B/F 3rd Floor	10-11-24	9:07	X	05409					
X		NP SS 2410 Sink Family	10-11-24	9:08	X	05410					

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

☐ SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello	Signature: J. Bello	Date/Time: 10-11-24
Client/Client's Representative (PRINT): JERRY Bello	Signature: J. Bello	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): JASON MOORE	Signature: J. Moore	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

NO Fee

Page of

GSL CLIENT # NOR 12

MICRO #

CHEM. # 24101054-11

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP☐ PICK-UP AT DROP OFF LOCATION☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District

Authorized by: Conely Henry

Mailing Address: 33 Mountain Ave

Phone: 908 669-8058

City/State/Zip: North Plainfield NJ 07068

Email: Emya Henry

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Somerset school

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NPSS-24-11 Field Lab	10-11-24	9:10	X		LEAD Fusion	054-11	1	P	28mm A	

⇒ *Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

⇒ *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

☐ SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): J. Rybicki

Signature: J. Rybicki

Date/Time: 10-11-24

Client/Client's Representative (PRINT): J. Rybicki

Signature: J. Rybicki

Date/Time: 10-11-24

1. Received/Relinquished by (PRINT): Jason Moeel

Signature: J. Moeel

Date/Time: 10/11/24 16:11

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2
NOROE

Page of

GSL CLIENT # NOR12

MICRO #

CHEM. # 24/10/1054-12-16

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District Contact/Authorized by: CINDY Henry

Mailing Address: 33 Mountain Avenue

Phone: 908-769-6058

City/State/Zip: NORTH Plainfield, NJ 07060

Email: JERRY@newwave
environmental.com

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: EAST END School

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NP-EE-24-01 - Kitchen Sink	10-11-24	9:30	X				1	P	250ml	A
X		NP-EE-24-02 BF in cafe	10-11-24	9:30	X				1	P	250ml	A
X		NP-EE-24-03 W/F by Family	10-11-24	9:31	X				1	P	250ml	A
X		NP-EE-24-04 Teacher's Sink	10-11-24	9:33	X				1	P	250ml	A
X		NP-EE-24-05 Nurse's Sink	10-11-24	9:35	X				1	P	250ml	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by: _____

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify: _____

☐ Standard Report + E2 PWS ID#: _____

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: _____ ☐ Check # _____ ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello

Signature: [Signature]

Date/Time: 10-11-24

Client/Client's Representative (PRINT): JERRY Bello

Signature: [Signature]

Date/Time: 10-11-24

1. Received/Relinquished by (PRINT): JASON MACH

Signature: [Signature]

Date/Time: 10/11/24 16:11

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

NOR 02

Page of

GSL CLIENT # NOR 12

MICRO #

CHEM. # 241011054-17-20

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District Contact/Authorized by: CINOY Henry

Mailing Address: 33 Mountain Ave

Phone: 908-769-6058

City/State/Zip: NORTH Plainfield, NJ 07060

Email: JERRY@newjune

SAMPLE INFORMATION

environmental.com

SAMPLE TYPE: DW

SAMPLE LOCATION: EAST END SCHOOL

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*
X		NPEE-24-07 - Copy Rm Smk	10-11-24	9:37	X		LEAD FIRST DRAW	054-17	1	P	250mL	A
X		NPEE-24-09 Bubble Rm 5	10-11-24	9:40	X		Lead First Draw	054-18	1	P	250mL	A
X		NPEE-24-10 W/F by 24	10-11-24	9:41	X		Lead First Draw	054-19	1	P	250mL	A
X		NPEE-24-13 Field Blank	10-11-24	9:42	X		Lead First Draw	054-20	1	P	250mL	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

☐ SUBCONTRACTED WORK

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

DATE/TIME:

☐ Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello

Signature: J. Bello

Date/Time: 10-11-24

Client/Client's Representative (PRINT): JERRY Bello

Signature: J. Bello

Date/Time: 10-11-24

1. Received/Relinquished by (PRINT): Jolon March

Signature: J. March

Date/Time: 10/11/24 16:11

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

NO EOC

Page of

GSL CLIENT # **NJ0R-42**

MICRO #

CHEM. # **241011054-21,22,23**

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Plainfield School District** Contact/Authorized by: **Cindy Henry**
Mailing Address: **33 Mountain Avenue** Phone: **908-769-6058**
City/State/Zip: **North Plainfield NJ 07060** Email: **JERRY Bello**

SAMPLE INFORMATION

SAMPLE TYPE: **DW**
SAMPLE LOCATION: **Harrison School**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION			
			Date	Time	AM	PM		No.	Type*	Size	Pres.*
X		NPMS-24-01 B/F by Room 3	10-11-24	8:00	X		Lead First Draw 054-21	1	P	250mL	A
X		NPMS-24-02 B/F by Room 5	10-11-24	8:01	X		Lead First Draw 054-22	1	P	250mL	A
X		NPMS-24-03 Field Blank	10-11-24	8:02	X		Lead First Draw 054-23	1	P	250mL	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by: _____

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify: _____

☐ Standard Report + E2 PWS ID#: _____

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello	Signature: <i>[Signature]</i>	Date/Time: 10-11-24
Client/Client's Representative (PRINT): JERRY Bello	Signature: <i>[Signature]</i>	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): Jaelon March	Signature: <i>[Signature]</i>	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

10/11/24 16:11 20.2

NOFEE

Page of

GSL CLIENT # NBR 12

MICRO #

CHEM. # 24101054-2425

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: NORTH Plainfield School District Contact/Authorized by: CINDY Henry

Mailing Address: 33 Main Avenue

Phone: 908-769-6058

City/State/Zip: NORTH Plainfield, NJ 07060

Email: JERRY Bello

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Watchung Board Office

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION			
			Date	Time	AM	PM		No.	Type*	Size	Pres.*
X		NP-WBO-2401-FRONT HALL	10-11-24	9:10	X		LEAD FIRST DRAW 054-24	1	P	250mL	A
X		NP-WBO-2402-Field Blank	10-11-24	9:10	X		LEAD FIRST DRAW 054-25	1	P	250mL	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

☐ SUBCONTRACTED WORK

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by: _____

SEND TO:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify: _____

DATE/TIME:

☐ Standard Report + E2 PWS ID#: _____

METHOD OF SHIPMENT:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello	Signature: [Signature]	Date/Time: 10-11-24
Client/Client's Representative (PRINT): JERRY Bello	Signature: [Signature]	Date/Time: 10-11-24
1. Received/Relinquished by (PRINT): JASON MARCH	Signature: [Signature]	Date/Time: 10/11/24 16:11
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

APPENDIX B
INSPECTOR'S
CERTIFICATIONS

New Jersey Department of Health

Having met the requirements of N.J.A.C. 8:50

New Wave Engineering, LLC

85 Redwood Avenue

WAYNE, NJ 07470

License Number: 1244

*is licensed as an Indoor Environmental Consultant to conduct Indoor
Environmental Health Assessments of Child Care Centers and
Educational Facilities in New Jersey.*

9/4/2024

Issue Date

9/4/2026

Expiration Date



Christina Tan, MD, MPH, Assistant Commissioner
Division of Epidemiology, Environmental and Occupational Health

This License is non-transferable and only valid for the licensee as indicated above.



American Council for Accredited Certification

hereby certifies that

Nadine Bello

has met all the specific standards and qualifications of the re-certification process,
including continued professional development, and is hereby re-certified as a



**Council-certified
Indoor Environmental Consultant**

This certificate expires on June 30, 2025

Charles F. Wiles, Executive Director

1506022

Certificate Number

This certificate remains the property of the American Council for Accredited Certification.