

ALOHA HUBER PARK_LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
Room 108 - Staff/Office Faucet - Right	22433200-001SF	10/25/24	0.321
Room 108 - Staff/Office Faucet - Left	22433200-002SF	10/25/24	ND
Room 105 - Staff/Office Faucet	22433200-003SF	10/25/24	1.34
Health room - Nurse's Sink - Left	22433200-004NS	10/25/24	0.685
Health Room - Nurse's Sink - Right	22433200-005NS	10/25/24	2.41
Music - Classroom Faucet - Left	22433200-006CF	10/25/24	0.362
Music - Classroom Faucet - Right	22433200-007CF	10/25/24	ND
Music/Gym/Band Hall Left - Drinking	22433200-008DW	10/25/24	0.212
Music/Gym/Band Hall Right - Drinking	22433200-009DW	10/25/24	ND
Band - Classroom Faucet	22433200-010CF	10/25/24	0.568
Band - Drinking Fountain	22433200-011DW	10/25/24	ND
Lobby Hall Left - Drinking Fountain	22433200-012DW	10/25/24	0.297
Lobby Hall Right - Drinking Fountain	22433200-013DW	10/25/24	0.324
Kitchen - Kitchen/Food Prep - East side of	22433200-014KF	10/25/24	1.14
Kitchen - Kitchen/Food Prep - North	22433200-015KF	10/25/24	0.487
Kitchen - Kitchen/Food Prep - West side of	22433200-016KF	10/25/24	3.31
Room 116 - Classroom Faucet	22433200-017CF	10/25/24	0.447
Room 116 - Drinking Fountain	22433200-018DW	10/25/24	ND
Room 117 - Classroom Faucet	22433200-019CF	10/25/24	0.391
Room 117 - Drinking Fountain	22433200-020DW	10/25/24	0.241
Room 118 - Classroom Faucet	22433200-021CF	10/25/24	0.442
Room 118 - Drinking Fountain	22433200-022DW	10/25/24	ND
Room 119 - Classroom Faucet	22433200-023CF	10/25/24	0.499
Room 119 - Drinking Fountain	22433200-024DW	10/25/24	ND
North 100 Hall Left - Drinking Fountain	22433200-025DW	10/25/24	0.432
North 100 Hall Right - Drinking Fountain	22433200-026DW	10/25/24	0.450
Room 121 - Classroom Faucet	22433200-027CF	10/25/24	0.955
Room 121 - Drinking Fountain	22433200-028DW	10/25/24	ND
Room 122 - Classroom Faucet	22433200-029CF	10/25/24	0.772
Room 122 - Drinking Fountain	22433200-030DW	10/25/24	ND
Room 123 - Classroom Faucet	22433200-031CF	10/25/24	0.607
Room 123 - Drinking Fountain	22433200-032DW	10/25/24	ND
Room 124 - Classroom Faucet	22433200-033CF	10/25/24	0.491
Room 124 - Drinking Fountain	22433200-034DW	10/25/24	0.272
Room 126 - Classroom Faucet	22433200-035CF	10/25/24	1.17
Room 126 - Drinking Fountain	22433200-036DW	10/25/24	ND
Room 127 - Classroom Faucet	22433200-037CF	10/25/24	0.359
Room 127 - Drinking Fountain	22433200-038DW	10/25/24	ND
Room 128 - Classroom Faucet	22433200-039CF	10/25/24	0.795
Room 128 - Drinking Fountain	22433200-040DW	10/25/24	ND
Room 129 - Classroom Faucet	22433200-041CF	10/25/24	0.670
Room 129 - Drinking Fountain	22433200-042DW	10/25/24	ND
Room 132 - Classroom Faucet	22433200-043CF	10/25/24	0.663
Room 132 - Drinking Fountain	22433200-044DW	10/25/24	0.422
Room 133 - Classroom Faucet	22433200-045CF	10/25/24	0.473
Room 133 - Drinking Fountain	22433200-046DW	10/25/24	ND

Room 134 - Classroom Faucet	22433200-047CF	10/25/24	0.750
Room 134 - Drinking Fountain	22433200-048DW	10/25/24	ND
Room 135 - Classroom Faucet	22433200-049CF	10/25/24	1.16
Room 135 - Drinking Fountain	22433200-050DW	10/25/24	ND
South 100 Hall Left - Drinking Fountain	22433200-051DW	10/25/24	0.516
South 100 Hall Right - Drinking Fountain	22433200-052DW	10/25/24	0.420
Room 137 - Classroom Faucet	22433200-053CF	10/25/24	0.448
Room 137 - Drinking Fountain	22433200-054DW	10/25/24	ND
Room 138 - Classroom Faucet	22433200-055CF	10/25/24	0.663
Room 138 - Drinking Fountain	22433200-056DW	10/25/24	0.231
Room 139 - Classroom Faucet	22433200-057CF	10/25/24	0.618
Room 139 - Drinking Fountain	22433200-058DW	10/25/24	ND
Room 140 - Classroom Faucet	22433200-059CF	10/25/24	0.439
Room 140 - Drinking Fountain	22433200-060DW	10/25/24	ND
Library Work Room - Staff/Office Faucet	22433200-061SF	10/25/24	3.85
North 200 Hall Left - Drinking Fountain	22433200-062DW	10/25/24	ND
North 200 Hall Right - Drinking Fountain	22433200-063DW	10/25/24	0.207
Room 204 - Classroom Faucet	22433200-064CF	10/25/24	1.28
Room 204 - Drinking Fountain	22433200-065DW	10/25/24	ND
Room 205 - Classroom Faucet	22433200-066CF	10/25/24	ND
Room 205 - Drinking Fountain	22433200-067DW	10/25/24	ND
Room 206 - Classroom Faucet	22433200-068CF	10/25/24	0.838
Room 206 - Drinking Fountain	22433200-069DW	10/25/24	ND
Room 207 - Classroom Faucet	22433200-070CF	10/25/24	0.660
Room 207 - Drinking Fountain	22433200-071DW	10/25/24	ND
Center 200 Hall - Drinking Fountain	22433200-072DW	10/25/24	0.203
Room 209 - Drinking Fountain	22433200-073DW	10/25/24	0.463
Room 209 - Classroom Faucet	22433200-074CF	10/25/24	0.644
Room 210 - Drinking Fountain	22433200-075DW	10/25/24	ND
Room 210 - Classroom Faucet	22433200-076CF	10/25/24	ND
Room 211 Left - Drinking Fountain	22433200-077DW	10/25/24	0.482
Room 211 Right - Classroom Faucet	22433200-078CF	10/25/24	0.801
Room 212 - Drinking Fountain	22433200-079DW	10/25/24	ND
Room 212 - Classroom Faucet	22433200-080CF	10/25/24	0.557
Room 214 - Drinking Fountain	22433200-081DW	10/25/24	ND
Room 214 - Classroom Faucet	22433200-082CF	10/25/24	0.432
Room 215 - Drinking Fountain	22433200-083DW	10/25/24	ND
Room 215 - Classroom Faucet	22433200-084CF	10/25/24	0.452
Room 216 - Drinking Fountain	22433200-085DW	10/25/24	1.48
Room 216 - Classroom Faucet	22433200-086CF	10/25/24	0.447
Room 217 - Drinking Fountain	22433200-087DW	10/25/24	ND
Room 217 - Classroom Faucet	22433200-088CF	10/25/24	0.412
Room 220 - Drinking Fountain Left	22433200-089DW	10/25/24	ND
Room 220 - Classroom Faucet	22433200-090CF	10/25/24	0.595
Room 220 - Drinking Fountain Right	22433200-091DW	10/25/24	ND
Room 221 South Wall Left Faucet -	22433200-092CF	10/25/24	3.57
Room 222 - Classroom Faucet	22433200-093CF	10/25/24	0.664
Room 222 - Drinking Fountain	22433200-094DW	10/25/24	0.320
Room 223 - Classroom Faucet	22433200-095CF	10/25/24	0.564

Room 223 - Drinking Fountain	22433200-096DW	10/25/24	ND
South 200 Hall - Drinking Fountain Left	22433200-097DW	10/25/24	0.360
South 200 Hall - Drinking Fountain Right	22433200-098DW	10/25/24	0.751
Room 224 - Classroom Faucet	22433200-099CF	10/25/24	0.574
Room 224 - Drinking Fountain	22433200-100DW	10/25/24	ND
Room 225 - Classroom Faucet	22433200-101CF	10/25/24	0.509
Room 225 - Drinking Fountain	22433200-102DW	10/25/24	ND
Room 226 - Classroom Faucet	22433200-103CF	10/25/24	0.610
Room 226 - Drinking Fountain	22433200-104DW	10/25/24	ND
Room 227 - Classroom Faucet	22433200-105CF	10/25/24	0.541
Room 227 - Drinking Fountain	22433200-106DW	10/25/24	ND