3930-FM-BSDW0196b 7/2020
Form

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER

PUBLIC NOTICE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
FAILURE TO MONITOR

ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.

Monitoring Requirements Not Met for Southern Fulton Elementary School

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2024 we failed to monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant we did not properly test for during the last year, the required sampling frequency, how many samples we took, when samples should have been taken, and the date on which corrective action samples were taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
PFAS	Quarterly	0	2nd Quarter	3rd Quarter

What happened? What was done? When will it be resolved?

PFAS samples were collected by Negley's Water and sent to the subcontracted lab to be analyzed, when in transport the containers were damaged and the samples were invalidated. By the time we were notified to re-collect the sample the 2nd quarter had ended. The samples were recollected during the 3rd quarter and show there is no PFAS detected in the water.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Negley's Water at 717-597-8650.

Certified by:

Signature: Tara L. Ott Date: 11/21/2024

Print Name and Title: Tara Ott - Negley's Water Commercial Compliance Manager

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: *Posted on website and notified via email*

PWS ID#: 4290818 Date distributed: _____