

Facility or Building Name	Burroughs Elementary
Did the facility test using the MDH testing program (WIIN)?	No
Facility Type (School or Child Care)	School
School ID Number or Child Care License Number	0001-03-110
Facility or Building Address	1601 West 50th Street, Minneapolis, MN 55419
Mailing Address	1225 North 7th Street Minneapolis, MN 55411
Contact Person	Lee Setter
Title	Manager, EH&S
Phone	612-668-0308
Email	Lee.Setter@mpls.k12.mn.us

SUMMARY	ANSWER
Total number of samples	49
Total number of fixtures sampled	49
Total number of results above 5 ppb	0
Total number of remediation actions	0
Next Scheduled Sampling Date (Month/Year)	10/2029

Unique Sample Site	Fixture Type	Location Description	Fixture Status	Sample Collection	Laboratory	Date/Time	Date/Time	Numeric Result	Unit of Measure	Name of Laboratory Used For	Remediation Action	Other	Was Remediation Successful	Additional Notes or Comments
0001-03-110-01	Filtered Bottle Filler	Lunch RM FBF	Active - Consumption	Initial - First Draw	24-13107	10/25/2024 3:30	11/14/2024 15:06	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-02	sink	Kitchen Dish Wash Sink	Active - Consumption	Initial - First Draw	24-13108	10/25/2024 3:31	11/14/2024 15:12	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-03	sink	Kitchen Prep Sink	Active - Consumption	Initial - First Draw	24-13109	10/25/2024 3:32	11/14/2024 15:18	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-04	Drinking Fountain	Gym DF North	Active - Consumption	Initial - First Draw	24-13110	10/25/2024 3:33	11/14/2024 15:24	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-05	Drinking Fountain	Gym DF South	Active - Consumption	Initial - First Draw	24-13111	10/25/2024 3:34	11/14/2024 15:30	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-06	Sink	RM 134 Health Main Sink	Active - Consumption	Initial - First Draw	24-13112	10/25/2024 3:35	11/14/2024 15:36	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-07	Sink	RM 134 Health RR Sink	Active - Consumption	Initial - First Draw	24-13113	10/25/2024 3:36	11/14/2024 15:42	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-08	Drinking Fountain	DF RM 105	Active - Consumption	Initial - First Draw	24-13114	10/25/2024 3:37	11/15/2024 10:50	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-09	Drinking Fountain	DF RM 107	Active - Consumption	Initial - First Draw	24-13115	10/25/2024 3:38	11/15/2024 10:56	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-10	Sink	RM 138 Sink	Active - Consumption	Initial - First Draw	24-13116	10/25/2024 3:39	11/15/2024 11:02	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-11	Drinking Fountain	DF RM 142	Active - Consumption	Initial - First Draw	24-13117	10/25/2024 3:40	11/15/2024 11:08	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-12	Drinking Fountain	DF RM 145	Active - Consumption	Initial - First Draw	24-13118	10/25/2024 3:42	11/15/2024 11:26	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-13	Drinking Fountain	DF RM 146	Active - Consumption	Initial - First Draw	24-13119	10/25/2024 3:43	11/15/2024 11:45	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-14	Drinking Fountain	DF RM 147	Active - Consumption	Initial - First Draw	24-13120	10/25/2024 3:44	11/15/2024 11:51	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-15	Drinking Fountain	DF RM 152	Active - Consumption	Initial - First Draw	24-13121	10/25/2024 3:45	11/15/2024 11:57	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-16	Drinking Fountain	DF RM 203	Active - Consumption	Initial - First Draw	24-13122	10/25/2024 3:46	11/15/2024 12:03	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-17	Drinking Fountain	DF RM 205	Active - Consumption	Initial - First Draw	24-13123	10/25/2024 3:47	11/15/2024 12:09	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-18	Drinking Fountain	DF RM 206	Active - Consumption	Initial - First Draw	24-13124	10/25/2024 3:48	11/15/2024 12:15	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-19	Filtered Bottle Filler	Hallway RM 224 FBF	Active - Consumption	Initial - First Draw	24-13125	10/25/2024 3:49	11/15/2024 12:21	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-20	Drinking Fountain	DF RM 231	Active - Consumption	Initial - First Draw	24-13126	10/25/2024 3:51	11/15/2024 12:27	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-21	Drinking Fountain	DF RM 232	Active - Consumption	Initial - First Draw	24-13127	10/25/2024 3:52	11/15/2024 12:33	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-22	Drinking Fountain	DF RM 233	Active - Consumption	Initial - First Draw	24-13128	10/25/2024 3:53	11/15/2024 12:51	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-23	Drinking Fountain	DF RM 235	Active - Consumption	Initial - First Draw	24-13129	10/25/2024 3:54	11/15/2024 13:09	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-24	Drinking Fountain	DF RM 236	Active - Consumption	Initial - First Draw	24-13130	10/25/2024 3:55	11/15/2024 13:15	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-25	Drinking Fountain	DF RM 238	Active - Consumption	Initial - First Draw	24-13131	10/25/2024 3:56	11/15/2024 13:21	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-26	Drinking Fountain	DF RM 240	Active - Consumption	Initial - First Draw	24-13132	10/25/2024 3:57	11/15/2024 13:27	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-27	Drinking Fountain	DF RM 301	Active - Consumption	Initial - First Draw	24-13133	10/25/2024 3:58	11/15/2024 13:33	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-28	Drinking Fountain	DF RM 302	Active - Consumption	Initial - First Draw	24-13134	10/25/2024 3:59	11/15/2024 13:39	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-29	Drinking Fountain	Hallway RM 311 Right DF	Active - Consumption	Initial - First Draw	24-13135	10/25/2024 4:02	11/15/2024 13:45	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-30	Drinking Fountain	Hallway RM 311 Left DF	Active - Consumption	Initial - First Draw	24-13136	10/25/2024 4:04	11/15/2024 13:51	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-31	Drinking Fountain	DF RM 304	Active - Consumption	Initial - First Draw	24-13137	10/25/2024 4:05	11/15/2024 13:57	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-32	Drinking Fountain	DF RM 312	Active - Consumption	Initial - First Draw	24-13138	10/25/2024 4:06	11/18/2024 13:07	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-33	Drinking Fountain	DF RM 315	Active - Consumption	Initial - First Draw	24-13139	10/25/2024 4:07	11/18/2024 13:13	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-34	Drinking Fountain	DF RM 320	Active - Consumption	Initial - First Draw	24-13140	10/25/2024 4:08	11/18/2024 13:31	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-35	Drinking Fountain	DF RM 321	Active - Consumption	Initial - First Draw	24-13141	10/25/2024 4:09	11/18/2024 13:49	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-36	Drinking Fountain	DF RM 322	Active - Consumption	Initial - First Draw	24-13142	10/25/2024 4:11	11/18/2024 13:55	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-37	Drinking Fountain	Hallway RM 326 Right DF	Active - Consumption	Initial - First Draw	24-13143	10/25/2024 4:12	11/18/2024 14:01	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-38	Drinking Fountain	Hallway RM 326 Left DF	Active - Consumption	Initial - First Draw	24-13144	10/25/2024 4:20	11/18/2024 14:07	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-39	Drinking Fountain	DF RM 329	Active - Consumption	Initial - First Draw	24-13145	10/25/2024 4:21	11/18/2024 14:13	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-40	Drinking Fountain	DF RM 330	Active - Consumption	Initial - First Draw	24-13146	10/25/2024 4:22	11/18/2024 14:19	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-41	Filtered Bottle Filler	Staff 342 FBF	Active - Consumption	Initial - First Draw	24-13147	10/25/2024 4:24	11/18/2024 14:25	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-42	Sink	Staff 342 Sink	Active - Consumption	Initial - First Draw	24-13148	10/25/2024 4:25	11/18/2024 14:31	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-43	Drinking Fountain	DF RM 346	Active - Consumption	Initial - First Draw	24-13149	10/25/2024 4:27	11/18/2024 14:37	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-44	Sink	RM 347 Sink	Active - Consumption	Initial - First Draw	24-13150	10/25/2024 4:28	11/19/2024 11:29	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-45	Drinking Fountain	DF RM 350	Active - Consumption	Initial - First Draw	24-13151	10/25/2024 4:29	11/19/2024 11:35	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-46	Drinking Fountain	DF RM 348	Active - Consumption	Initial - First Draw	24-13152	10/25/2024 4:30	11/19/2024 11:53	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-47	Drinking Fountain	DF RM 353	Active - Consumption	Initial - First Draw	24-13153	10/25/2024 4:32	11/19/2024 12:11	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-48	Drinking Fountain	DF RM 357	Active - Consumption	Initial - First Draw	24-13154	10/25/2024 4:34	11/19/2024 12:17	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-110-49	Drinking Fountain	DF RM 358	Active - Consumption	Initial - First Draw	24-13155	10/25/2024 4:35	11/19/2024 12:23	ND	µg/L	Twin City Water Clinic, Inc.				

Definitions of Reporting Fields

Field Name	Response Needed or Definition	Where does this information come
Unique Sample Site Identification Number	A unique number or code using numbers and or letters that a facility assigns to each fixture in the building. This prevents confusion about which sample goes with which fixture.	Facility
Fixture Type	Describes the type of fixture such as sink, fountain, bottle filler, ice machine, kitchen kettle, coffee machine, etc..	Facility
Location Description	Specific description of the location of the fixture. Ex. Classroom sink in Room 112 or Left drinking fountain in gym	Facility
Fixture Status	Describes if the fixture is currently being used and how it is used. Examples are Active-Consumption, Inactive-Consumption, Active-Nonconsumption, Inactive-Nonconsumption	Facility
Sample Collection Type	Initial first draw, Initial Flushed, Follow-up First Draw, Follow-up Flushed, Other	Facility
Laboratory Identification Number	Number assigned by the laboratory to each sample. It may be helpful for facilities using this spreadsheet to cross reference to their lab results. (Optional)	Lab
Date/Time Collected	Date and time the sample was collected Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab
Date/Time Analyzed	Date and time the sample was analyzed Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab
Numeric Result	This is the number representing the result reported by the lab. Ex. 5.12, 7.03, 89.02, for results that are not detected please use ND	Lab
Unit of Measure	This is the unit of the result reported by the lab Ex. Parts per billion (ppb), micrograms per liter (ug/L).	Lab
Name of Laboratory Used For Analysis	The name of the laboratory used for sample analysis.	Lab
Remediation Action	Describes the type of remediation (if needed). Select from drop down menu. You only need to complete if result is 5ppb or more. If the action you took is not listed select OTHER and describe	Facility
Other Remediation-Please Describe	Use this field to type in your remediation action if the choice was not listed in the Remediation Action Drop down menu.	Facility
Was Remediation Successful (ie. Follow-up testing below 5 ppb)	Select from the drop down. Options are Yes, No, Not Applicable(N/A), and Pending Results	Facility

Other Important Terms	Definitions
Consumption	For the purposes of this testing consumption means a fixture where the water is used for drinking water or food/formula preparation.
Non-Consumption	A fixture that is not used for drinking water or food preparation such as a laboratory sink or a mop sink in a locked custodial closet. MDH recommends that non-consumption fixtures be labeled as not for drinking if they are not tested.
Active	A fixture currently able to be used.
Inactive	A fixture that has been taken out of service either temporarily or permanently
First Draw	A type of water sample where the water has been stagnant for 8-18 hours before collecting a sample. The most common type of lead sample type.
Flushed	A type of water sample where the water has been allowed to run before collecting. Typically collected when investigating to source of lead or evaluating remediation options.
Initial	This is typically a first draw sample collected during a round of monitoring. A sample may be an initial-first draw or an initial-flushed
Follow-up	This is typically collected if an initial sample collected during a round of sampling is 5ppb or more. Follow-up samples can be repeated first draw samples or flushed samples depending on the type of follow-up activities conducted to reduce lead.