

Radon Tests - Hoover Elementary School									
#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Main Office	W. Wall Counter	2987397	03/04/24	6:21 AM	03/06/24	6:42 AM	1.8	None.
2	Principal's Office	W. Wall Bookcase	2987423	03/04/24	6:22 AM	03/06/24	6:43 AM	2.8	None.
3	Principal's Conference Room	S. Wall Counter	2987473	03/04/24	6:23 AM	03/06/24	6:44 AM	1.6	None.
4	Health Room	S. Wall Desk	2987399	03/04/24	6:24 AM	03/06/24	6:45 AM	1.4	None.
5	Staff Work Room	W. Wall File Cabinet	2987495	03/04/24	6:25 AM	03/06/24	6:46 AM	1.7	None.
6	Room 1	S. Wall Desk	2987456	03/04/24	6:26 AM	03/06/24	6:47 AM	0.9	None.
7	Room 1 - Blank	S. Wall Desk	2987356	03/04/24	6:27 AM	03/06/24	6:48 AM	0.1	None.
8	Gym # 1	N. Wall NE End	2989280	03/04/24	6:28 AM	03/06/24	6:49 AM	0.1	None.
9	Gym # 2	N. Wall NW End	2987402	03/04/24	6:29 AM	03/06/24	6:50 AM	0.5	None.
10	Gym # 3	S. Wall N.E End	2896332	03/04/24	6:30 AM	03/06/24	6:51 AM	0.1	None.
11	Stage	N.W. End of Stage	2987426	03/04/24	6:31 AM	03/06/24	6:52 AM	0.3	None.
12	Stage - Duplicate	N.W. End of Stage	2987460	03/04/24	6:32 AM	03/06/24	6:53 AM	1.0	None.
13	Room 5	Middle of Classroom	2989235	03/04/24	6:33 AM	03/06/24	6:54 AM	0.9	None.
14	Custodial Office	Center of Room	2987389	03/04/24	6:34 AM	03/06/24	6:55 AM	1.5	None.
15	Cafeteria # 1	S. Wall By Display Case	2987501	03/04/24	6:35 AM	03/06/24	6:56 AM	0.5	None.
16	Cafeteria # 2	S. Wall Center of Room	2987295	03/04/24	6:36 AM	03/06/24	6:57 AM	1.3	Found Disturbed.
17	Room 11	W. Wall Center of Bookshelf	2987433	03/04/24	6:37 AM	03/06/24	6:58 AM	1.1	None.
18	Room 12	S.E. Wall On Book Shelf	2987467	03/04/24	6:38 AM	03/06/24	6:59 AM	0.8	None.
19	Room 12 - Blank	S.E. Wall On Book Shelf	2987403	03/04/24	6:39 AM	03/06/24	7:00 AM	0.6	None.
20	Room 13	West Wall By The Sink First Shelf Up	2987442	03/04/24	6:40 AM	03/06/24	7:01 AM	2.4	None.
21	Room 14	S. West Wall On Book Shelf	2987374	03/04/24	6:41 AM	03/06/24	7:02 AM	1.1	None.
22	Room 14 - Duplicate	S. West Wall On Book Shelf	2987412	03/04/24	6:42 AM	03/06/24	7:03 AM	1.4	None.
23	Room 21	E. Wall File Cabinet	2987431	03/04/24	6:43 AM	03/06/24	7:04 AM	0.8	None.
24	Room 21 - Duplicate	E. Wall File Cabinet	2987449	03/04/24	6:44 AM	03/06/24	7:05 AM	0.3	None.
25	Room 22	W. Wall Center of Bookshelf	2989271	03/04/24	6:22 AM	03/06/24	6:42 AM	1.5	None.
26	Room 22 - Blank	W. Wall Center of Bookshelf	2987493	03/04/24	6:23 AM	03/06/24	6:43 AM	0.3	None.
27	Room 23	W. Wall Center of Bookshelf	2987440	03/04/24	6:24 AM	03/06/24	6:44 AM	0.8	None.
28	Room 24	W. Wall Center of Bookshelf	2987427	03/04/24	6:25 AM	03/06/24	6:45 AM	1.6	None.
29	Staff Break Room	E. Wall Center	2987400	03/04/24	6:26 AM	03/06/24	6:46 AM	0.5	None.
30	Small Staff Break Room	W. Wall Center	2989202	03/04/24	6:27 AM	03/06/24	6:47 AM	1.0	None.
31	Room 31	E. Wall Center of Bookshelf	2987494	03/04/24	6:28 AM	03/06/24	6:48 AM	0.4	None.
32	Room 32	E. Wall Top of Bookshelf	2987469	03/04/24	6:29 AM	03/06/24	6:49 AM	1.6	None.
33	Room 32 - Duplicate	E. Wall Top of Bookshelf	2989222	03/04/24	6:30 AM	03/06/24	6:50 AM	1.5	None.
34	Room 33	E. Wall Center of Room	2989186	03/04/24	6:31 AM	03/06/24	6:51 AM	1.5	None.
35	Room 34	W. Wall Center of Room	2989265	03/04/24	6:32 AM	03/06/24	6:52 AM	0.5	None.
36	Room 34 - Blank	W. Wall center of Room	2989229	03/04/24	6:33 AM	03/06/24	6:53 AM	0.7	None.
37	Room 41	W. Wall Cubby	2987408	03/04/24	6:34 AM	03/06/24	6:54 AM	0.1	None.
38	Room 41 - Duplicate	W. Wall Cubby	2987409	03/04/24	6:35 AM	03/06/24	6:55 AM	1.0	None.
39	Room 42	W. Wall By Sink	2987439	03/04/24	6:36 AM	03/06/24	6:56 AM	0.2	None.
40	Room 43	W. Wall By Sink	2989279	03/04/24	6:37 AM	03/06/24	6:57 AM	0.1	None.
41	Room 44	W. Wall By Sink	2989193	03/04/24	6:38 AM	03/06/24	6:58 AM	1.2	None.
42	Room 44 - Blank	W. Wall By Sink	2989203	03/04/24	6:39 AM	03/06/24	6:59 AM	0.1	None.
43	Room 51	Left of Door On Shelf	2987488	03/04/24	6:40 AM	03/06/24	7:00 AM	1.6	None.
44	Room 52	Righ of Front Door On Shelf	2987496	03/04/24	6:41 AM	03/06/24	7:01 AM	0.8	None.
45	Room 52 - Duplicate	Right of Front Door on Shelf	2989219	03/04/24	6:42 AM	03/06/24	7:02 AM	1.4	None.
46	Room 53	Left of Front Door On Table	2987404	03/04/24	6:43 AM	03/06/24	7:03 AM	2.8	None.
47	Room 53 - Blank	Left of Front Door on Table	2987448	03/04/24	6:44 AM	03/06/24	7:04 AM	1.7	None.
48	Room 54	Right of Front Door By Office	2989221	03/04/24	6:45 AM	03/06/24	7:05 AM	1.8	None.
49	Room 55	Right of Front Door By Office	2987418	03/04/24	6:25 AM	03/06/24	6:44 AM	1.8	None.
50	Room 55 - Blank	Right of Front Door by Office	2987388	03/04/24	6:26 AM	03/06/24	6:45 AM	0.1	None.
51	Room 56	Left of Front Door On Shelf	2987463	03/04/24	6:27 AM	03/06/24	6:46 AM	1.3	None.
52	Room 56 - Duplicate	Left of Front Door On Shelf	2987626	03/04/24	6:28 AM	03/06/24	6:47 AM	1.1	None.
53	Media Center # 1	Librarian Desk	CRM	11/13/24	7:00 AM	11/15/24	7:15 AM	1.1	None.
54	Media Center # 2	N.W. Wall Bookcase	2987406	03/04/24	6:30 AM	03/06/24	6:49 AM	2.1	None.
55	Media Center - Blank	Librarian Desk	2989278	03/04/24	6:31 AM	03/06/24	6:50 AM	0.6	None.
56	Media Center Office	W. Wall Bookcase	2989294	03/04/24	6:32 AM	03/06/24	6:51 AM	2.5	None.
57	Computer Room	S.E. Wall Counter	2987417	03/04/24	6:33 AM	03/06/24	6:52 AM	1.8	None.
58	Computer Room - Duplicate	S.E. Wall Counter	2989256	03/04/24	6:34 AM	03/06/24	6:53 AM	2.8	None.
59	Computer Room Office	S.E. Wall Counter	2989185	03/04/24	6:35 AM	03/06/24	6:54 AM	1.7	None.
60	Computer Room Study	AV Stand	CRM	11/13/24	6:12 AM	11/15/24	6:12 AM	1.1	Tested high, Outside air increased
61	Room 45	S. Wall Top of Cubbie	2987396	03/04/24	6:37 AM	03/06/24	6:56 AM	0.8	None.
62	Room 45 - Blank	S. Wall Top of Cubbie	2989242	03/04/24	6:38 AM	03/06/24	6:57 AM	0.4	None.
63	Room 46	E. Wall Top of Cubbie	2989269	03/04/24	6:39 AM	03/06/24	6:58 AM	1.1	None.
64	Room 47	S. Wall	2987483	03/04/24	6:40 AM	03/06/24	6:59 AM	0.1	None.
65	Room 47 - Duplicate	S. Wall	2987486	03/04/24	6:41 AM	03/06/24	7:00 AM	0.8	None.
66	Room 48	S. West Corner	2989224	03/04/24	6:42 AM	03/06/24	7:01 AM	0.4	None.
67	Room 61	S. Wall Desk	2987435	03/04/24	6:43 AM	03/06/24	7:02 AM	0.9	None.
68	Room 61 - Duplicate	S. Wall Desk	2989272	03/04/24	6:44 AM	03/06/24	7:03 AM	0.5	None.
69	Room 62	S.E. Corner	2987392	03/04/24	6:45 AM	03/06/24	7:04 AM	0.9	None.
70	Room 62 - Blank	S.E. Corner	2987477	03/04/24	6:46 AM	03/06/24	7:05 AM	0.3	None.
#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
71	Room 64 (a)	KSU Radon Chamber	2987394	03/04/24		03/06/24		25.6	None.
72	Room 64 (b)	KSU Radon Chamber	2989253	03/04/24		03/06/24		25.1	None.

*The E.P.A.'s recommended action level for radon is 4.0 pCi/L.

*This is not a health based number.

*Outdoor radon levels across the country average 0.4 pCi/L.

*If an RPD test result over 4.0 pCi/L differs by 28% or more, the data quality should be questioned.

*A trend in RPE values that are more than ± 30% should be investigated