

Radon Tests - Abe Lincoln Elementary School									
#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Staff Break Room	South - Table	2815875	26-Oct-20	5:53 AM	28-Oct-20	1:56 PM	0.8	None.
2	Staff Work Room	SE Corner	2765807	26-Oct-20	5:56 AM	28-Oct-20	1:58 PM	1.0	None.
3	Health Room	E. Desk	2816007	26-Oct-20	5:58 AM	28-Oct-20	2:00 PM	0.4	None.
4	Main Office	W. Desk	2816035	26-Oct-20	5:59 AM	28-Oct-20	2:01 PM	0.6	None.
5	Main Office - Duplicate	W. Desk	2815930	26-Oct-20	6:00 AM	28-Oct-20	2:01 PM	0.6	None.
6	Main Office Conference Room	NE. Desk	2815914	26-Oct-20	6:03 AM	28-Oct-20	2:02 PM	0.8	None.
7	Principal's Office	E. Book Case	2815941	26-Oct-20	6:05 AM	28-Oct-20	2:02 PM	1.1	None.
8	Music Room	S.E. Stage Ledge	2816042	26-Oct-20	6:07 AM	28-Oct-20	2:08 PM	0.5	None.
9	Music Room - Blank	S.E. Stage Ledge	2815934	26-Oct-20	6:07 AM	26-Oct-20	6:07 AM	0.4	None.
10	Office North of Music Room	N. Book Case	2816044	26-Oct-20	6:08 AM	28-Oct-20	2:08 PM	0.9	None.
11	Stage	N.W. Corner-Paper Roll	2815932	26-Oct-20	6:13 AM	28-Oct-20	2:06 PM	0.7	None.
12	Conference Room A	E. Book Case	2765654	26-Oct-20	6:11 AM	28-Oct-20	2:04 PM	1.0	None.
13	Gym # 1	N.E. Stage Corner	2765200	26-Oct-20	6:16 AM	28-Oct-20	2:11 PM	0.7	None.
14	Gym # 2	S.E. Stage Corner	2817996	26-Oct-20	6:17 AM	28-Oct-20	2:13 PM	0.8	None.
15	Gym # 3	S.W. Corner	2815871	26-Oct-20	6:18 AM	28-Oct-20	2:13 PM	0.6	None.
16	Custodial Office	S. Desk	2816039	26-Oct-20	6:20 AM	28-Oct-20	2:15 PM	0.9	None.
17	Cafeteria # 1	S. Counter	2816735	26-Oct-20	6:21 AM	28-Oct-20	2:15 PM	0.5	None.
18	Cafeteria # 2	NW. File Cabinet	2765201	26-Oct-20	6:22 AM	28-Oct-20	2:16 PM	0.5	None.
19	Room 1	E. Counter	2816010	26-Oct-20	6:25 AM	28-Oct-20	2:18 PM	0.6	None.
20	Room 2	E. Counter	2815882	26-Oct-20	6:27 AM	28-Oct-20	2:19 PM	0.7	None.
21	Room 3	E. Counter	2815950	26-Oct-20	6:28 AM	28-Oct-20	2:20 PM	0.5	None.
22	Room 4	N. Counter	2765778	26-Oct-20	6:30 AM	28-Oct-20	2:22 PM	0.4	None.
23	Room 4 - Duplicate	N. Counter	2815945	26-Oct-20	6:30 AM	28-Oct-20	2:22 PM	0.8	None.
24	Room 5	E. Counter	2816047	26-Oct-20	6:31 AM	28-Oct-20	2:23 PM	1.0	None.
25	Room 5 - Blank	E. Counter	2816008	26-Oct-20	6:31 AM	26-Oct-20	6:31 AM	0.2	None.
26	Room 6	W. File Cabinet	2815884	26-Oct-20	6:33 AM	28-Oct-20	2:25 PM	0.6	None.
27	Room 7	W. Counter	2815860	26-Oct-20	6:37 AM	28-Oct-20	2:27 PM	0.7	None.
28	Room 8	S. Wall File Cabinet	2817983	26-Oct-20	6:38 AM	28-Oct-20	2:28 PM	0.8	None.
29	Room 9	E. File Cabinet	2816025	26-Oct-20	6:40 AM	28-Oct-20	2:30 PM	0.8	None.
30	Room 9 - Duplicate	E. File Cabinet	2815935	26-Oct-20	6:40 AM	28-Oct-20	2:30 PM	0.8	None.
31	Room 10	W. Counter	2817994	26-Oct-20	6:41 AM	28-Oct-20	2:31 PM	0.6	None.
32	Room 11E	W. Bookcase	2816048	26-Oct-20	6:06 AM	28-Oct-20	2:32 PM	0.7	None.
33	Room 11D	N. White Board	2815880	26-Oct-20	6:08 AM	28-Oct-20	2:34 PM	0.4	None.
34	Room 11C	E. Wall Table	2816018	26-Oct-20	6:11 AM	28-Oct-20	2:35 PM	0.5	None.
35	Room 11B	S. Wall Table	2815915	26-Oct-20	6:13 AM	28-Oct-20	3:05 PM	0.7	None.
36	Room 11A	Table Center Room	2765248	26-Oct-20	6:15 AM	28-Oct-20	2:36 PM	1.3	None.
37	Room 12	E. Wall File Cabinet	2815933	26-Oct-20	6:16 AM	28-Oct-20	3:06 PM	0.6	None.
38	Room 13	S. Wall Behind Desk	2765775	26-Oct-20	6:20 AM	28-Oct-20	2:40 PM	0.5	None.
39	Room 14	E. Wall Cabinet	2815943	26-Oct-20	6:22 AM	28-Oct-20	2:42 PM	1.2	None.
40	Room 15	Center Table	2817988	26-Oct-20	6:23 AM	28-Oct-20	2:41 PM	0.5	None.
41	Room 15 - Duplicate	Center Table	2816011	26-Oct-20	6:23 AM	28-Oct-20	2:41 PM	0.5	None.
42	Room 16	Center Table	2815931	26-Oct-20	6:28 AM	28-Oct-20	2:43 PM	0.8	None.
43	Room 17	Center Table	2710039	26-Oct-20	6:30 AM	28-Oct-20	2:44 PM	0.5	None.
44	Room 18	Center Table	2817990	26-Oct-20	6:32 AM	28-Oct-20	2:46 PM	0.7	None.
45	Room 19	Center Table	2815936	26-Oct-20	6:35 AM	28-Oct-20	2:46 PM	0.6	None.
46	Room 20	Center Table	2815917	26-Oct-20	6:37 AM	28-Oct-20	2:48 PM	0.2	None.
47	Room 20 - Duplicate	Center Table	2765207	26-Oct-20	6:37 AM	28-Oct-20	2:48 PM	0.5	None.
48	Room 21	S. Wall File	2707346	26-Oct-20	6:39 AM	28-Oct-20	2:49 PM	0.7	None.
49	Room 22	E. Wall Cabinet	2765595	26-Oct-20	6:41 AM	28-Oct-20	2:51 PM	0.5	None.
50	Room 23	Center Table	2816020	26-Oct-20	6:43 AM	28-Oct-20	2:50 PM	0.5	None.
51	Room 23 - Blank	Center Table	2765206	26-Oct-20	6:43 AM	26-Oct-20	6:43 AM	0.1	None.
52	Room 24	W. Wall Cabinet	2816023	26-Oct-20	6:46 AM	28-Oct-20	2:53 PM	0.6	None.
53	Room 24 - Duplicate	W. Wall Cabinet	2815887	26-Oct-20	6:46 AM	28-Oct-20	2:03 PM	0.6	None.
54	Media Center # 1	W. Wall Cabinet	2815912	26-Oct-20	6:53 AM	28-Oct-20	2:54 PM	0.4	None.
55	Media Center # 2	N.W. Corner Table	2704536	26-Oct-20	6:54 AM	28-Oct-20	2:58 PM	0.6	None.
56	Media Center Office	W. Wall Counter	2815863	26-Oct-20	6:56 AM	28-Oct-20	3:00 PM	0.4	None.
57	Media Center Work Room	W. Wall Table	2708662	26-Oct-20	6:57 AM	28-Oct-20	3:02 PM	0.2	None.
58	Office - Northeast Corner MC	Table Center Room	2708558	26-Oct-20	6:59 AM	28-Oct-20	3:03 PM	1.0	None.
59	Computer Room	E. Wall Table	2765246	26-Oct-20	6:50 AM	28-Oct-20	2:57 PM	0.4	None.
60	Office - West of Computer Room	S. Table	2816028	26-Oct-20	6:49 AM	28-Oct-20	2:56 PM	0.2	None.
#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
61	Spike # 1 (Room 25-A)	Spiked at KSU Radon Chamber (21.3 pCi/L)	2765219	26-Oct-20	10:00 AM	28-Oct-20	10:00 AM	22.0	None.
62	Spike # 2 (Room 25-B)	Spiked at KSU Radon Chamber (21.3 pCi/L)	2815872	26-Oct-20	10:00 AM	28-Oct-20	10:00 AM	25.2	None.

\*The E.P.A.'s recommended action level for radon is 4.0 pCi/L.

\*This is not a health based number.

\*Outdoor radon levels across the country average 0.4 pCi/L.

\*If an RPD test result over 4.0 pCi/L differs by 28% or more, the data quality should be questioned.

\*A trend in RPE values that are more than ± 30% should be investigated