

Radon Tests - Jacksonville Elementary School									
#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Main Office	North Wall	2918304	19-Oct-21	5:57 AM	21-Oct-21	6:28 AM	1.1	None.
2	Principle's Office	West Wall	2918268	19-Oct-21	5:59 AM	21-Oct-21	6:29 AM	1.6	None.
3	Health Room	East Wall	2918298	19-Oct-21	6:02 AM	21-Oct-21	6:30 AM	0.8	None.
4	Staff Work Room	North Wall	2918305	19-Oct-21	6:06 AM	21-Oct-21	6:31 AM	1.0	None.
5	Room 6	West Wall	2756625	19-Oct-21	6:10 AM	21-Oct-21	6:33 AM	0.7	None.
6	Room 7	West Wall	2918240	19-Oct-21	6:14 AM	21-Oct-21	6:35 AM	0.8	None.
7	Room 7 - Blank	West Wall	2916962	19-Oct-21	6:15 AM	21-Oct-21	6:36 AM	0.4	None.
8	Room 4	West Wall	2918300	19-Oct-21	6:18 AM	21-Oct-21	6:38 AM	0.8	None.
9	Room 4 - Duplicate	West Wall	2913378	19-Oct-21	6:19 AM	21-Oct-21	6:38 AM	0.2	None.
10	Room 5	South Wall	2916029	19-Oct-21	6:22 AM	21-Oct-21	6:40 AM	0.6	None.
11	Room 2	North Wall	2918250	19-Oct-21	6:25 AM	21-Oct-21	6:42 AM	0.7	None.
12	Room 3	North Wall	2918287	19-Oct-21	6:27 AM	21-Oct-21	6:43 AM	0.9	None.
13	Room 3 - Work Room/Storage	North Wall	2916036	19-Oct-21	6:28 AM	21-Oct-21	6:44 AM	0.8	None.
14	Room 1	North Wall	2916014	19-Oct-21	6:30 AM	21-Oct-21	6:48 AM	0.8	None.
15	Staff Break Room	South Wall	2916040	19-Oct-21	6:32 AM	21-Oct-21	6:49 AM	0.6	None.
16	Cafeteria	SW Corner	2913665	19-Oct-21	5:59 AM	21-Oct-21	6:29 AM	0.9	None.
17	Cafeteria - Duplicate	SW Corner	2918283	19-Oct-21	5:59 AM	21-Oct-21	6:29 AM	0.9	None.
18	Media Center # 1	Middle of Room	2913344	19-Oct-21	6:04 AM	21-Oct-21	6:31 AM	1.0	None.
19	Media Center # 2	SW Corner	2918266	19-Oct-21	6:07 AM	21-Oct-21	6:32 AM	0.8	None.
20	Media Center Office # 1	East Wall	2918302	19-Oct-21	6:09 AM	21-Oct-21	6:32 AM	1.3	None.
21	Media Center Office # 2	SE Corner	2917644	19-Oct-21	6:12 AM	21-Oct-21	6:33 AM	1.6	None.
22	Media Center Office # 3	NE Corner	2918257	19-Oct-21	6:14 AM	21-Oct-21	6:34 AM	1.5	None.
23	Media Center Office # 4	NE Corner	2918308	19-Oct-21	6:15 AM	21-Oct-21	6:35 AM	1.3	None.
24	Computer Room	NE Wall	2913345	19-Oct-21	6:17 AM	21-Oct-21	6:36 AM	1.1	None.
25	Comp Room Off 1	SW Corner	2756580	19-Oct-21	6:19 AM	21-Oct-21	6:36 AM	1.1	None.
26	Comp Room Off 2	NE Corner	2817993	19-Oct-21	6:21 AM	21-Oct-21	6:37 AM	1.2	None.
24	Media Work Room	West Corner	2815951	19-Oct-21	6:23 AM	21-Oct-21	6:37 AM	0.7	None.
25	Room 16	West Wall	2917634	19-Oct-21	6:26 AM	21-Oct-21	6:39 AM	1.8	None.
26	Room 17	West Wall	2913673	19-Oct-21	6:28 AM	21-Oct-21	6:40 AM	1.7	None.
27	Room 17 - Blank	West Wall	2917594	19-Oct-21	6:28 AM	21-Oct-21	6:40 AM	0.3	None.
28	Room 18	SE Wall	2918288	19-Oct-21	6:31 AM	21-Oct-21	6:41 AM	0.9	None.
29	Room 19	SE Wall	2918277	19-Oct-21	6:33 AM	21-Oct-21	6:42 AM	1.1	None.
30	Room 19 - Duplicate	SE Wall	2917610	19-Oct-21	6:33 AM	21-Oct-21	6:42 AM	0.7	None.
31	Room 20	NE Wall	2913707	19-Oct-21	6:00 AM	21-Oct-21	6:30 AM	1.0	None.
32	Room 21	NE Wall	2916942	19-Oct-21	6:01 AM	21-Oct-21	6:33 AM	1.3	None.
33	Music Room	NW Wall	2918280	19-Oct-21	6:04 AM	21-Oct-21	6:36 AM	1.2	None.
34	Music Room - Duplicate	NW Wall	2916018	19-Oct-21	6:04 AM	21-Oct-21	6:37 AM	0.8	None.
35	Room 9	SE Wall	2916055	19-Oct-21	6:08 AM	21-Oct-21	6:38 AM	1.0	None.
36	Room 8	NE Wall	2918256	19-Oct-21	6:13 AM	21-Oct-21	6:40 AM	1.0	None.
37	Room 11	NE Wall	2918267	19-Oct-21	6:16 AM	21-Oct-21	6:41 AM	0.9	None.
38	Room 10	SW Wall	2918301	19-Oct-21	6:20 AM	21-Oct-21	6:42 AM	0.7	None.
39	Room 12	NW Wall	2918281	19-Oct-21	6:22 AM	21-Oct-21	6:43 AM	0.8	None.
40	Room 13	SE Wall	2916043	19-Oct-21	6:27 AM	21-Oct-21	6:44 AM	1.1	None.
41	Room 13 - Duplicate	SE Wall	2913758	19-Oct-21	6:27 AM	21-Oct-21	6:45 AM	0.9	None.
42	Room 15	SW Wall	2913377	19-Oct-21	6:30 AM	21-Oct-21	6:46 AM	1.5	None.
43	Room 14	SW Wall	2913339	19-Oct-21	6:37 AM	21-Oct-21	6:48 AM	1.7	None.
44	Gymnasium # 1	West Wall	2913380	19-Oct-21	5:58 AM	21-Oct-21	6:29 AM	0.9	None.
45	Gymnasium # 2	South Wall	2917604	19-Oct-21	6:03 AM	21-Oct-21	6:31 AM	1.0	None.
46	Gymnasium # 3	East Wall	2916026	19-Oct-21	6:09 AM	21-Oct-21	6:33 AM	1.4	None.
47	Gymnasium # 4	North Wall	2913708	19-Oct-21	6:11 AM	21-Oct-21	6:35 AM	1.0	None.
48	Gymnasium - Blank	North Wall	2916013	19-Oct-21	6:11 AM	21-Oct-21	6:35 AM	0.1	None.
49	Stage	SSW Wall	2918204	19-Oct-21	6:41 AM	21-Oct-21	6:50 AM	1.4	None.
50	Stage - Duplicate	SSW Wall	2913341	19-Oct-21	6:41 AM	21-Oct-21	6:50 AM	1.5	None.
#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
51	Spike #1 (Room 23)		2765264					30.4	None.
52	Spike #2 (Room 22)		2818003					28.2	None.

*The E.P.A.'s recommended action level for radon is 4.0 pCi/L.

*This is not a health based number.

*Outdoor radon levels across the country average 0.4 pCi/L.

*If an RPD test result over 4.0 pCi/L differs by 28% or more, the data quality should be questioned.

*A trend in RPE values that are more than $\pm$ 30% should be investigated