

Jefferson									
#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Main Office	Northwest Countertop	2987411	03/05/24	6:12 AM	03/07/24	6:40 AM	0.6	None.
2	Principal's Office	Bookshelf	2989188	03/05/24	6:13 AM	03/07/24	6:41 AM	0.6	None.
3	Health Room	Top of Fridge	2987410	03/05/24	6:14 AM	03/07/24	6:42 AM	0.6	None.
4	Room 7	North Wall - Countertop	2989205	03/05/24	6:15 AM	03/07/24	6:43 AM	0.4	None.
5	Room 7 - Duplicate	North Wall - Countertop	2989207	03/05/24	6:16 AM	03/07/24	6:44 AM	0.6	None.
6	Room 9	West Wall - Cubby	2990196	03/05/24	6:17 AM	03/07/24	6:45 AM	0.5	None.
7	Room 11	West Wall - Cubby	2990207	03/05/24	6:18 AM	03/07/24	6:46 AM	0.1	None.
8	Room 13	Bookshelf	2990188	03/05/24	6:19 AM	03/07/24	6:47 AM	0.1	None.
9	Room 12	East Wall - Cabinet	2990170	03/05/24	6:20 AM	03/07/24	6:48 AM	0.7	None.
10	Room 10	East Wall - Countertop	2989288	03/05/24	6:21 AM	03/07/24	6:49 AM	0.7	None.
11	Room 10 - Blank	East Wall - Countertop	2990503	03/05/24	6:22 AM	03/07/24	6:50 AM	0.5	None.
12	Room 6	West Wall - Bookshelf	2990064	03/05/24	6:23 AM	03/07/24	6:51 AM	0.7	None.
13	Room 14	Northeast Corner	2987479	03/05/24	6:24 AM	03/07/24	6:52 AM	1.5	None.
14①	Media Center # 1	Southeast Wall - Bookshelf	2989273	03/05/24	6:25 AM	03/07/24	6:53 AM	1.7	None.
15②	Media Center # 2	North Wall - Counter	2987472	03/05/24	6:26 AM	03/07/24	6:54 AM	1.5	None.
16	Room 21	Northwest Wall - Countertop	2989232	03/05/24	6:27 AM	03/07/24	6:55 AM	1.4	None.
17	Room 23	East Wall - Filing Cabinet	2990182	03/05/24	6:28 AM	03/07/24	6:56 AM	1.2	None.
18	Room 25	West Wall - Shelf	2989218	03/05/24	6:29 AM	03/07/24	6:57 AM	0.9	None.
19	Room 27	Northwest Wall - Countertop	2990198	03/05/24	6:08 AM	03/07/24	6:41 AM	0.7	None.
20	Room 29	West Wall - Cubby	2990171	03/05/24	6:09 AM	03/07/24	6:42 AM	0.2	None.
21	Room 31	West Wall - Countertop	2990177	03/05/24	6:10 AM	03/07/24	6:43 AM	0.5	None.
22	Room 33	East Wall - Countertop	2990189	03/05/24	6:11 AM	03/07/24	6:44 AM	0.5	None.
23	Room 33 - Blank	East Wall - Countertop	2990197	03/05/24	6:12 AM	03/07/24	6:45 AM	0.5	None.
24	Room 34	Southeast Wall - Bookshelf	2990223	03/05/24	6:13 AM	03/07/24	6:46 AM	0.8	None.
26	Room 35	Southeast Wall - Filing Cabinet	2990229	03/05/24	6:15 AM	03/07/24	6:48 AM	0.6	None.
28①	Modular #1	Northeast Wall - Office Bookcase	2990481	03/05/24	6:17 AM	03/07/24	6:50 AM	0.4	None.
29①	Modular #1 - Duplicate	North East Wall - Office Bookcase	2990493	03/05/24	6:18 AM	03/07/24	6:51 AM	0.5	None.
30②	Modular #2	East Wall - Conference Room Shelf	2990487	03/05/24	6:19 AM	03/07/24	6:52 AM	0.5	None.
31③	Modular #3	East Wall - Kid's Room - Filing Cabinet	2990162	03/05/24	6:20 AM	03/07/24	6:53 AM	0.7	None.
32④	Modular #4	Southeast Wall - Office Shelf	2990211	03/05/24	6:21 AM	03/07/24	6:54 AM	0.3	None.
33⑤	Modular #5	Southwest Wall - Break Room	2990490	03/05/24	6:22 AM	03/07/24	6:55 AM	0.3	None.
34⑤	Modular #5 - Blank	Southwest Wall - Break Room	2990156	03/05/24	6:23 AM	03/07/24	6:56 AM	0.3	None.
35⑥	Modular #6	North Wall - Office Desk	2990486	03/05/24	6:24 AM	03/07/24	6:57 AM	0.5	None.
38	Room 32	South Wall - BookCase	2990492	03/05/24	6:27 AM	03/07/24	7:00 AM	0.4	None.
39	Room 30	North Wall - Table	2990209	03/05/24	6:28 AM	03/07/24	7:01 AM	0.4	None.
40	Room 30 - Duplicate	North Wall - Table	2989273	03/05/24	6:29 AM	03/07/24	7:02 AM	0.5	None.
41	Room 28	West Wall - Bookcase	2990166	03/05/24	6:30 AM	03/07/24	7:03 AM	0.4	None.
42	Room 26	North Wall - Cabinet By Clock	2990184	03/05/24	6:31 AM	03/07/24	7:04 AM	1.5	None.
43	Room 24	Desk	2990164	03/05/24	6:32 AM	03/07/24	7:05 AM	1.2	None.
44	Room 22	By Door	2990180	03/05/24	6:13 AM	03/07/24	6:40 AM	1.6	None.
45	Room 20	North Wall - Countertop	2990225	03/05/24	6:14 AM	03/07/24	6:41 AM	1.3	None.
46	Room 20 - Duplicate	North Wall - Countertop	2990501	03/05/24	6:15 AM	03/07/24	6:42 AM	1.5	None.
47	Room 18	North Wall - Countertop	2990208	03/05/24	6:16 AM	03/07/24	6:43 AM	0.8	None.
48	Room 17	South Wall - Table	2990204	03/05/24	6:17 AM	03/07/24	6:44 AM	0.9	None.
49	Room 19	By Sink	2990494	03/05/24	6:18 AM	03/07/24	6:45 AM	1.2	None.
50	Stage	South Wall	2990219	03/05/24	6:19 AM	03/07/24	6:46 AM	0.5	None.
51①	Gymnasium # 1	West Wall	2990183	03/05/24	6:20 AM	03/07/24	6:47 AM	1.4	None.
52②	Gymnasium # 2	East Wall	2990232	03/05/24	6:21 AM	03/07/24	6:48 AM	1.5	None.
53③	Gymnasium # 3	South Wall	2990222	03/05/24	6:22 AM	03/07/24	6:49 AM	0.6	None.
54④	Gymnasium # 4	West Wall	2990185	03/05/24	6:23 AM	03/07/24	6:50 AM	1.2	None.
55	Staff Work Room	East Wall - Countertop	2990220	03/05/24	6:24 AM	03/07/24	6:51 AM	0.9	None.
56	Room 3 East of Staff Work Room	Southeast Wall - Countertop	2990500	03/05/24	6:25 AM	03/07/24	6:52 AM	0.8	None.
57①	Cafeteria # 1	East Wall - Fire Extinguisher	2990165	03/05/24	6:26 AM	03/07/24	6:53 AM	0.6	None.
58②	Cafeteria # 2	West Wall - Bulletin Board	2990234	03/05/24	6:27 AM	03/07/24	6:54 AM	0.4	None.
59	Staff Break Room	East Wall - Countertop	2990161	03/05/24	6:28 AM	03/07/24	6:55 AM	0.9	None.
60	Staff Break Room - Duplicate	East Wall - Countertop	2990226	03/05/24	6:29 AM	03/07/24	6:56 AM	0.9	None.
61	Custodial Office	Desk Top	2990178	03/05/24	6:30 AM	03/07/24	6:57 AM	0.6	None.
#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
62	Spike #1 (Room 41)	KSU Radon Chamber Spike to 20.2	2987362	03/05/24		03/07/24		19.9	
63	Spike #2 (Room 42)	KSU Radon Chamber Spike to 20.2	2987498	03/05/24		03/07/24		20.2	

*The E.P.A.'s recommended action level for radon is 4.0 pCi/L.
*This is not a health based number.
*Outdoor radon levels across the country average 0.4 pCi/L.

*If an RPD test result over 4.0 pCi/L differs by 28% or more, the data quality should be questioned.
*A trend in RPE values that are more than ± 30% should be investigated