

Lead Tests - McLoughlin Middle School - Main Building - # 20481500						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20481500-001DW	20481500-001DW 24A	Black Gym - Drinking Fountain	09/23/21	ND	This drinking fountain has a lead filter on it.
2	20481500-002DW	20481500-002DW 24A	Wrestling Room - Drinking Fountain	09/23/21	1.0	None.
3	20481500-003BF	20481500-003BF 24A	Outside Black Gym Men's Restroom - Sink (Left)	09/23/21	1.4	None.
4	20481500-004BF	20481500-004BF 24A	Outside Black Gym Men's Restroom - Sink (Center)	09/23/21	0.7	None.
5	20481500-005BF	20481500-005BF 24A	Outside Black Gym Men's Restroom - Sink (Right)	09/23/21	2.5	None.
6	20481500-006BF	20481500-006BF 24A	Outside Black Gym Women's Restroom - Left Sink (1)	09/23/21	1.6	None.
7	20481500-007BF	20481500-007BF 24A	Outside Black Gym Women's Restroom - Sink (2)	09/23/21	5.7	None.
8	20481500-008BF	20481500-008BF 24A	Outside Black Gym Women's Restroom - Sink (3)	09/23/21	1.1	None.
9	20481500-009BF	20481500-009BF 24A	Outside Black Gym Women's Restroom - Right Sink (4)	09/23/21	1.0	None.
10	20481500-010BF	20481500-010BF 24A	Boy's Locker Room - Left Sink (1)	09/23/21	1.0	None.
11	20481500-011BF	20481500-011BF 24A	Boy's Locker Room - Sink (2)	09/23/21	6.7	None.
12	20481500-012BF	20481500-012BF 24A	Boy's Locker Room - Sink (3)	01/11/22	1.1	None.
13	20481500-013BF	20481500-013BF 24A	Boy's Locker Room - Right Sink (4)	09/23/21	4.8	None.
14	20481500-014BF	20481500-014BF 24A	Girl's Locker Room - Left Sink (1)	09/23/21	4.0	None.
15	20481500-015BF	20481500-015BF 24A	Girl's Locker Room - Sink (2)	09/23/21	1.4	None.
16	20481500-016BF	20481500-016BF 24A	Girl's Locker Room - Sink (3)	09/23/21	2.5	None.
17	20481500-017BF	20481500-017BF 24A	Girl's Locker Room - Right Sink (4)	09/23/21	1.1	None.
18	20481500-018DW	20481500-018DW 24A	Gold Gym - Drinking Fountain	09/23/21	ND	This drinking fountain has a lead filter on it.
N/A	N/A	N/A	Boy's Locker Room - Staff Shower	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Boy's Locker Room - Shower Head (1)	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Boy's Locker Room - Shower Head (2)	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Boy's Locker Room - Shower Head (3)	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Boy's Locker Room - Shower Head (4)	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Boy's Locker Room - Shower Head (5)	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Boy's Locker Room - Shower Head (6)	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Girl's Locker Room - Staff Shower	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Girl's Locker Room - Shower Head (1)	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Girl's Locker Room - Shower Head (2)	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Girl's Locker Room - Shower Head (3)	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Girl's Locker Room - Shower Head (4)	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Girl's Locker Room - Shower Head (5)	N/A	N/A	Water should not be consumed from the shower head.
N/A	N/A	N/A	Girl's Locker Room - Shower Head (6)	N/A	N/A	Water should not be consumed from the shower head.
19	20481500-019DW	20481500-019DW 24A	Cafeteria - Drinking Fountain	09/23/21	2.0	None.
20	20481500-020OT	20481500-020OT 24A	Cafeteria Snack Zone - Sink	09/23/21	3.3	None.
21 (A)	20481500-021KF	20481500-021KF 24A	Kitchen Pre-rinse/Dishwasher - Sink	09/23/21	ND	None.
22 (B)	20481500-022KF	20481500-022KF 24A	Kitchen Food Prep - Sink (South Wall)	09/23/21	0.7	This drinking fountain has a lead filter on it.
23 (C)	20481500-023KF	20481500-023KF 24A	Kitchen Food Prep - Sink (West Wall)	09/23/21	0.6	None.
24 (D)	20481500-024KF	20481500-024KF 24A	Kitchen - Electric Hot Water Tap	09/23/21	ND	None.
25 (E)	20481500-025KF	20481500-025KF 24A	Kitchen Hand Wash - Sink	09/23/21	ND	None.
26	20481500-026BF	20481500-026BF 24A	Kitchen Staff Unisex Restroom - Sink	09/23/21	2.6	None.
27	20481500-027DW	20481500-027DW 24A	Outside South Cafeteria Entrance - Drinking Fountain (Upper)	09/23/21	ND	None.
28	20481500-028DW	20481500-028DW 24A	Outside South Cafeteria Entrance - Drinking Fountain (Lower)	09/23/21	2.8	None.
29	20481500-029BF	20481500-029BF 24A	Near Room 106 Men's Restroom - Left Sink (1)	09/23/21	1.9	None.
30	20481500-030BF	20481500-030BF 24A	Near Room 106 Men's Restroom - Sink (2)	09/23/21	1.2	None.
31	20481500-031BF	20481500-031BF 24A	Near Room 106 Men's Restroom - Sink (3)	09/23/21	2.2	None.
32	20481500-032BF	20481500-032BF 24A	Near Room 106 Men's Restroom - Sink (4)	09/23/21	4.4	None.
33	20481500-033BF	20481500-033BF 24A	Near Room 106 Men's Restroom - Right Sink (5)	09/23/21	1.8	None.
34	20481500-034BF	20481500-034BF 24A	Near Room 106 Women's Restroom - Left Sink (1)	09/23/21	2.3	None.
35	20481500-035BF	20481500-035BF 24A	Near Room 106 Women's Restroom - Sink (2)	09/23/21	1.0	None.
36	20481500-036BF	20481500-036BF 24A	Near Room 106 Women's Restroom - Sink (3)	09/23/21	1.8	None.
37	20481500-037BF	20481500-037BF 24A	Near Room 106 Women's Restroom - Sink (4)	09/23/21	0.8	None.
38	20481500-038BF	20481500-038BF 24A	Near Room 106 Women's Restroom - Right Sink (5)	09/23/21	4.7	None.
39	20481500-039DW	20481500-039DW 24A	Room 106 - Drinking Fountain	09/23/21	0.6	None.
40	20481500-040CF	20481500-040CF 24A	Room 106 - Sink	09/23/21	2.6	None.
41	20481500-041DW	20481500-041DW 24A	Room 107 - Drinking Fountain	09/23/21	3.1	None.
42	20481500-042CF	20481500-042CF 24A	Room 107 - Sink	09/23/21	2.9	None.
43	20481500-043DW	20481500-043DW 24A	Room 108 - Drinking Fountain	09/23/21	1.2	None.
44	20481500-044CF	20481500-044CF 24A	Room 108 - Sink	09/23/21	1.5	None.
45	20481500-045DW	20481500-045DW 24A	Room 105 - Drinking Fountain	09/23/21	1.2	None.
N/A	20481500-186CF	N/A	Room 105 (Science) - Sink	05/15/19	2.6	"Non-Potable Water" Sign Installed 3 Dec 2019.
46	20481500-046DW	20481500-046DW 24A	Room 104 - Drinking Fountain	09/23/21	1.3	None.
47	20481500-047CF	20481500-047CF 24A	Room 104 - Sink	09/23/21	1.5	None.

48	20481500-048SF	20481500-048SF 24A	Staff Break Room - Sink	09/23/21	ND	None.
49	20481500-049BF	20481500-049BF 24A	Staff Break Room Men's Restroom - Sink (Left)	09/23/21	1.5	None.
50	20481500-050BF	20481500-050BF 24A	Staff Break Room Men's Restroom - Sink (Right)	09/23/21	1.4	None.
51	20481500-051BF	20481500-051BF 24A	Staff Break Room Women's Restroom - Sink (Left)	09/23/21	1.1	None.
52	20481500-052BF	20481500-052BF 24A	Staff Break Room Women's Restroom - Sink (Right)	09/23/21	7.8	None.
53	20481500-053CF	20481500-053CF 24A	Room 103 - Sink (Left - North Wall)	09/23/21	1.0	None.
54	20481500-054DW	20481500-054DW 24A	Room 103 - Drinking Fountain (Right - North Wall)	09/23/21	1.0	None.
55	20481500-055CF	20481500-055CF 24A	Room 103 - Sink (Right - North Wall)	09/23/21	ND	None.
N/A	20481500-187CF	N/A	Room 103 - Sink (Island)	05/15/19	184.0	Fixture was removed and capped.
56	20481500-056CF	20481500-056CF 24A	Room 102 A - Sink	09/23/21	0.8	None.
57	20481500-057DW	20481500-057DW 24A	Room 102 - Drinking Fountain (Left - North Wall)	09/23/21	0.7	None.
58	20481500-058CF	20481500-058CF 24A	Room 102 - Sink (Left - North Wall)	09/23/21	1.8	None.
59	20481500-059CF	20481500-059CF 24A	Room 102 - Sink (Right - North Wall)	09/23/21	1.2	None.
N/A	20481500-188CF	N/A	Room 102 - Sink (Island)	05/15/19	256.0	Fixture was removed and capped.
60	20481500-060DW	20481500-060DW 24A	Room 101 - Drinking Fountain	09/23/21	0.6	None.
61	20481500-061CF	20481500-061CF 24A	Room 101 - Sink	09/23/21	ND	None.
62	20481500-062DW	20481500-062DW 24A	Room 100 - Drinking Fountain	09/23/21	0.7	None.
63	20481500-063CF	20481500-063CF 24A	Room 100 - Sink	09/23/21	1.9	None.
64	20481500-064DW	20481500-064DW 24A	Media Center - Drinking Fountain	09/23/21	11.6	None.
65	20481500-065SF	20481500-065SF 24A	Media Center Office - Sink	09/23/21	0.9	None.
66	20481500-066SF	20481500-066SF 24A	Media Center AVA Storage - Sink	10/22/21	1.5	None.
67	20481500-067SF	20481500-067SF 24A	Media Center Staff Library - Sink	09/23/21	1.2	None.
68	20481500-068DW	20481500-068DW 24A	Outside Media Center In The Hallway - Drinking Fountain	09/23/21	ND	It has a filter.
69	20481500-069WB	20481500-069WB 24A	Outside Media Center In The Hallway - Bottle Filler	09/23/21	ND	It has a filter.
70	20481500-070DW	20481500-070DW 24A	Main Office Large Conference Room - Drinking Fountain	09/23/21	ND	None.
71	20481500-071SF	20481500-071SF 24A	Main Office Large Conference Room - Sink	09/23/21	2.3	None.
72	20481500-072SF	20481500-072SF 24A	Main Office Kitchenette - Sink	09/23/21	ND	None.
73	20481500-073NS	20481500-073NS 24A	Health Room - Sink	09/23/21	ND	None.
74	20481500-074BF	20481500-074BF 24A	Health Room Restroom - Sink	09/23/21	2.1	None.
75	20481500-075SF	20481500-075SF 24A	Staff Work Room - Sink	09/23/21	1.4	None.
76	20481500-076BF	20481500-076BF 24A	Outside Main Custodial Office Unisex Restroom - Sink	09/23/21	2.3	None.
77	20481500-077DW	20481500-077DW 24A	Room 114 - Drinking Fountain	09/23/21	0.8	None.
78	20481500-078CF	20481500-078CF 24A	Room 114 - Sink	09/23/21	3.4	None.
79	20481500-079BF	20481500-079BF 24A	Room 114 Unisex Restroom - Sink	09/23/21	0.8	None.
80	20481500-080DW	20481500-080DW 24A	Room 113 - Drinking Fountain	09/23/21	ND	None.
81	20481500-081CF	20481500-081CF 24A	Room 113 - Sink	09/23/21	1.6	None.
82	20481500-082DW	20481500-082DW 24A	Room 112 - Drinking Fountain	09/23/21	ND	None.
83	20481500-083CF	20481500-083CF 24A	Room 112 - Sink	09/23/21	1.1	None.
84	20481500-084BF	20481500-084BF 24A	Across From Room 111 Men's Restroom - Left Sink (1)	09/23/21	2.1	None.
85	20481500-085BF	20481500-085BF 24A	Across From Room 111 Men's Restroom - Sink (2)	09/23/21	4.5	None.
86	20481500-086BF	20481500-086BF 24A	Across From Room 111 Men's Restroom - Sink (3)	09/23/21	1.7	None.
87	20481500-087BF	20481500-087BF 24A	Across From Room 111 Men's Restroom - Right Sink (4)	09/23/21	1.4	None.
88	20481500-088BF	20481500-088BF 24A	Across From Room 111 Women's Restroom - Left Sink (1)	09/23/21	1.6	None.
89	20481500-089BF	20481500-089BF 24A	Across From Room 111 Women's Restroom - Sink (2)	09/23/21	1.4	None.
90	20481500-090BF	20481500-090BF 24A	Across From Room 111 Women's Restroom - Sink (3)	09/23/21	4.5	None.
91	20481500-091BF	20481500-091BF 24A	Across From Room 111 Women's Restroom - Right Sink (4)	09/23/21	3.1	None.
92	20481500-092DW	20481500-092DW 24A	Room 111 - Drinking Fountain	09/23/21	1.1	None.
93	20481500-093CF	20481500-093CF 24A	Room 111 - Sink	09/23/21	1.0	None.
94	20481500-094DW	20481500-094DW 24A	Band Room Storage Room 106A - Drinking Fountain	09/23/21	1.0	None.
95	20481500-095CF	20481500-095CF 24A	Band Room Storage Room 106A - Sink	09/23/21	0.9	None.
96	20481500-096DW	20481500-096DW 24A	Room 110 - Drinking Fountain	09/23/21	ND	None.
N/A	20481500-189CF	N/A	Room 110 (Science) - Sink (Left Fixture)	05/15/19	2.4	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	20481500-190CF	N/A	Room 110 (Science) - Sink (Right Fixture)	05/15/19	1.7	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	N/A	N/A	Room 110 - Eye Wash (Attached To Drinking Fountain)	N/A	N/A	None.
97	20481500-097DW	20481500-097DW 24A	Outside Room 221 - Drinking Fountain	09/23/21	1.0	None.
98	20481500-098DW	20481500-098DW 24A	Room 223 (Ceramics) - Drinking Fountain (North - Island)	09/23/21	ND	None.
99 A	20481500-099CF	20481500-099CF 24A	Room 223 (Ceramics) - Sink (North - Island)	09/23/21	2.5	None.
100 B	20481500-100CF	20481500-100CF 24A	Room 223 (Ceramics) - Sink (South - Island)	09/23/21	1.3	None.
101 C	20481500-101CF	20481500-101CF 24A	Room 223 (Ceramics) - Sink (On East Wall - North)	09/23/21	0.6	None.
102 D	20481500-102CF	20481500-102CF 24A	Room 223 (Ceramics) - Sink (On East Wall - South)	09/23/21	ND	None.
N/A A	20481500-191CF	N/A	Room 224 (Science) - Sink (Hand Wash - North Wall)	05/15/19	0.7	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A B	20481500-192CF	N/A	Room 224 (Science) - Sink (On East Wall - Left)	05/15/19	0.8	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A C	20481500-193CF	N/A	Room 224 (Science) - Sink (On East Wall - Center)	05/15/19	1.6	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A D	20481500-194CF	N/A	Room 224 (Science) - Sink (On East Wall - Right)	05/15/19	2.2	"Non-Potable Water" Sign Installed 3 Dec 2019.

103	20481500-103DW	20481500-103DW 24A	Room 224 - Drinking Fountain (On East Wall - Left)	09/23/21	ND	None.
104	20481500-104BF	20481500-104BF 24A	Outside Room 224 Women's Restroom - Sink (Left)	09/23/21	1.8	None.
105	20481500-105BF	20481500-105BF 24A	Outside Room 224 Women's Restroom - Sink (Right)	09/23/21	2.3	None.
106	20481500-106BF	20481500-106BF 24A	Outside Room 224 Women's Restroom - Sink (Center)	09/23/21	4.1	None.
107	20481500-107BF	20481500-107BF 24A	Outside Room 224 Men's Restroom - Sink (Left)	09/23/21	1.9	None.
108	20481500-108BF	20481500-108BF 24A	Outside Room 224 Men's Restroom - Sink (Right)	09/23/21	5.7	None.
109	20481500-109BF	20481500-109BF 24A	Outside Room 224 Men's Restroom - Sink (Center)	09/23/21	5.1	None.
110	20481500-110DW	20481500-110DW 24A	Room 220 B - Drinking Fountain	09/23/21	1.0	None.
111	20481500-111CF	20481500-111CF 24A	Room 220 B - Sink	09/23/21	2.2	None.
112	20481500-112BF	20481500-112BF 24A	Room 220 B Unisex Restroom - Sink	09/23/21	3.0	None.
113	20481500-113DW	20481500-113DW 24A	Room 220 A - Drinking Fountain	09/23/21	ND	None.
114	20481500-114CF	20481500-114CF 24A	Room 220 A - Sink	09/23/21	3.0	None.
115	20481500-115DW	20481500-115DW 24A	Room 225 - Drinking Fountain	09/23/21	0.7	None.
116	20481500-116CF	20481500-116CF 24A	Room 225 - Sink	09/23/21	2.6	None.
117	20481500-117DW	20481500-117DW 24A	Room 226 - Drinking Fountain	09/23/21	ND	None.
118	20481500-118CF	20481500-118CF 24A	Room 226 - Sink	09/23/21	1.7	None.
119	20481500-119DW	20481500-119DW 24A	Room 227 - Drinking Fountain	09/23/21	0.6	None.
120	20481500-120CF	20481500-120CF 24A	Room 227 - Sink	09/23/21	1.9	None.
121	20481500-121DW	20481500-121DW 24A	Room 217 - Drinking Fountain	09/23/21	ND	None.
122	20481500-122CF	20481500-122CF 24A	Room 217 - Sink	09/23/21	1.3	None.
123	20481500-123DW	20481500-123DW 24A	Room 218 - Drinking Fountain	09/23/21	1.2	None.
124	20481500-124CF	20481500-124CF 24A	Room 218 - Sink	09/23/21	2.4	None.
125	20481500-125DW	20481500-125DW 24A	Room 216 - Drinking Fountain	09/23/21	0.7	None.
126	20481500-126CF	20481500-126CF 24A	Room 216 - Sink	09/23/21	0.9	None.
127	A 20481500-127CF	20481500-127CF 24A	Room 215 (Culinary) - North East Sink (A)	09/23/21	3.6	None.
128	B 20481500-128DW	20481500-128DW 24A	Room 215 (Culinary) - North West Drinking Fountain (B)	09/23/21	0.7	None.
129	B 20481500-129CF	20481500-129CF 24A	Room 215 (Culinary) - North West Sink (B)	09/23/21	1.6	None.
130	C 20481500-130CF	20481500-130CF 24A	Room 215 (Culinary) - Sink (C)	09/23/21	1.4	None.
131	D 20481500-131CF	20481500-131CF 24A	Room 215 (Culinary) - Sink (D)	09/23/21	5.3	None.
132	E 20481500-132CF	20481500-132CF 24A	Room 215 (Culinary) - Sink (E)	09/23/21	1.9	None.
133	F 20481500-133CF	20481500-133CF 24A	Room 215 (Culinary) - South West Sink (F)	09/23/21	1.4	None.
134	G 20481500-134CF	20481500-134CF 24A	Room 215 (Culinary) - South East Sink (G)	09/23/21	1.6	None.
135	H 20481500-135CF	20481500-135CF 24A	Room 215 (Culinary) - Sink (Utility In Storage Room)	09/23/21	14.5	None.
136	20481500-136DW	20481500-136DW 24A	Room 229 - Drinking Fountain	09/23/21	0.7	None.
137	20481500-137CF	20481500-137CF 24A	Room 229 - Sink	09/23/21	1.9	None.
138	20481500-138DW	20481500-138DW 24A	Room 230 - Drinking Fountain (North)	09/23/21	0.7	None.
139	20481500-139CF	20481500-139CF 24A	Room 230 - Sink (North)	09/23/21	5.1	None.
140	20481500-140DW	20481500-140DW 24A	Room 230 - Drinking Fountain (South)	09/23/21	ND	None.
141	20481500-141CF	20481500-141CF 24A	Room 230 - Sink (South)	09/23/21	2.0	None.
142	20481500-142BF	20481500-142BF 24A	Across From Room 230 Men's Restroom - Sink (Left)	09/23/21	0.5	None.
143	20481500-143BF	20481500-143BF 24A	Across From Room 230 Men's Restroom - Sink (Center)	09/23/21	1.9	None.
144	20481500-144BF	20481500-144BF 24A	Across From Room 230 Men's Restroom - Sink (Right)	09/23/21	2.7	None.
145	20481500-145BF	20481500-145BF 24A	Across From Room 230 Women's Restroom - Sink (Left)	09/23/21	0.7	None.
146	20481500-146BF	20481500-146BF 24A	Across From Room 230 Women's Restroom - Sink (Center)	09/23/21	3.3	None.
147	20481500-147BF	20481500-147BF 24A	Across From Room 230 Women's Restroom - Sink (Right)	09/23/21	3.7	None.
148	20481500-148DW	20481500-148DW 24A	In Hallway Across From Room 230 - Drinking Fountain	09/23/21	ND	None.
149	A 20481500-149DW	20481500-149DW 24A	Room 231 (Science) - Drinking Fountain (Left - West Wall)	09/23/21	8.1	None.
N/A	A 20481500-195CF	N/A	Room 231 (Science) - Sink (Left - West Wall)	05/15/19	3.0	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	B 20481500-196CF	N/A	Room 231 (Science) - Sink (Right - West Wall)	05/15/19	1.9	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	N/A	N/A	Room 231 (Science) - Eye Wash	N/A	N/A	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	C 20481500-197CF	N/A	Room 231 (Science) - Sink (Left - North Wall)	05/15/19	2.3	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	D 20481500-198CF	N/A	Room 231 (Science) - Sink (Right - North Wall)	05/15/19	2.6	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	E 20481500-199CF	N/A	Room 231 (Science) - Sink (Left - East Wall)	05/15/19	1.6	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	F 20481500-200CF	N/A	Room 231 (Science) - Sink (Center - East Wall)	05/15/19	2.1	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	G 20481500-201CF	N/A	Room 231 (Science) - Sink (Right - East Wall)	05/15/19	1.8	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	H 20481500-202CF	N/A	Room 231 (Science) - Sink (Island)	05/15/19	54.6	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	I 20481500-203CF	N/A	Room 231/232 Storage Room (Science) - Sink	05/15/19	0.8	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	A 20481500-204CF	N/A	Room 232 (Science) - Sink (Right - West Wall)	05/15/19	0.8	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	N/A	N/A	Room 232 (Science) - Eye Wash	N/A	N/A	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	B 20481500-205CF	N/A	Room 232 (Science) - Sink (Left - West Wall)	05/15/19	0.8	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	C 20481500-206CF	N/A	Room 232 (Science) - Sink (Right - South Wall)	05/15/19	3.1	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	D 20481500-207CF	N/A	Room 232 (Science) - Sink (Left - South Wall)	05/15/19	0.8	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	E 20481500-208CF	N/A	Room 232 (Science) - Sink (Right - East Wall)	05/15/19	2.9	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	F 20481500-209CF	N/A	Room 232 (Science) - Sink (Center) - East Wall)	05/15/19	1.5	"Non-Potable Water" Sign Installed 24 July 2019.

N/A	20481500-210CF	N/A	Room 232 (Science) - Sink (Left - East Wall)	05/15/19	0.6	"Non-Potable Water" Sign Installed 24 July 2019.
N/A	20481500-211CF	N/A	Room 232 (Science) - Sink (Island)	05/15/19	34.0	"Non-Potable Water" Sign Installed 24 July 2019.
150	20481500-150DW	20481500-150DW24A	Room 232 (Science) - Drinking Fountain (Right - West Wall)	09/23/21	0.9	None.
151	20481500-151DW	20481500-151DW24A	Room 200 - Drinking Fountain	09/23/21	0.7	None.
152	20481500-152CF	20481500-152CF24A	Room 200 - Sink	09/23/21	2.2	None.
153	20481500-153CF	20481500-153CF24A	Room 202 (Science) - Sink (Left - North Wall)	09/23/21	1.2	"Non-Potable Water" Sign Installed11/22/21.
N/A	N/A	N/A	Room 202 - Eye Wash	N/A	N/A	Water should not be consumed from the eye wash.
154	20481500-154DW	20481500-154DW24A	Room 202 (Science) - Drinking Fountain (Center - North Wall)	09/23/21	1.4	
155	20481500-155CF	20481500-155CF24A	Room 202 (Science) - Sink (Center - North Wall)	09/23/21	1.0	"Non-Potable Water" Sign Installed11/22/21.
156	20481500-156CF	20481500-156CF24A	Room 202 (Science) - Sink (Island)	09/23/21	758.0	Mike Medel Removed this fixture.
157	20481500-157CF	20481500-157CF24A	Room 202 (Science) - Sink (Right - North Wall)	09/23/21	2.1	"Non-Potable Water" Sign Installed11/22/21.
158	20481500-158SF	20481500-158SF24A	Room 202/204 (Science) - Storage Room - Sink	09/23/21	2.6	
159	20481500-159CF	20481500-159CF24A	Room 204 (Science) - Sink (Left - North Wall)	09/23/21	1.3	"Non-Potable Water" Sign Installed11/22/21.
160	20481500-160CF	20481500-160CF24A	Room 204 (Science) - Sink (Center - North Wall)	09/23/21	1.2	"Non-Potable Water" Sign Installed11/22/21.
N/A	N/A	N/A	Room 204 - Eye Wash	N/A	N/A	Water should not be consumed from the eye wash.
161	20481500-161DW	20481500-161DW24A	Room 204 (Science) - Drinking Fountain (Right - North Wall)	09/23/21	0.9	
162	20481500-162CF	20481500-162CF24A	Room 204 (Science) - Sink (Right - North Wall)	09/23/21	ND	"Non-Potable Water" Sign Installed11/22/21.
163	20481500-163CF	20481500-163CF24A	Room 204 (Science) - Sink (Island)	09/23/21	2.6	"Non-Potable Water" Sign Installed11/22/21.
164	20481500-164DW	20481500-164DW24A	Room 201 - Drinking Fountain	09/23/21	0.5	None.
165	20481500-165CF	20481500-165CF24A	Room 201 - Sink	09/23/21	2.6	None.
166	20481500-166DW	20481500-166DW24A	Room 203 - Drinking Fountain	09/23/21	ND	None.
167	20481500-167CF	20481500-167CF24A	Room 203 - Sink	09/23/21	3.3	None.
168	20481500-168DW	20481500-168DW24A	Room 205 - Drinking Fountain	09/23/21	ND	None.
169	20481500-169CF	20481500-169CF24A	Room 205 - Sink	09/23/21	1.9	None.
170	20481500-170DW	20481500-170DW24A	Room 206 - Drinking Fountain	09/23/21	1.4	None.
171	20481500-171CF	20481500-171CF24A	Room 206 - Sink	09/23/21	1.6	None.
172	20481500-172DW	20481500-172DW24A	Room 207 - Drinking Fountain	09/23/21	1.0	None.
173	20481500-173CF	20481500-173CF24A	Room 207 - Sink	09/23/21	1.7	None.
174	20481500-174DW	20481500-174DW24A	Room 208 - Drinking Fountain	09/23/21	0.8	None.
175	20481500-175CF	20481500-175CF24A	Room 208 - Sink	09/23/21	1.7	None.
176	20481500-176DW	20481500-176DW24A	Room 209 - Drinking Fountain	09/23/21	0.9	None.
177	20481500-177CF	20481500-177CF24A	Room 209 - Sink	09/23/21	1.4	None.
178	20481500-178DW	20481500-178DW24A	Room 211 - Drinking Fountain (Right - West Wall)	09/23/21	7.5	None.
N/A	20481500-211CF	N/A	Room 211 (Science) - Sink (Left - East Wall)	05/15/19	1.7	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	20481500-212CF	N/A	Room 211(Science) - Sink (Center - East Wall)	05/15/19	3.2	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	20481500-213CF	N/A	Room 211 (Science) - Sink (Right - East Wall)	05/15/19	3.0	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	20481500-214CF	N/A	Room 211 (Science) - Sink (Left - West Wall)	05/15/19	2.6	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	N/A	N/A	Room 211 - Eye Wash	N/A	N/A	Water should not be consumed from the eye wash.
N/A	20481500-215CF	N/A	Room 211 (Science) - Sink (Right - West Wall)	05/15/19	1.9	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	N/A	N/A	Room 211 (Science) - Sink (Island)	N/A	N/A	This sink is not operational.
N/A	20481500-216CF	N/A	Room 211/213 Storage Room (Science) - Sink	05/15/19	1.9	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	20481500-217CF	N/A	Room 213 (Science) - Sink (Left - East Wall)	05/15/19	2.0	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	20481500-218CF	N/A	Room 213 (Science) - Sink (Center - East Wall)	05/15/19	1.2	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	20481500-219CF	N/A	Room 213 (Science) - Sink (Right - East Wall)	05/15/19	1.8	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	20481500-220CF	N/A	Room 213 (Science) - Sink (Left - West Wall)	05/15/19	0.7	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	N/A	N/A	Room 213 - Eye Wash	N/A	N/A	Water should not be consumed from the eye wash.
N/A	20481500-221CF	N/A	Room 213 (Science) - Sink (Right - West Wall)	05/15/19	1.2	"Non-Potable Water" Sign Installed 3 Dec 2019.
N/A	20481500-222CF	N/A	Room 213 (Science) - Sink (Island)	05/15/19	1.1	"Non-Potable Water" Sign Installed 3 Dec 2019.
179	20481500-179DW	20481500-179DW24A	Room 213 - Drinking Fountain (Left - West Wall)	08/02/24	ND	None.
180	20481500-180DW	20481500-180DW24A	Room 210 - Drinking Fountain	09/23/21	7.6	None.
181	20481500-181CF	20481500-181CF24A	Room 210 - Sink	09/23/21	1.6	None.
182	20481500-182DW	20481500-182DW24A	Room 212 - Drinking Fountain	09/23/21	1.0	None.
183	20481500-183CF	20481500-183CF24A	Room 212 - Sink	09/23/21	1.2	None.
184	20481500-184DW	20481500-184DW24A	Room 214 - Drinking Fountain	09/23/21	0.5	None.
185	20481500-185CF	20481500-185CF24A	Room 214 - Sink	09/23/21	2.8	None.
Lead Tests - McLoughlin Middle School - Athletic Equipment Storage Building - # 20481501						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20481501-001DW	20481501-001DW24A	Outside Athletic Storage Building - Drinking Fountain (Left)	09/23/21	0.8	None.
2	20481501-002DW	20481501-002DW24A	Outside Athletic Storage Building - Drinking Fountain (Right)	09/23/21	0.6	None.
3	20481501-003BF	20481501-003BF24A	Outside Athletic Storage Building Men's Restroom - Sink	09/23/21	1.1	None.
4	20481501-004BF	20481501-004BF24A	Outside Athletic Storage Building Women's Restroom - Sink	09/23/21	1.5	None.
5	20481501-005OS	20481501-005OS24A	Outside Athletic Storage Building - Water Horse	09/23/21	2.7	None.

*None Detected (ND) = 0.515 Or Less PPB

= Fixture Where Water Has The Potential of Being Consumed (All of These Will Be Tested When Testing The Whole School)

- *ODE's required action level is 15 parts per billion (PPB)
- *The E.P.A.'s recommended action level for lead in schools is 20 PPB. Oregon's action level for schools changed to 15 PPB in 2019 in accordance with OAR 333-061-0400. In 2021, ODE changed the unit of measurement for reporting to parts per billion (PPB).
- *The E.P.A. action level for copper is 1.30
- *Lead test results will be posted on the MSD/Facilities website within 5 days minus the school map for security purposes.