



ADDENDUM 2

November 27, 2024

PROJECT: Bid #2024/25-02 KITCHEN MAINTENANCE REPAIRS

PROJECT LOCATIONS:

ANDERSON ELEMENTARY SCHOOL
8902 Hewitt Place
Garden Grove, CA 92844

DEMILLE ELEMENTARY SCHOOL
15400 Van Buren Street
Midway City, CA 92655

EASTWOOD ELEMENTARY SCHOOL
1352 University Street
Westminster, CA 92683

LAND EARLY LEARNING CENTER
15151 Temple Street
Westminster, CA 92683

WEBBER ELEMENTARY SCHOOL
14142 Hoover Street
Westminster, CA 92683

AND

***BID ALTERNATE FOR KITCHEN MAINTENANCE REPAIRS
(3 LOCATIONS)***

AT

FINLEY ELEMENTARY SCHOOL
13521 Edwards Street
Westminster, CA 92683

SCHMITT ELEMENTARY SCHOOL
7200 Trask Avenue
Westminster, CA 92683

SEQUOIA ELEMENTARY SCHOOL
5900 Iroquois Road
Westminster, CA 92683

Kitchen Maintenance Repairs - Bid No. 2024/25-02

This Addendum forms a part of the Contract Documents. It modifies the original Project Manual and Drawings, as well as any Addendum previously issued, as noted below. Bidders are required to acknowledge receipt of this Addendum in the space provided in the proposal form. Failure to acknowledge receipt of each addendum may subject bidder to disqualification.

Item No. 1:

RFI #2: Substitution Request

Question: Can "Westcoat - Temper-crete RTB" be substituted for "Key Resin Company - Key Quartz b-125" for the epoxy floors.

Answer: Yes, Westcoat -Tempercrete RTB is an acceptable substitution.

Item No. 2:

Bid Form was updated and replaced in its entirety to reflect correct Bid number as 2024/25-02. Was previously incorrectly listed at 2024/25-01 in the original bid form.