

Vista Unified School District – Mission Vista HS Theater Modernization  
ADDENDUM No. 2

November 27, 2024

---

**The following is issued to supplement or revise the Contract Documents. The revisions to the documents are described below. Unless specifically changed by this addendum, the remainder of the drawings, documents, specifications, and bid date/time shall remain in effect as originally issued.**

**BIDDER QUESTIONS / REQUESTS FOR INFORMATION:**

**Mission Vista High School**

- 1) 1.11 D. QUALIFICATIONS shows Lighting Control Contractor to be Licensed as a C7. Please confirm that both C7 & C10 are acceptable for the Lighting Controls and AV contractors. The C10 encompasses the C7 license and is the more stringent.

**RESPONSE: Per specification 26.09.23 section 1.11 D outlines the type of license needed for the project.**

- 2) Per job walk evaluation, please confirm all exposed conduits / LV pathways installed down walls and in ceilings are to be painted black?

**RESPONSE: All new, exposed conduits, pathways, and cable management must be black or painted black.**

- 3) According to the BOM provided with bid documents, it appears the (2) existing rack mounted lighting processors are not being replaced. Please advise? Note: If processors are replaced with new, it would make it a complete SR3 model rack with factory 5 year warranty.

**RESPONSE: Please refer to Specification 26.09.23, section 1.7, and 1.8.**