



LRC Indoor Testing and Research
140 Iowa Lane, Suite 102
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave
Nags Head, NC

Project #: 24-3284
Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: -

Table 1: Non-Viable Air Samples

Date Collected:	11/14/24	11/14/24	11/14/24	11/14/24	11/14/24
	1	2	3	4	5
Spore Identification	Cafeteria	Gym	Hall at D113	CR D123	Media Center
<i>Cladosporium</i>	53	27	13	13	40
Ascospores	13	13	-	27	-
Basidiospores ²	27	13	27	-	40
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	13	13	13	27
<i>Penicillium/Aspergillus</i> Group ¹	13	13	13	-	13
Hyphal Elements ³	40	-	-	13	13
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	13	-	13	-	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrinium</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	13	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
Torula	-	-	-	-	-
Pithomyces	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	13	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	173	93	80	67	133
Particulate Level	low-moderate	low	low	low	low-moderate
Date Analyzed:	11/22/24	11/22/24	11/22/24	11/22/24	11/22/24

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
140 Iowa Lane, Suite 102
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave
Nags Head, NC

Project #: 24-3284
Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: -

Table 1: Non-Viable Air Samples

Date Collected:	11/14/24	11/14/24	11/14/24	11/14/24	11/14/24
	6	7	8	9	10
Spore Identification	Hall at B153	CR B155	Hall at C122	CR C117	Hall at A121
<i>Cladosporium</i>	93	-	40	-	13
Ascospores	-	-	27	27	-
Basidiospores ²	27	13	27	-	-
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	13	-	-	-	-
<i>Penicillium/Aspergillus</i> Group ¹	13	13	-	-	-
Hyphal Elements ³	27	-	-	-	-
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrinium</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
Torula	-	-	-	-	-
Pithomyces	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	173	27	93	27	13
Particulate Level	low	low	low-moderate	low	low
Date Analyzed:	11/22/24	11/22/24	11/22/24	11/22/24	11/22/24

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
140 Iowa Lane, Suite 102
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave
Nags Head, NC

Project #: 24-3284
Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: -

Table 1: Non-Viable Air Samples

Date Collected:	11/14/24	11/14/24	11/14/24	#REF!	#REF!
	11	12	13	#REF!	#REF!
Spore Identification	CR A120	Hall at B111	Outdoor Air	#REF!	#REF!
<i>Cladosporium</i>	27	67	107	#REF!	#REF!
Ascospores	13	27	253	#REF!	#REF!
Basidiospores ²	-	13	680	#REF!	#REF!
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	27	53	#REF!	#REF!
<i>Penicillium/Aspergillus</i> Group ¹	13	13	107	#REF!	#REF!
Hyphal Elements ³	-	-	13	#REF!	#REF!
<i>Alternaria</i>	-	-	-	#REF!	#REF!
<i>Curvularia</i>	-	-	-	#REF!	#REF!
<i>Epicoccum</i>	-	-	-	#REF!	#REF!
<i>Cercospora</i>	-	-	-	#REF!	#REF!
<i>Arthrinium</i>	-	-	-	#REF!	#REF!
Clear Brown	-	-	-	#REF!	#REF!
Colorless	-	-	-	#REF!	#REF!
<i>Trichocladium</i>	-	-	-	#REF!	#REF!
Unidentified	-	-	-	#REF!	#REF!
<i>Ulocladium</i>	-	-	-	#REF!	#REF!
<i>Torula</i>	-	-	-	#REF!	#REF!
<i>Pithomyces</i>	-	-	-	#REF!	#REF!
Rust ⁵	-	-	-	#REF!	#REF!
<i>Drechslera/Bipolaris</i>	-	-	-	#REF!	#REF!
<i>Tetraploa</i>	-	-	-	#REF!	#REF!
<i>Chaetomium</i>	-	-	-	#REF!	#REF!
<i>Stachybotrys</i>	-	-	-	#REF!	#REF!
	-	-	-	#REF!	#REF!
Total Spores/m³	53	147	1213	#REF!	#REF!
Particulate Level	low	low-moderate	low	#REF!	#REF!
Date Analyzed:	11/22/24	11/22/24	11/22/24	#REF!	#REF!

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

—

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: —

Sample Number: 1

Sample Location: Cafeteria

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low-moderate

Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	4	53	spores/m ³	31%
Ascospores	1	13	spores/m ³	8%
Basidiospores	2	27	spores/m ³	15%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	8%
Hyphal Elements	3	40	spores/m ³	23%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>	1	13	spores/m ³	8%
<i>Epicoecum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrimum</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>	1	13	spores/m ³	8%
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	13	173	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

—

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: —

Sample Number: 2

Sample Location: Gym

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low

Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	29%
Ascospores	1	13	spores/m ³	14%
Basidiospores	1	13	spores/m ³	14%
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	14%
<i>Penicillium</i> / <i>Aspergillus</i> Group	1	13	spores/m ³	14%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoecum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified	1	13	spores/m ³	14%
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera</i> / <i>Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	7	93	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

—

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: —

Sample Number: 3

Sample Location: Hall at D113

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low

Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	17%
Ascospores		-	spores/m ³	-
Basidiospores	2	27	spores/m ³	33%
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	17%
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	17%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>	1	13	spores/m ³	17%
<i>Epicoecum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	6	80	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

—

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: —
IAQ

PO/Claim #: —

Sample Number: 4

Sample Location: CR D123

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low

Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	20%
Ascospores	2	27	spores/m ³	40%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	20%
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements	1	13	spores/m ³	20%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	5	67	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

—

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: —

Sample Number: 5

Sample Location: Media Center

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low-moderate

Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	3	40	spores/m ³	30%
Ascospores		-	spores/m ³	-
Basidiospores	3	40	spores/m ³	30%
Smuts, <i>Periconia</i> , Myxomycetes	2	27	spores/m ³	20%
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	10%
Hyphal Elements	1	13	spores/m ³	10%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	10	133	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

—

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: —

Sample Number: 6

Sample Location: Hall at B153

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low

Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	7	93	spores/m ³	54%
Ascospores		-	spores/m ³	-
Basidiospores	2	27	spores/m ³	15%
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	8%
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	8%
Hyphal Elements	2	27	spores/m ³	15%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoecum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	13	173	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

—

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: — IAQ

PO/Claim #: —

Sample Number: 7

Sample Location: CR B155

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low

Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	50%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	50%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

—

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: —

Sample Number: 8

Sample Location: Hall at C122

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low-moderate

Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	3	40	spores/m ³	43%
Ascospores	2	27	spores/m ³	29%
Basidiospores	2	27	spores/m ³	29%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	7	93	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

—

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: — IAQ

PO/Claim #: —

Sample Number: 9

Sample Location: CR C117

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low

Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores	2	27	spores/m ³	100%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

—

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: —

Sample Number: 10

Sample Location: Hall at A121

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low

Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	100%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	1	13	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

—

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: —

Sample Number: 11

Sample Location: CR A120

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low

Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	50%
Ascospores	1	13	spores/m ³	25%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	25%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoecum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrimum</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	4	53	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

—

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: —

Sample Number: 12

Sample Location: Hall at B111

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low-moderate

Notes:

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	5	67	spores/m ³	45%
Ascospores	2	27	spores/m ³	18%
Basidiospores	1	13	spores/m ³	9%
Smuts, <i>Periconia</i> , Myxomycetes	2	27	spores/m ³	18%
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	9%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	11	147	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.

**Certificate of Laboratory Analysis**

Non-Viable Spore Trap Analysis

Dare County Schools

Ian Adams

3020 S Wrightsville Ave

Nags Head, NC

-

Project #: 24-3284

Project Location: First Flight Elementary

Project Type: IAQ

PO/Claim #: -

Sample Number: 13

Sample Location: Outdoor Air

Date Collected: 11/14/24

Test Requested: Non-viable spore trap analysis

Date Analyzed: 11/22/24

Volume (L): 75

Percentage of Slide Read: 100.0%

Detection Limit: 13.33

Particulate Level: low

Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	8	107	spores/m ³	9%
Ascospores	19	253	spores/m ³	21%
Basidiospores	51	680	spores/m ³	56%
Smuts, <i>Periconia</i> , Myxomycetes	4	53	spores/m ³	4%
<i>Penicillium/Aspergillus</i> Group	8	107	spores/m ³	9%
Hyphal Elements	1	13	spores/m ³	1%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	91	1213	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research

140 Iowa Lane, Suite 102

Cary, NC 27511

(919) 342-4936

Certificate of Laboratory Analysis

Project #: **24-3284**

Report Information:

DETECTION LIMITS (DL) for samples are the minimum number of spores or colonies forming units that can be satisfactorily identified for each sample type.

SPORE TRAP SAMPLES: Calculations based on volume of air sampled & percentage of slide counted, i.e. DL = 1000 L / 75 L if 100% of the slide is counted.

CODE 11: Fungal content and/or particulate level on slide too heavy to identify and enumerate fungal content.

Footnotes:

1. *Penicillium/Aspergillus* group spores are characterized by their small size, round to ovoid shape, being unicellular and usually colorless to lightly pigmented. There are numerous genera of fungi whose spore morphology is similar to that of the *Penicillium/Aspergillus* type. Several common examples would be *Acremonium*, *Paecilomyces*, and *Trichoderma*. Although the majority of spores placed in this group are *Penicillium*, *Aspergillus*, or a combination of both, these are not the only two possibilities.
2. Basidiospores are primarily transported indoors from outdoor sources and rarely grow indoors. A high basidiospore count indoors can be indicative of a wood decay problem or wet soil, and should be verified if and an outdoor source of the spores is not present.
3. Hyphae are the tubular filaments of fungi. Hyphae can fragment and become airborne much like spores and are potentially allergenic.
4. The Smut, *Periconia*, Myxomycete group is a group composed of three different types of organisms whose spores have similar morphologies. Smuts are plant pathogens, *Periconia* is a relatively uncommon mold indoors, and Myxomycetes are not fungi, but slime molds. Although these organisms do not typically proliferate indoors, their spores are potentially allergenic.
5. Rusts are plant pathogens. These fungi do not typically grow indoors unless an infected plant is present. Rust spores are potentially allergenic.

Direct Microscopic Exam Reporting:

We use a 400x-600x magnification microscope.

Reporting Quantification Levels are as follows:

Reporting Level	Quantitative Description
Occasional	1-10 per square inch
Few	11-100 per square inch
Moderate	101-1000 per square inch
Numerous	More than 1,000 per square inch

Submitted By Analyst:

Cathy A. Richmond, BS

11/22/2024