

Lead in Water Testing Results
 South Washington County Schools
Oltman Middle School – 6625 Goodview Ave S, Cottage Grove, MN 55016

On March 8th, 2024 Oltman Middle School’s drinking water was tested for the concentration of lead.

All water sources tested less than our action level of 5 parts-per-billion (ppb), no action will be taken to these water sources at this time.

| LOCATION | SOURCE | RESULT (ppb) |
|--------------------------------------|------------------|---------------------|
| Room 110B | SINK (left) | < 1.00 |
| Room 110B | SINK (right) | 2.44 |
| Room 110B | SPRAYER (left) | 2.75 |
| Room 110B | SPRAYER (right) | 3.43 |
| Hallway, 2 nd floor south | BOTTLE FILLER | < 1.00 |
| Hallway, 2 nd floor south | FOUNTAIN (left) | < 1.00 |
| Hallway, 2 nd floor south | FOUNTAIN (right) | < 1.00 |
| Hallway, 2 nd floor north | BOTTLE FILLER | < 1.00 |
| Hallway, 2 nd floor north | FOUNTAIN (left) | < 1.00 |
| Hallway, 2 nd floor north | FOUNTAIN (right) | < 1.00 |
| Hallway, by M186 | BOTTLE FILLER | < 1.00 |
| Hallway, by M186 | FOUNTAIN (left) | < 1.00 |
| Hallway, by M186 | FOUNTAIN (right) | < 1.00 |
| Hallway, by M166 | BOTTLE FILLER | < 1.00 |
| Hallway, by M166 | FOUNTAIN (left) | < 1.00 |
| Hallway, by M166 | FOUNTAIN (right) | < 1.00 |
| Hallway, by 149 | BOTTLE FILLER | < 1.00 |
| Hallway, by 149 | FOUNTAIN (left) | < 1.00 |
| Hallway, by 149 | FOUNTAIN (right) | < 1.00 |
| Hallway, by 107 | FOUNTAIN (left) | < 1.00 |
| Hallway, by 107 | FOUNTAIN (right) | < 1.00 |
| Cafeteria | BOTTLE FILLER | < 1.00 |
| Cafeteria | FOUNTAIN (left) | < 1.00 |
| Cafeteria | FOUNTAIN (right) | < 1.00 |
| Hallway, by kitchen | BOTTLE FILLER | < 1.00 |
| Hallway, by kitchen | FOUNTAIN (left) | < 1.00 |
| Hallway, by kitchen | FOUNTAIN (right) | < 1.00 |
| Kitchen | SINK | < 1.00 |
| Kitchen | SPRAYER | < 1.00 |
| Nurse’s Office | SINK | < 1.00 |
| Pool | BOTTLE FILLER | < 1.00 |
| Pool | FOUNTAIN (left) | < 1.00 |

| | | |
|----------------|------------------|--------|
| Pool | FOUNTAIN (right) | < 1.00 |
| Staff Dining | SINK | < 1.00 |
| Staff Workroom | SINK | < 1.00 |