

ADDENDUM #3

Date: 12/09/2024

Project: Chiller Replacement Projects at
Fieler and Salk Elementary Schools for the
Merrillville Community School Corporation
6701 Delaware Street
Merrillville, Indiana 46410
Architect's Project #24012

To: Prospective Bidders

This addendum forms a part of the Bid Documents and modifies the original Bid Documents dated 11/05/2024 as noted below. Acknowledge receipt of this addendum in the space on the Bid Form. Failure to do so may subject bidder to disqualification.

GENERAL

1. Per the warranty for the chiller equipment a strainer system will be required. Please provide a strainer system with the chillers and the installation for the system on the existing piping. The location will have to be coordinated in field.

END OF ADDENDUM #3