

Lead in School Drinking Water Report

Robert Frost Elementary School



Date(s) collected: 2024-05-22

Date(s) analyzed: 2024-06-06, 2024-06-11

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389512	Main	Fountain/ Tap Combo	Music Rm 144	1 of 1	Tap	center	49
389514	Main	Fountain/ Tap Combo	Music Rm 144	1 of 1	Water Fountain	right	20
389518	Main	Fountain/ Tap Combo	Rm 131	1 of 1	Tap	center	18
389161	Main	Fountain/ Tap Combo	Rm 125	1 of 1	Tap	center	2
389165	Main	Fountain/ Tap Combo	Rm 124	1 of 1	Tap	center	2
389102	Main	Sink	Rm 215	1 of 1	Tap	center	1
389144	Main	Fountain/ Tap Combo	Rm 120	1 of 1	Tap	center	1
389148	Main	Sink	Nurse	1 of 1	Tap	center	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location Room	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389150	Main	Fountain/ Tap Combo	Rm 204	1 of 1	Tap	center	1
389155	Main	Fountain	South Wing Outside	1 of 1	Water Fountain	center	1
389158	Main	Fountain/ Tap Combo	Rm 208	1 of 1	Tap	center	1
389163	Main	Fountain/ Tap Combo	Rm 125	1 of 1	Water Fountain	right	1
389167	Main	Fountain/ Tap Combo	Rm 124	1 of 1	Water Fountain	right	1
389170	Main	Fountain/ Tap Combo	Rm 209	1 of 1	Tap	center	1
389171	Main	Fountain/ Tap Combo	Rm 123	1 of 1	Tap	center	1
389500	Main	Sink - Multi- Compartment	Kitchen	1 of 2	Tap	left	1
389506	Main	Pot Filler	Kitchen	2 of 2	Tap	center	1
389516	Main	Sink	Library Office	1 of 1	Tap	center	1
389524	Main	Fountain/ Tap Combo	Rm 134	1 of 1	Tap	center	1
389525	Main	Fountain/ Tap Combo	Rm 137	1 of 1	Tap	center	1
389528	Main	Fountain/ Tap Combo	Rm 133	1 of 1	Tap	center	1
389529	Main	Fountain/	Rm 141	1 of 1	Tap	center	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389537	Main	Tap Combo					
389537	Main	Fountain/ Tap Combo	Rm 138	1 of 1	Tap	center	1
389100	Main	Fountain/ Tap Combo	Rm 213	1 of 1	Water Fountain	right	<1
389104	Main	Fountain/ Tap Combo	Rm 214	1 of 1	Tap	center	<1
389106	Main	Fountain/ Tap Combo	Rm 214	1 of 1	Water Fountain	right	<1
389108	Main	Fountain/ Tap Combo	Rm 212	1 of 1	Tap	center	<1
389110	Main	Fountain/ Tap Combo	Rm 212	1 of 1	Water Fountain	right	<1
389140	Main	Fountain/ Tap Combo	Rm 121	1 of 1	Tap	center	<1
389141	Portable 8/9	Fountain/ Tap Combo	P8	1 of 1	Water Fountain	right	<1
389142	Main	Fountain/ Tap Combo	Rm 121	1 of 1	Water Fountain	right	<1
389143	Portable 8/9	Fountain/ Tap Combo	P9	1 of 1	Tap	center	<1
389145	Portable 8/9	Fountain/ Tap Combo	P9	1 of 1	Water Fountain	left	<1
389146	Main	Fountain/ Tap Combo	Rm 120	1 of 1	Water Fountain	right	<1
389147	Portable	Fountain/ Tap Combo	P6	1 of 1	Tap	center	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	6/7	Tap Combo					
389149	Portable 6/7	Fountain/ Tap Combo	P6	1 of 1	Water Fountain	right	<1
389151	Portable 6/7	Fountain/ Tap Combo	P7	1 of 1	Tap	center	<1
389152	Main	Fountain/ Tap Combo	Rm 204	1 of 1	Water Fountain	right	<1
389153	Portable 6/7	Fountain/ Tap Combo	P7	1 of 1	Water Fountain	left	<1
389154	Main	Fountain/ Tap Combo	Rm 207	1 of 1	Tap	center	<1
389156	Main	Fountain/ Tap Combo	Rm 207	1 of 1	Water Fountain	right	<1
389157	Main	Fountain	Teachers Lounge	1 of 1	Water Fountain	center	<1
389159	Main	Sink	Teachers Lounge Kitchen	1 of 1	Tap	center	<1
389160	Main	Fountain/ Tap Combo	Rm 208	1 of 1	Water Fountain	right	<1
389162	Main	Fountain	Between 208 And 210	1 of 2	Water Fountain	left	<1
389164	Main	Fountain	Between 208 And 210	2 of 2	Water Fountain	right	<1
389166	Main	Fountain/ Tap Combo	Rm 210	1 of 1	Tap	center	<1
389168	Main	Fountain/ Tap	Rm 210	1 of 1	Water Fountain	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389169	Main	Combo Fountain	Between Rm 124 And 123	1 of 1	Water Fountain	center	<1
389172	Main	Fountain/ Tap Combo	Rm 209	1 of 1	Water Fountain	right	<1
389173	Main	Fountain/ Tap Combo	Rm 123	1 of 1	Water Fountain	right	<1
389174	Main	Fountain/ Tap Combo	Rm 211	1 of 1	Tap	center	<1
389175	Main	Fountain/ Tap Combo	Rm 122	1 of 1	Tap	center	<1
389176	Main	Fountain/ Tap Combo	Rm 211	1 of 1	Water Fountain	right	<1
389177	Main	Fountain/ Tap Combo	Rm 122	1 of 1	Water Fountain	right	<1
389178	Main	Fountain/ Tap Combo	Rm 213	1 of 1	Tap	center	<1
389179	Main	Fountain	Between 122 And 121	1 of 1	Water Fountain	center	<1
389366	Portable 2/3	Sink	P2	1 of 1	Tap	center	<1
389368	Portable 2/3	Sink	P3	1 of 1	Tap	center	<1
389370	Portable 4/5	Fountain/ Tap Combo	P4	1 of 1	Tap	center	<1
389372	Portable 4/5	Fountain/ Tap Combo	P4	1 of 1	Water Fountain	right	<1
389374	Portable	Fountain/	P5	1 of 1	Tap	center	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	4/5	Tap Combo					
389376	Portable 4/5	Fountain/ Tap Combo	P5	1 of 1	Water Fountain	left	<1
389378	Portable 8/9	Fountain/ Tap Combo	P8	1 of 1	Tap	center	<1
389502	Main	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	right	<1
389504	Main	Sink - Multi-Compartment	Kitchen	1 of 2	Sprayer	right	<1
389508	Main	Fountain with Bottle Filler	Cafeteria Across 144	1 of 1	Water Fountain	center	<1
389510	Main	Fountain with Bottle Filler	Cafeteria Across 144	1 of 1	Water Bottle Filler	center	<1
389520	Main	Fountain/ Tap Combo	Rm 131	1 of 1	Water Fountain	right	<1
389522	Main	Fountain	Between 134 And 136	1 of 1	Water Fountain	center	<1
389526	Main	Fountain/ Tap Combo	Rm 134	1 of 1	Water Fountain	right	<1
389527	Main	Fountain/ Tap Combo	Rm 137	1 of 1	Water Fountain	right	<1
389530	Main	Fountain/ Tap Combo	Rm 133	1 of 1	Water Fountain	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389531	Main	Fountain/ Tap Combo	Rm 141	1 of 1	Water Fountain	right	<1
389532	Main	Fountain/ Tap Combo	Rm 136	1 of 1	Tap	center	<1
389533	Main	Fountain/ Tap Combo	Rm 140	1 of 1	Tap	center	<1
389534	Main	Fountain/ Tap Combo	Rm 136	1 of 1	Water Fountain	right	<1
389535	Main	Fountain/ Tap Combo	Rm 140	1 of 1	Water Fountain	right	<1
389536	Main	Fountain/ Tap Combo	Rm 135	1 of 1	Tap	center	<1
389538	Main	Fountain/ Tap Combo	Rm 135	1 of 1	Water Fountain	right	<1
389539	Main	Fountain/ Tap Combo	Rm 138	1 of 1	Water Fountain	right	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**