

Lead in School Drinking Water Report

Maya Angelou Elementary



Date(s) collected: 2024-03-27, 2024-03-28

Date(s) analyzed: 2024-04-12

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
370856	Main Building	Fountain/Tap Combo	Rm 152	1 of 1	Tap	2
389046	Main Building	Fountain/Tap Combo	Rm 207	1 of 1	Tap	2
389080	Main Building	Fountain/Tap Combo	Rm 166	1 of 1	Water Fountain	2
389090	Main Building	Fountain/Tap Combo	Rm 170	1 of 1	Tap	1
370826	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	<1
370828	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	<1
370830	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	<1
370832	Main Building	Pot Filler	Kitchen	2 of 2	Tap	<1
370834	Main	Pot Filler	Kitchen	2 of 2	Sprayer	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
	Building					
370836	Main Building	Fountain	Gym	1 of 1	Water Fountain	<1
370838	Main Building	Fountain with Bottle Filler	Hallway Across Music Rm	1 of 1	Water Fountain	<1
370840	Main Building	Fountain with Bottle Filler	Hallways Across Music Rm	1 of 1	Water Bottle Filler	<1
370842	Main Building	Fountain/Tap Combo	Music Rm 186	1 of 1	Tap	<1
370844	Main Building	Fountain/Tap Combo	Music Rm 186	1 of 1	Water Fountain	<1
370846	Main Building	Sink	Staff Lounge Rm 122	1 of 1	Tap	<1
370848	Main Building	Fountain with Bottle Filler	Staff Restroom Fountain	1 of 1	Water Fountain	<1
370850	Main Building	Fountain with Bottle Filler	Staff Restroom Fountain	1 of 1	Water Bottle Filler	<1
370852	Main Building	Sink	Health Room	1 of 1	Tap	<1
370854	Main Building	Sink	Library	1 of 1	Tap	<1
388941	Main Building	Fountain/Tap Combo	Rm 211	1 of 1	Water Fountain	<1
388943	Main Building	Fountain/Tap Combo	Rm 213	1 of 1	Tap	<1
388945	Main Building	Fountain/Tap Combo	Rm 213	1 of 1	Water Fountain	<1
388947	Main Building	Fountain/Tap Combo	Rm 215	1 of 1	Tap	<1
388949	Main Building	Fountain/Tap Combo	Rm 215	1 of 1	Water Fountain	<1
388951	Main Building	Fountain/Tap Combo	Rm217	1 of 1	Tap	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
388953	Main Building	Fountain/Tap Combo	Rm 217	1 of 1	Water Fountain	<1
388955	Main Building	Sink	Staff 214	1 of 1	Tap	<1
388957	Main Building	Fountain/Tap Combo	Rm 212	1 of 1	Tap	<1
388959	Main Building	Fountain/Tap Combo	Rm 212	1 of 1	Water Fountain	<1
388961	Main Building	Fountain/Tap Combo	Rm 210	1 of 1	Tap	<1
388963	Main Building	Fountain/Tap Combo	Rm 210	1 of 1	Water Fountain	<1
388965	Main Building	Fountain/Tap Combo	Rm 208	1 of 1	Tap	<1
388967	Main Building	Fountain/Tap Combo	Rm 208	1 of 1	Water Fountain	<1
388969	Main Building	Fountain/Tap Combo	Rm 206	1 of 1	Tap	<1
388971	Main Building	Fountain/Tap Combo	Rm 206	1 of 1	Water Fountain	<1
388975	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Sprayer	<1
389020	Main Building	Fountain/Tap Combo	Rm 121	1 of 1	Tap	<1
389021	Portable 5/6	Fountain/Tap Combo	Portable 5	1 of 1	Tap	<1
389022	Main Building	Fountain/Tap Combo	Rm 121	1 of 1	Water Fountain	<1
389023	Portable 5/6	Fountain/Tap Combo	Portable 5	1 of 1	Water Fountain	<1
389024	Main Building	Fountain/Tap Combo	Rm 123	1 of 1	Tap	<1
389025	Portable 5/6	Fountain/Tap Combo	Portable 6	1 of 1	Tap	<1
389026	Main Building	Fountain/Tap Combo	Rm 123	1 of 1	Water Fountain	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
389027	Portable 5/6	Fountain/Tap Combo	Portable 6	1 of 1	Water Fountain	<1
389028	Main Building	Fountain/Tap Combo	Rm 127	1 of 1	Tap	<1
389029	Portable 3/4	Fountain/Tap Combo	Portable 3	1 of 1	Tap	<1
389030	Main Building	Fountain/Tap Combo	Rm 127	1 of 1	Water Fountain	<1
389031	Portable 3/4	Fountain/Tap Combo	Portable 3	1 of 1	Water Fountain	<1
389032	Main Building	Fountain/Tap Combo	Rm 138	1 of 1	Tap	<1
389033	Portable 3/4	Fountain/Tap Combo	Portable 4	1 of 1	Tap	<1
389034	Main Building	Fountain/Tap Combo	Rm 138	1 of 1	Water Fountain	<1
389035	Portable 3/4	Fountain/Tap Combo	Portable 4	1 of 1	Water Fountain	<1
389036	Main Building	Fountain	Outside Rm 138	1 of 1	Water Fountain	<1
389037	Portable 1/2	Fountain/Tap Combo	Portable 1	1 of 1	Tap	<1
389038	Main Building	Fountain/Tap Combo	Rm 134	1 of 1	Tap	<1
389039	Portable 1/2	Fountain/Tap Combo	Portable 1	1 of 1	Water Fountain	<1
389040	Main Building	Fountain/Tap Combo	Rm 134	1 of 1	Water Fountain	<1
389041	Portable 1/2	Fountain/Tap Combo	Portable 2	1 of 1	Tap	<1
389042	Main Building	Fountain/Tap Combo	Rm 201	1 of 1	Tap	<1
389043	Portable 1/2	Fountain/Tap Combo	Portable 2	1 of 1	Water Fountain	<1
389044	Main Building	Fountain/Tap Combo	Rm 201	1 of 1	Water Fountain	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
389045	Main Building	Fountain/Tap Combo	Rm 115	1 of 1	Tap	<1
389047	Main Building	Fountain/Tap Combo	Rm 115	1 of 1	Water Fountain	<1
389048	Main Building	Fountain/Tap Combo	Rm 207	1 of 1	Water Fountain	<1
389049	Main Building	Fountain	Between 115 And 117 Fountain	1 of 1	Water Fountain	<1
389050	Main Building	Fountain/Tap Combo	Rm 209	1 of 1	Tap	<1
389051	Main Building	Fountain/Tap Combo	Rm 117	1 of 1	Tap	<1
389052	Main Building	Fountain/Tap Combo	Rm 209	1 of 1	Water Fountain	<1
389053	Main Building	Fountain/Tap Combo	Rm 117	1 of 1	Water Fountain	<1
389054	Main Building	Fountain	Outside 209	1 of 2	Water Fountain	<1
389055	Main Building	Fountain/Tap Combo	Rm 119	1 of 1	Tap	<1
389056	Main Building	Fountain	Outside Rm 211	2 of 2	Water Fountain	<1
389057	Main Building	Fountain/Tap Combo	Rm 119	1 of 1	Water Fountain	<1
389058	Main Building	Fountain/Tap Combo	Rm 211	1 of 1	Tap	<1
389059	Main Building	Fountain	Between 119 And 121 Fountain	1 of 1	Water Fountain	<1
389060	Main Building	Fountain/Tap Combo	Rm 152	1 of 1	Water Fountain	<1
389062	Main Building	Fountain	Hallway Between 155 And 157	1 of 1	Water Fountain	<1
389064	Main Building	Sink	Rm 161 Art Office	1 of 1	Tap	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
389066	Main Building	Fountain/Tap Combo	Rm 160	1 of 1	Tap	<1
389068	Main Building	Fountain/Tap Combo	Rm 160	1 of 1	Water Fountain	<1
389070	Main Building	Fountain/Tap Combo	Rm 162	1 of 1	Tap	<1
389072	Main Building	Fountain/Tap Combo	Rm 162	1 of 1	Water Fountain	<1
389074	Main Building	Fountain/Tap Combo	Rm 164	1 of 1	Tap	<1
389076	Main Building	Fountain/Tap Combo	Rm 164	1 of 1	Water Fountain	<1
389078	Main Building	Fountain/Tap Combo	Rm 166	1 of 1	Tap	<1
389082	Main Building	Fountain/Tap Combo	Rm 169	1 of 1	Tap	<1
389084	Main Building	Fountain/Tap Combo	Rm 169	1 of 1	Water Fountain	<1
389086	Main Building	Fountain/Tap Combo	Rm 171	1 of 1	Tap	<1
389088	Main Building	Fountain/Tap Combo	Rm 171	1 of 1	Water Fountain	<1
389091	Main Building	Fountain/Tap Combo	Rm 175	1 of 1	Water Fountain	<1
389092	Main Building	Fountain/Tap Combo	170	1 of 1	Water Fountain	<1
389093	Portable 7/8	Fountain/Tap Combo	Portable 7	1 of 1	Tap	<1
389094	Main Building	Fountain/Tap Combo	Rm 168	1 of 1	Tap	<1
389095	Portable 7/8	Fountain/Tap Combo	Portable 7	1 of 1	Water Fountain	<1
389096	Main Building	Fountain/Tap Combo	Rm 168	1 of 1	Water Fountain	<1
389097	Portable 7/8	Fountain/Tap Combo	Portable 8	1 of 1	Tap	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
389098	Main Building	Fountain/Tap Combo	Rm 175	1 of 1	Tap	<1
389099	Portable 7/8	Fountain/Tap Combo	Portable 8	1 of 1	Water Fountain	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**