

J.C. Broderick & Associates, Inc.

Environmental/Construction Consulting & Testing



January 31, 2023

Mr. Severino Fasulo
Syosset Central School District
99 Pell Lane
Syosset, New York 11791

**Re: Indoor Radon Sampling and Methane Monitoring
Baylis Elementary School
580 Woodbury Road
Plainview, New York 11803
Sampling Dates: January 10-13, 2023**

JCB#: 22-52916

Dear Mr. Fasulo:

J.C. Broderick and Associates, Inc. (JCB) was retained to perform indoor radon sampling and methane monitoring within the above referenced school building. The existing active sub-slab depressurization system (SSDS) for radon mitigation was turned off 48-hours prior to the start and throughout the duration of the sampling.

The radon sampling was performed by experienced JCB representatives following the EPA Radon Measurement in Schools (EPA 402-R-92-014) guidance document. Sampling was performed utilizing Short-Term test devices which were placed in frequently occupied rooms in contact with the ground.

Radon Laboratory Analytical Summary

The short-term Radon in Air sampling was performed utilizing laboratory supplied test kits, assigned individual identification numbers and were secured. Chain of Custody documents were prepared, and the samples were then delivered to an independent New York State Department of Health (NYSDOH) Environmental Laboratory Approval Program (ELAP) certified laboratory for analysis of Radon in Air.

EMSL Analytical Inc. (EMSL) of Cinnaminson, New Jersey provided laboratory analytical services. Copies of EMSL's NYSDOH certifications are available upon request.

The laboratory analytical results for the Radon in Air samples were reviewed and compared to the United States Environmental Protection Agency (EPA) recommended action level of 4.0 pCi/L as reported in Radon Measurement in Schools Revised Edition (EPA 402-R-92-014), dated July 1993.

The monitoring for methane gas was also performed during this period utilizing a Landtec GEM 5000 methane detecting real-time monitor. The monitor recorded the percentage of methane along with carbon dioxide and oxygen every 15-minutes.

The results of the sampling performed revealed the following:

- All radon results were reported below the EPA action level.
- No methane was recorded by the detector.

January 31, 2023
Mr. Severino Fasulo of Syosset CSD
Indoor Radon Sampling and Methane Monitoring
Baylis Elementary School
580 Woodbury Rd., Plainview, NY 11803
JCB#: 22-52916

Please see the attached laboratory reports to be included in the District's Radon Measurement Plan. If there are any questions or if more information is needed, please feel free to contact our office.

Sincerely,
J. C. Broderick & Associates, Inc.

A handwritten signature in black ink, appearing to read "Steven Muller", with a long horizontal flourish extending to the right.

Steven Muller, P.G.
Director, Subsurface Division

Appendix A

Figures



J.C. Broderick & Associates
 Environmental Consulting & Testing
 1775 Expressway Dr. North
 Hauppauge, New York 11788
 Phone: 631.584.5492 Fax: 631.584.5913

JCB #: 12-22347
SYOSSET CENTRAL SCHOOL DISTRICT
 Baylis Elementary School
 580 Woodbury Road, Plainview, NY 11803

Appendix B

Laboratory Analysis Reports



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 382300470
 CustomerID: JCBR50
 CustomerPO:
 ProjectID:

Attn: **Steven Muller**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
 Fax:
 Received: 1/20/2023 10:21 AM
 Analysis Date: 1/21/2023
 Collected: 1/10/2023

Project: **Baylis ES# 22-52916**

Test **Baylis ES# 22-52916**
 Site: **580 Woodbury Road**
Plainview, NY 11803

Test Report: Radon in Air Test Results

Liquid Scintillation ID	Location	Radon Activity (pCi/L)	Start	Stop	Temperature F	Humidity %	Sample Type
524648 382300470-0001	Room # 2005-File cabinet	0.7	1/10/2023 6:42:00 AM	1/13/2023 4:39:00 PM	72.5	33.7	Customer
Sample Notes:							
524528 382300470-0002	Room # 2005-File cabinet	0.9	1/10/2023 6:42:00 AM	1/13/2023 4:39:00 PM	72.5	33.7	Duplicate
Sample Notes: Duplicate's Customer Sample:382300470-0001 Duplicate RPD = 25.0%							
524510 382300470-0003	Room # 2006-Supply cabinet	0.9	1/10/2023 6:42:00 AM	1/13/2023 4:40:00 PM	73.5	31.7	Customer
Sample Notes:							
524636 382300470-0004	Room # 2007-Bookshelf	0.6	1/10/2023 6:43:00 AM	1/13/2023 4:42:00 PM	73.5	31.7	Customer
Sample Notes:							
524699 382300470-0005	Room # 2008-Supply cabinet	0.7	1/10/2023 6:44:00 AM	1/13/2023 4:43:00 PM	72.3	32.6	Customer
Sample Notes:							
524618 382300470-0006	Room # 2008-Supply cabinet	-0.1	1/10/2023 6:44:00 AM	1/13/2023 4:43:00 PM	72.3	32.6	Blank
Sample Notes:							
524634 382300470-0007	Room # 2009-Bookshelf	0.2	1/10/2023 6:44:00 AM	1/13/2023 4:45:00 PM	70.7	31.5	Customer
Sample Notes:							
524529 382300470-0008	Room # 2010-Bookshelf	0.4	1/10/2023 6:45:00 AM	1/13/2023 4:48:00 PM	69.6	33.5	Customer
Sample Notes:							
524627 382300470-0009	Room # 2011-Storage cabinet	0.7	1/10/2023 6:45:00 AM	1/13/2023 4:46:00 PM	71.7	34.6	Customer
Sample Notes:							
524670 382300470-0010	Room # 2012-Supply cabinet	0.7	1/10/2023 6:46:00 AM	1/13/2023 4:51:00 PM	69.6	32.7	Customer
Sample Notes:							



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>

cinnaminsonradonlab@emsl.com

EMSL Order: 382300470

CustomerID: JCBR50

CustomerPO:

ProjectID:

Test Report: Radon in Air Test Results

Liquid Scintillation ID	Location	Radon Activity (pCi/L)	Start	Stop	Temperature F	Humidity %	Sample Type
524651 382300470-0011	Room # 2013-Supply cabinet	0.6	1/10/2023 6:47:00 AM	1/13/2023 4:52:00 PM	70.7	31.5	Customer
Sample Notes:							
524556 382300470-0012	Room # 2015-Bookshelf	0.6	1/10/2023 6:47:00 AM	1/13/2023 4:53:00 PM	72.8	31.7	Customer
Sample Notes:							
524682 382300470-0013	Room # 2020-Bookshelf	0.8	1/10/2023 6:48:00 AM	1/13/2023 4:55:00 PM	73.5	31.3	Customer
Sample Notes:							
524623 382300470-0014	Room # 2021-Bookshelf	0.7	1/10/2023 6:49:00 AM	1/13/2023 4:59:00 PM	74.6	29.8	Customer
Sample Notes:							
524578 382300470-0015	Room # 2022-Control panel	0.7	1/10/2023 6:50:00 AM	1/13/2023 4:57:00 PM	72.8	29.7	Customer
Sample Notes:							
524587 382300470-0016	Room # 2026-File cabinet	0.7	1/10/2023 6:51:00 AM	1/13/2023 5:02:00 PM	71.2	30.6	Customer
Sample Notes:							
524567 382300470-0017	Room # 2026-File cabinet	1.5	1/10/2023 6:51:00 AM	1/13/2023 5:02:00 PM	71.2	30.6	Duplicate
Sample Notes: Duplicate's Customer Sample:382300470-0016 Duplicate RPD >67% Duplicate RPD = 72.7%							
524579 382300470-0018	Room # 2029-Speaker	1	1/10/2023 6:53:00 AM	1/13/2023 5:03:00 PM	71.9	30.6	Customer
Sample Notes:							
524686 382300470-0019	Room # 2029-Speaker	0	1/10/2023 6:53:00 AM	1/13/2023 5:03:00 PM	71.9	30.6	Blank
Sample Notes:							
524621 382300470-0020	Room # 2032-Shelf	1.1	1/10/2023 6:55:00 AM	1/13/2023 5:05:00 PM	73	28.7	Customer
Sample Notes:							
524602 382300470-0021	Room # 2035-Bookshelf	1.1	1/10/2023 6:56:00 AM	1/13/2023 5:06:00 PM	71.9	30.7	Customer
Sample Notes:							
524696 382300470-0022	Room # 2038-Bookshelf	0.7	1/10/2023 6:57:00 AM	1/13/2023 5:08:00 PM	72.5	29.4	Customer
Sample Notes:							
524680 382300470-0023	Room # 2041-Candy machine	0.9	1/10/2023 6:58:00 AM	1/13/2023 5:14:00 PM	75	25.8	Customer
Sample Notes:							

Please visit www.radontestinglab.com



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>

cinnaminsonradonlab@emsl.com

EMSL Order: 382300470

CustomerID: JCBR50

CustomerPO:

ProjectID:

Test Report: Radon in Air Test Results

Liquid Scintillation ID	Location	Radon Activity (pCi/L)	Start	Stop	Temperature F	Humidity %	Sample Type
524566 382300470-0024	Room # 2044-Bookshelf	0.9	1/10/2023 6:59:00 AM	1/13/2023 5:16:00 PM	74.3	29.8	Customer
Sample Notes:							
524615 382300470-0025	Room # 2046-Bookshelf	0.9	1/10/2023 7:00:00 AM	1/13/2023 5:17:00 PM	72.8	29.4	Customer
Sample Notes:							
524538 382300470-0026	Room # 2047-Bookshelf	0.8	1/10/2023 7:01:00 AM	1/13/2023 5:19:00 PM	72.1	29.3	Customer
Sample Notes:							
524691 382300470-0027	Room # 2048-Bookshelf	0.6	1/10/2023 7:02:00 AM	1/13/2023 5:20:00 PM	72.1	27.6	Customer
Sample Notes:							
524664 382300470-0028	Room # 2049-Bookshelf	1	1/10/2023 7:03:00 AM	1/13/2023 5:22:00 PM	72.5	29.4	Customer
Sample Notes:							
524662 382300470-0029	Room # 2049A-Bookshelf	0.6	1/10/2023 7:04:00 AM	1/13/2023 5:23:00 PM	72.5	26.7	Customer
Sample Notes:							
524411 382300470-0030	Room # 2049A-Bookshelf	0.4	1/10/2023 7:04:00 AM	1/13/2023 5:23:00 PM	72.5	26.7	Duplicate
Sample Notes: Duplicate's Customer Sample:382300470-0029 Duplicate RPD = 40.0%							
524659 382300470-0031	Room # 2050-Shelf	0.9	1/10/2023 7:05:00 AM	1/13/2023 5:57:00 PM	73.4	28.9	Customer
Sample Notes:							
524620 382300470-0032	Room # 2053-Desk	0.4	1/10/2023 7:06:00 AM	1/13/2023 5:55:00 PM	73	26.7	Customer
Sample Notes:							
524608 382300470-0033	Room # 2061-Speaker	0.7	1/10/2023 7:07:00 AM	1/13/2023 5:27:00 PM	74.6	25.3	Customer
Sample Notes:							
524609 382300470-0034	Room # 2063-Shelf	0.7	1/10/2023 7:08:00 AM	1/13/2023 5:30:00 PM	72.3	27.6	Customer
Sample Notes:							
524585 382300470-0035	Room # 2065-Speaker	0.5	1/10/2023 7:09:00 AM	1/13/2023 5:31:00 PM	72.6	26.7	Customer
Sample Notes:							
524423 382300470-0036	Room # 2068-Supply cabinet	1	1/10/2023 7:10:00 AM	1/13/2023 5:41:00 PM	73.5	25.7	Customer
Sample Notes:							

Please visit www.radontestinglab.com



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>

cinnaminsonradonlab@emsl.com

EMSL Order: 382300470

CustomerID: JCBR50

CustomerPO:

ProjectID:

Test Report: Radon in Air Test Results

Liquid Scintillation ID	Location	Radon Activity (pCi/L)	Start	Stop	Temperature F	Humidity %	Sample Type
524320 382300470-0037	Room # 2070-Cabinet	0.5	1/10/2023 7:10:00 AM	1/13/2023 5:49:00 PM	72.6	29.8	Customer
Sample Notes:							
524614 382300470-0038	Room # 2071-Cabinet	0.6	1/10/2023 7:11:00 AM	1/13/2023 5:52:00 PM	73.2	27.1	Customer
Sample Notes:							
524463 382300470-0039	Room # 2073-Speaker	0.5	1/10/2023 7:12:00 AM	1/13/2023 5:53:00 PM	73.2	25.7	Customer
Sample Notes:							
524343 382300470-0040	Room # 2077-Shelf	0.5	1/10/2023 7:13:00 AM	1/13/2023 5:25:00 PM	74.1	28.7	Customer
Sample Notes:							
524415 382300470-0041	Room # 2077-Shelf	0.6	1/10/2023 7:13:00 AM	1/13/2023 5:25:00 PM	74.1	28.7	Duplicate
Sample Notes: Duplicate's Customer Sample:382300470-0040					Duplicate RPD = 18.2%		
524622 382300470-0042	Room # 1055-Desk	0.3	1/10/2023 7:14:00 AM	1/13/2023 5:57:00 PM	74.3	28	Customer
Sample Notes:							
524586 382300470-0043	Room # 1055-Desk	0.2	1/10/2023 7:14:00 AM	1/13/2023 5:57:00 PM	74.3	28	Blank
Sample Notes:							
524472 382300470-0044	Room # C-7-Bookshelf	1.5	1/10/2023 7:15:00 AM	1/13/2023 5:44:00 PM	73.5	35.7	Customer
Sample Notes:							
524388 382300470-0045	Room # C-9-Bookshelf	1.1	1/10/2023 7:16:00 AM	1/13/2023 5:46:00 PM	72.6	41.7	Customer
Sample Notes:							
524403 382300470-0046	Room # C-10-Cabinet	1.6	1/10/2023 7:17:00 AM	1/13/2023 5:42:00 PM	73.2	35.8	Customer
Sample Notes:							
524374 382300470-0047	Room # C-12-Speaker	0.8	1/10/2023 7:18:00 AM	1/13/2023 5:44:00 PM	72.8	37.7	Customer
Sample Notes:							
524454 382300470-0048	Room # B-6-Bookshelf	1	1/10/2023 7:21:00 AM	1/13/2023 5:12:00 PM	71.9	36.6	Customer
Sample Notes:							
524316 382300470-0049	Room # B-9-Bookshelf	0.5	1/10/2023 7:22:00 AM	1/13/2023 5:10:00 PM	72.1	33.6	Customer
Sample Notes:							

Report Notes

Please visit www.radontestinglab.com



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>

cinnaminsonradonlab@emsl.com

EMSL Order: 382300470

CustomerID: JCBR50

CustomerPO:

ProjectID:

Test Report: Radon in Air Test Results

Liquid Scintillation ID	Location	Radon Activity (pCi/L)	Start	Stop	Temperature F	Humidity %	Sample Type
-------------------------	----------	------------------------	-------	------	---------------	------------	-------------

The United States Environmental Protection Agency (EPA) has established a radon action level of 4.0pCi/L. EPA recommends mitigation of a structure if the confirmed radon level is equal to or greater than 4.0pCi/L.

The radon tests were performed using liquid scintillation radon detectors and counted on a liquid scintillation counter following EPA Method # 402-R-92-004 testing protocol for Radon in Air testing. EPA recommends retesting every two years.

Please contact EMSL Analytical, Inc. or your State Health Department for further information.

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of Radon in Air.

Analyst(s)

Symone Tibbs (49)

Dominic Gehret, Radiochemistry Laboratory Manager, 10872

In no event shall EMSL be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL and whether EMSL has been informed of the possibility of such damages, arising out of or in connection with EMSL's services thereunder or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. In no event shall EMSL be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereunder. The test results meets all NELAC requirements unless otherwise specified.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ FL RB2034/R2687,IL RNL2008202,IN RTL00935,IA RNLAB10005,KS KS-LB-0005/KS-MS-0482,ME SPC202,MN RL-0005,NE 474/RMB-1083,NJ 03036/MEB92525/MES13910,NY 10872,OH RL39,OK D9952,PA 2573/3393/68-00367,RI RMB-108/RI00179,WV RL000220,NRSB-ARL6006,NRPP

Initial report from 01/26/2023 13:41:56

MTH



**CHAIN OF CUSTODY
RADON LABORATORY SERVICES**
(COMMERCIAL USE)

EMSL ANALYTICAL, INC.
200 ROUTE 130 NORTH
CINNAMINSON, NJ 08077
PHONE: 800-220-3675
www.emsl.com

EMSL Job #: 382300470

EMSL ANALYTICAL, INC.

Company Information: EMSL Acct #: JCB R50

Company Name: JCBROODRICK & ASSOC. INC.

Contact: STEVE MULLER

Address: 1775 EXPRESSWAY DR. N

City: HAUPPAUGE

State: NY Zip: 11788

Phone: 631-584-5492 Fax: 631-584-3392

Email: SMULLER@JCBROODRICK.COM

Technician Certification #: _____

Tech Name: STEVE MULLER

Tech Signature: [Signature]

Project/Site Information: *Required

Project Name: BAYLIS ES

Project # / PO: 22-52916

*Address: 580 WOODBURY ROAD

*City: PLAINVIEW *State: NY *Zip: 11807

*Building type? Residential Non-Residential
 School Other: _____

*Building foundation type? Basement Crawlspace
 Slab on Grade Other: _____

Special Notes / Instructions: _____

***Turnaround Time (TAT) Options**

1 Day 2 Day 3 Day 4 Day

Disclaimer: In no event shall EMSL be liable for indirect, special, consequential, or incidental damages for loss of profit or goodwill regardless of the negligence, the sole or contribution of EMSL and whether EMSL has been informed of the possibility of such damages arising out of or in connection with EMSL's services thereunder or delivery, use, reliance upon or interpretation of test results by client or third party. We accept no legal responsibility for the purposes for which the client uses the test results. In no event shall EMSL be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereafter.

(S) Sample (B) Blank (D) Duplicate	Device Number	Location	Room #	Exposure Period Beginning Date		Exposure Period Ending Date		Temp, °F	Humidity, %
				Date	Time	Date	Time		
(S) Sample	524648	FILE CABINET	2005	1/10/23	6:42	1/13/23	1639	72.5	33.7
D	524528								
S	524510	SUPPLY CABINET	2006	1/10/23	6:42	1/13/23	1640	73.5	31.7
S	524636	BOOK SHELF	2007	1/10/23	6:43	1/13/23	1642	73.5	31.7
S	524699	SUPPLY CABINET	2008	1/10/23	6:44	1/13/23	1643	72.3	32.6
B	524618								
S	524634	BOOK SHELF	2009	1/10/23	6:44	1/13/23	1645	70.7	31.5
S	524529	BOOK SHELF	2010	1/10/23	6:45	1/13/23	1648	69.6	33.5
S	524627	STORAGE CABINET	2011	1/10/23	6:45	1/10/23	1646	71.7	34.6

Relinquished by (Sign): _____ Date: _____ Time: _____

Received by EMSL (Sign): _____ Date: _____ Time: _____



**CHAIN OF CUSTODY
RADON LABORATORY SERVICES**
(COMMERCIAL USE)

EMSL ANALYTICAL, INC.
200 ROUTE 130 NORTH
CINNAMINSON, NJ 08077
PHONE: 800-220-3675
www.emsl.com

EMSL Job #: 382300470

EMSL ANALYTICAL, INC.

(S) Sample (B) Blank (D) Duplicate	Device Number	Location	Room #	Exposure Period Beginning Date		Exposure Period Ending Date		Temp. °F	Humidity, %
				Date	Time	Date	Time		
S	524670	SUPPLY CABINET	2012	1/10/23	646	1/13/23	1651	69.6	32.7
S	524651	SUPPLY CABINET	2013	1/10/23	647	1/13/23	1652	70.7	31.5
S	524556	BOOK SHELF	2015	1/10/23	647	1/13/23	1653	72.8	31.7
S	524682	BOOK SHELF	2020	1/10/23	648	1/13/23	1655	73.5	31.3
S	524623	BOOK SHELF	2021	1/10/23	649	1/13/23	1659	74.6	29.8
S	524578	CENTRAL POWER	2022	1/10/23	650	1/13/23	1657	72.8	29.7
S	524587	FILE CABINETS	2026	1/10/23	651	1/13/23	1702	71.2	30.6
D	524567								
S	524579	SPEAKER	2029	1/10/23	653	1/10/23	1703	71.9	30.6
B	524686								
S	524621	SHULK	2032	1/10/23	655	1/13/23	1705	73.0	28.7
S	524602	BOOK SHELF	2035	1/10/23	656	1/13/23	1706	71.9	30.7
S	524696	BOOK SHELF	2038	1/10/23	657	1/13/23	1708	72.5	29.4
S	524680	CANDY MACHINES	2041	1/10/23	658	1/13/23	1714	75.0	25.8
S	524566	BOOK SHELF	2044	1/10/23	659	1/13/23	1716	74.3	29.8
S	524615	BOOK SHELF	2046	1/10/23	700	1/13/23	1717	72.8	29.4
S	524538	BOOK SHELF	2047	1/10/23	701	1/13/23	1719	72.1	29.3
S	524691	BOOK SHELF	2048	1/10/23	702	1/13/23	1720	72.1	27.6

Relinquished by (Sign): _____ Date: _____ Time: _____

Received by EMSL (Sign): _____ Date: _____ Time: _____

2 Page of 4



**CHAIN OF CUSTODY
RADON LABORATORY SERVICES
(COMMERCIAL USE)**

EMSL ANALYTICAL, INC.
200 ROUTE 130 NORTH
CINNAMINSON, NJ 08077
PHONE: 800-220-3675
www.emsl.com

EMSL Job #: 3823 00470

EMSL ANALYTICAL, INC.

(S) Sample (B) Blank (D) Duplicate	Device Number	Location	Room #	Exposure Period Beginning Date		Exposure Period Ending Date		Temp, °F	Humidity, %
				Date	Time	Date	Time		
S	524664	BOOK SHELF	2049	1/10/23	703	1/13/23	1722	72.5	24.4
S	524662	BOOK SHELF	2049A	1/10/23	704	1/10/23	1723	72.5	26.7
D	524411								
S	524659	SHELF	2050	1/10/23	705	1/13/23	1757	73.4	28.9
S	524620	DESK	2053	1/10/23	706	1/13/23	1755	73.0	26.7
S	524608	SPEAKER	2061	1/10/23	707	1/13/23	1727	74.6	25.3
S	524609	SHELF	2063	1/10/23	708	1/10/23	1730	72.3	27.6
S	524585	SPEAKER	2065	1/10/23	709	1/13/23	1731	72.6	26.7
S	524423	SUPPLY CABINET	2068	1/10/23	710	1/13/23	1741	73.5	25.7
S	524320	CABINET	2070	1/10/23	710	1/13/23	1749	72.6	29.8
S	524614	CABINET	2071	1/10/23	711	1/13/23	1752	73.2	27.1
S	524463	SPEAKER	2073	1/10/23	712	1/13/23	1753	73.2	25.7
S	524343	SHELF	2077	1/10/23	713	1/13/23	1725	74.1	28.7
D	524415								
S	524622	DESK	1056	1/10/23	714	1/13/23	1757	74.3	28.0
B	524586								
S	524472	BOOK SHELF	C-7	1/10/23	715	1/13/23	1747	73.5	35.7
S	524388	BOOK SHELF	C-9	1/10/23	716	1/13/23	1746	72.8	41.7
S	524403	CABINET	C-10	1/10/23	717	1/13/23	1742	73.2	35.8

Relinquished by (Sign): _____

Date: _____

Time: _____

Received by EMSL (Sign): _____

Date: _____

Time: _____

P 11:50

EMSL ANALYTICAL, INC.
RECORDED
SERIALIZED
INDEXED



**CHAIN OF CUSTODY
RADON LABORATORY SERVICES**
(COMMERCIAL USE)

EMSL ANALYTICAL, INC.
200 ROUTE 130 NORTH
CINNAMINSON, NJ 08077
PHONE: 800-220-3675
www.emsl.com

EMSL Job #: 382300470

EMSL ANALYTICAL, INC.

(S) Sample (B) Blank (D) Duplicate	Device Number	Location	Room #	Exposure Period Beginning Date		Exposure Period Ending Date		Temp, °F	Humidity, %	
				Date	Time	Date	Time			
S	524374	SPEAKER	C-12	1/10/23	718	1/13/23	1754	72.8	37.7	
S	524454	BOOK SHELF	B-6	1/15/23	721	1/13/23	1712	71.9	36.6	
S	524316	BOOK SHELF	B-9	1/15/23	722	1/13/23	1710	72.1	33.6	
<div style="border: 1px solid black; width: 100%; height: 100%; transform: rotate(45deg); opacity: 0.5;"></div>										
								RECEIVED EMSL ANALYTICAL, INC. CARLE PLACE, NY 2023 JAN 17 P 7:50		

Relinquished by (Sign):

Date: 1/16/2023 Time: _____

Received by EMSL (Sign): _____

Date: _____ Time: _____