



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 18-12-02508

Received Date: 12/19/2018
Reported Date: 12/27/2018
Sampled By: Alex Salvador
Tech Certification #:

Project/Test Address: 181385; 262 Grove Road; Marshal Elementary; South Orange, NJ

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
18-12-02508-001	ME-S-1FL-120	12/16/2018	ROOM 120	2.91	12/21/2018	
18-12-02508-002	ME-DW-1FL-H121	12/16/2018	HALL BY RM 121	1.55	12/21/2018	
18-12-02508-003	ME-DW-1FL-121	12/16/2018	ROOM 121	1.14	12/21/2018	
18-12-02508-004	ME-S-1FL-119	12/16/2018	ROOM 119	2.83	12/21/2018	
18-12-02508-005	ME-S-1FL-122	12/16/2018	ROOM 122	1.08	12/21/2018	
18-12-02508-006	ME-DW-1FL-H122	12/16/2018	HALL BY 122	1.14	12/21/2018	
18-12-02508-007	ME-DW-1FL-124	12/16/2018	HALL BY 124	<1.00	12/21/2018	
18-12-02508-008	ME-DW-1FL-125	12/16/2018	ROOM 125	<1.00	12/21/2018	
18-12-02508-009	ME-DW-1FL-126	12/16/2018	ROOM 126	<1.00	12/21/2018	
18-12-02508-010	ME-DW-1FL-127	12/16/2018	ROOM 127	<1.00	12/21/2018	
18-12-02508-011	ME-DW-1FL-128	12/16/2018	ROOM 128	<1.00	12/21/2018	
18-12-02508-012	ME-WF-1FL-C	12/16/2018	CAFETERIA	<1.00	12/21/2018	
18-12-02508-014	ME-DW-1FL-BR-2	12/16/2018	HALL BY BATH RMS	1.40	12/21/2018	

Rev 1.0 (Revised On: 12/27/2018): Changed laboratory sample numbers and removed last sample per client request.

Environmental Hazards Services, L.L.C

Client Number: 201327
 Project/Test Address: 181385; 262 Grove Road; Marshal Elementary; South Orange, NJ

Report Number: 18-12-02508

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
18-12-02508-015	ME-S-1FL-TL	12/16/2018	TEACHER'S LOUNGE	<1.00	12/21/2018	
18-12-02508-016	ME-S-1FL-NB	12/16/2018	NURSE BATH	1.03	12/21/2018	
18-12-02508-017	ME-S-1FL-101-1	12/16/2018	ROOM 101	<1.00	12/21/2018	
18-12-02508-018	ME-S-1FL-101-2	12/16/2018	ROOM 101	1.04	12/21/2018	
18-12-02508-019	ME-DW-1FL-143	12/16/2018	ROOM 143	<1.00	12/21/2018	
18-12-02508-020	ME-DW-2FL-203	12/16/2018	HALL BY 203	<1.00	12/21/2018	
18-12-02508-021	ME-DW-2FL-213	12/16/2018	ROOM 213	<1.00	12/21/2018	
18-12-02508-022	ME-DW-2FL-209	12/16/2018	ROOM 209	<1.00	12/21/2018	
18-12-02508-023	ME-DW-2FL-210	12/16/2018	ROOM 210	<1.00	12/21/2018	
18-12-02508-024	ME-DW-2FL-211	12/16/2018	ROOM 211	<1.00	12/21/2018	
18-12-02508-025	ME-S-1FL-PS	12/16/2018	DETACHED CLASS ROOM	<1.00	12/21/2018	
18-12-02508-026	ME-S-1FL-PO	12/16/2018	PRINCIPAL'S OFFICE	<1.00	12/21/2018	

Method: SM 3113B-2010
 Analyst: Jennalee Zlotkowski
 Accreditation #: NJ VA008

Reviewed By Authorized Signatory:



Jennifer Canon-Rothkopf
 Quality Assurance Supervisor

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L = micrograms per liter ppb = parts per billion