



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 19-06-04314

Received Date: 06/26/2019
Reported Date: 06/28/2019
Sampled By: Alex Salvador
Tech Certification #:

Project/Test Address: 190677; South Mountain Elementary School; South Orange, NJ

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
19-06-04314-001	1	06/23/2019	ROOM 3	<1.00	06/28/2019	
19-06-04314-002	2	06/23/2019	ROOM 5 HALL	1.05	06/28/2019	
19-06-04314-003	3	06/23/2019	ROOM 9	<1.00	06/28/2019	
19-06-04314-004	4	06/23/2019	ROOM 120 HALL	<1.00	06/28/2019	
19-06-04314-005	5	06/23/2019	ROOM 120 HALL	<1.00	06/28/2019	
19-06-04314-006	6	06/23/2019	ROOM 107 HALL	<1.00	06/28/2019	
19-06-04314-007	7	06/23/2019	ROOM 107 HALL BOTTLE FILL	<1.00	06/28/2019	
19-06-04314-008	8	06/23/2019	ROOM 107	<1.00	06/28/2019	
19-06-04314-009	9	06/23/2019	NURSE BATH	1.22	06/28/2019	
19-06-04314-010	10	06/23/2019	ROOM 102	15.7	06/28/2019	
19-06-04314-011	11	06/23/2019	ROOM 205 HALL	<1.00	06/28/2019	
19-06-04314-012	12	06/23/2019	ROOM 209	3.04	06/28/2019	
19-06-04314-013	13	06/23/2019	CAFETERIA SINK 1	1.12	06/28/2019	

Environmental Hazards Services, L.L.C

Client Number: 201327
Project/Test Address: 190677; South Mountain Elementary School; South
Orange, NJ

Report Number: 19-06-04314

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
19-06-04314-014	14	06/23/2019	CAFETERIA SINK 2	1.45	06/28/2019	
19-06-04314-015	15	06/23/2019	LIBRARY	<1.00	06/28/2019	

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion