



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 19-06-04362

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Received Date: 06/26/2019
Reported Date: 06/28/2019
Sampled By: Alex Salvador
Tech Certification #:

Project/Test Address: 190677; South Mountain Elementary Annex; South Orange, NJ

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
19-06-04362-001	1	06/23/2019	CLASSROOM 114	<1.00	06/28/2019	
19-06-04362-002	2	06/23/2019	CLASSROOM 117	<1.00	06/28/2019	
19-06-04362-003	3	06/23/2019	CLASSROOM 116	<1.00	06/28/2019	
19-06-04362-004	4	06/23/2019	CLASSROOM 115	<1.00	06/28/2019	
19-06-04362-005	5	06/23/2019	BY BOILER ROOM	<1.00	06/28/2019	
19-06-04362-006	6	06/23/2019	FACULTY LOUNGE	<1.00	06/28/2019	
19-06-04362-007	7	06/23/2019	NURSES OFFICE	1.43	06/28/2019	
19-06-04362-008	8	06/23/2019	BY ROOM 103	1.22	06/28/2019	
19-06-04362-009	9	06/23/2019	ROOM 101	<1.00	06/28/2019	
19-06-04362-010	10	06/23/2019	ROOM 102	4.40	06/28/2019	
19-06-04362-011	11	06/23/2019	ROOM 103	<1.00	06/28/2019	
19-06-04362-012	12	06/23/2019	PRINCIPALS OFFICE	<1.00	06/28/2019	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 19-06-04362

Project/Test Address: 190677; South Mountain Elementary Annex; South
Orange, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion