



181 US Hwy 46
Mine Hill, NJ 07803
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:

Columbia High School
17 Parker Ave., Maplewood, NJ 07040

Performed For:

South Orange Maplewood Board of Education
Sheila Paschall
25 West Parker Ave
Maplewood, NJ 07040

Prepared By:

LEW Corporation
181 US Hwy 46
Mine Hill, NJ 07803

Phone (908) 654-8068
Fax (908) 654-8069
Website <http://www.LEWCorp.com>

Inspection Date: 7/18, 8/15, 2021
Project Number: 210552 & 210641

Table of Contents

Contact Information	3
Introduction	4
Sampling Methodology	4
Drinking Water Results	5
Recommendations	5
Additional Recommendations	6

Appendices

Appendix A	Exceedances
Appendix B	Recommendations
Appendix C	All results
Appendix D	Floor Plan(S)
Appendix E	Laboratory Data

Contact Information

Agency

Client Contact:	Sheila Paschall
Client Name:	South Orange Maplewood Board of Education Columbia High School
Street Address	25 West Parker Ave Maplewood, NJ 07040
Phone Number:	201 259 2469

Risk Assessor(s)

Site Assessor(s):	Alex Salvador
License:	NJDOH # 022779
Signature:	
Date:	August 23, 2021
E-Mail	asalvador@lewcorp.com

Firm

Organization:	LEW Corporation
Certification #:	NJDCA 00015 E
Street:	181 US Hwy 46
City, State & Zip:	Mine Hill, NJ 07803
Phone Number:	908-654-8068
Web Address:	http://www.lewcorp.com

Laboratory

Organization:	Environmental Hazard Services, LLC
Street:	7469 Whitepine Road
City, State & Zip:	Richmond, VA 23237
NJDEP Certification #	VA008
Phone Number:	800-347-4010

Introduction

LEW Corporation was contracted by South Orange Maplewood Board of Education to test for the presence of lead in drinking water Columbia High School 17 Parker Avenue Maplewood NJ.

Sampling Methodology

LEW Corporation followed the July 13, 2016 amendments to NJAC 6A:26. Full details on sampling practices can be found in Districts Sampling Plan.

All samples were collected in 250mL wide mouth plastic containers that was prepackaged by the analytical laboratory. The sample containers may contain nitric acid, if expedited analysis is required. If not, nitric acid will be added to each sample upon arrival at the laboratory. At each sample location, the first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than forty-eight hours. If second draw samples were collected, they were collecting following a flushing protocol outlined in the District's Sampling Plan.

Drinking Water Results

On July 18, 2021 LEW Corporation collected the following number of water samples:

On August 15, 2021 LEW Corporation returned to the High School to collect post remediation samples.

Columbia High School

- 38 first draw samples collected
- 3 samples above the 15ppb action level
- 1 sample (quality control)

Columbia High School 8-15-2021

- 3 first draw samples collected
- 0 samples above the 15ppb action level

No further sampling is required clearance has been achieved.

The complete list of samples that exceeded the 15ppb limit can be found in Appendix A. The complete list of all sample results can be found in Appendix C. The laboratory results can be found in Appendix E.

Certain outlets could not or were not tested due to various reasons. The following table lists those locations and the reason why samples were not collected.

School	Sample Location	Reason for not testing.
None		

Recommendations July 18, 2021

Those outlets where the first draw sample tested below 15ppb are not considered to be elevated and no mitigation is necessary.

For those outlets where the first draw sample exceeds 15ppb the following steps are recommended:

- 1) Immediately discontinue use of the outlets.
- 2) Conduct second draw (flush) samples on these outlets to further delineate source of contamination.

A complete list of recommendations per outlet can be found in Appendix B.

Recommendations August 15, 2021

No further sampling is necessary

Additional Recommendations

- 1) Follow-up samples should be collected after any remediation efforts in order to determine the efficacy of the work.
- 2) Any of the inoperable/non-functioning outlets listed above that are brought back into service should be sample.
- 3) Comply with all requirements set forth in NJAC 6A:26.

Appendix A Exceedances

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
1 st Draw Samples July 18, 2021					
Columbia High School	7/18/2021	7/23/2021	4	HALL BY C109 BUBBLER	19.8
Columbia High School	7/18/2021	7/23/2021	31	HALL BY BOYS BATH BUBBLER	42.4
Columbia High School	7/18/2021	7/23/2021	40	ROOM C128 SINK	57.9

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
1 st Draw Samples August 15, 2021					
None					

Appendix B Recommendations

July 18, 2021

Building	Sample ID	Location	Remediation Recommendation
Columbia High School	4	HALL BY C109 BUBBLER	Stop usage of outlet. Perform second draw sampling.
Columbia High School	31	HALL BY BOYS BATH BUBBLER	
Columbia High School	40	ROOM C128 SINK	

August 15, 2021

Building	Sample ID	Location	Remediation Recommendation
None			

Appendix C All Results

July 18, 2021

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
1 st Draw Samples Columbia High School					
Columbia High School	7/18/2021	7/23/2021	1	NURSE OFFICE SINK	1.51
Columbia High School	7/18/2021	7/23/2021	2	NURSE BATH SINK	1.12
Columbia High School	7/18/2021	7/23/2021	3	STAFF BATH SINK	5.60
Columbia High School	7/18/2021	7/23/2021	4	HALL BY C109 BUBBLER	19.8
Columbia High School	7/18/2021	7/23/2021	5	HALL BY C109 BUBBLER	13.4
Columbia High School	7/18/2021	7/23/2021	6	HALL BY B134 BUBBLER	<1.00
Columbia High School	7/18/2021	7/23/2021	7	HALL BY B114 BUBBLER	6.23
Columbia High School	7/18/2021	7/23/2021	8	HALL BY B114 BUBBLER	3.28
Columbia High School	7/18/2021	7/23/2021	9	HALL BY D105 BUBBLER	3.04
Columbia High School	7/18/2021	7/23/2021	10	HALL BY D105 BUBBLER	3.81
Columbia High School	7/18/2021	7/23/2021	11	HALL BY A129 SINK	<1.00
Columbia High School	7/18/2021	7/23/2021	12	KITCHEN SINK	1.16
Columbia High School	7/18/2021	7/23/2021	13	KITCHEN KETTLE	<1.00
Columbia High School	7/18/2021	7/23/2021	14	KITCHEN ICE MACHINE	<1.00
Columbia High School	7/18/2021	7/23/2021	15	CAFETERIA BOTTLE FILL	<1.00
Columbia High School	7/18/2021	7/23/2021	16	HALL BY BLACK BOX BUBBLER	5.25
Columbia High School	7/18/2021	7/23/2021	17	HALL BY BLACK BOX BUBBLER	6.57
Columbia High School	7/18/2021	7/23/2021	18	HALL BY A241 BUBBLER	2.62
Columbia High School	7/18/2021	7/23/2021	19	HALL BY A241 BUBBLER	<1.00
Columbia High School	7/18/2021	7/23/2021	20	HALL BY D203 BUBBLER	3.67
Columbia High School	7/18/2021	7/23/2021	21	HALL BY D203 BUBBLER	1.94

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
1 st Draw Samples					
Columbia High School	7/18/2021	7/23/2021	23	FACULTY LOUNGE SINK	<1.00
Columbia High School	7/18/2021	7/23/2021	24	HALL BY B207 BUBBLER	4.16
Columbia High School	7/18/2021	7/23/2021	25	HALL BY B230 BUBBLER	<1.00
Columbia High School	7/18/2021	7/23/2021	26	HALL BY B230 BUBBLER	3.77
Columbia High School	7/18/2021	7/23/2021	27	HALL BY C207 BUBBLER	2.52
Columbia High School	7/18/2021	7/23/2021	28	HALL BY C207 BUBBLER	<1.00
Columbia High School	7/18/2021	7/23/2021	29	HALL BY C229 BUBBLER	<1.00
Columbia High School	7/18/2021	7/23/2021	30	HALL BY C229 BUBBLER	<1.00
Columbia High School	7/18/2021	7/23/2021	31	HALL BY BOYS BATH BUBBLER	42.4
Columbia High School	7/18/2021	7/23/2021	32	HALL BY D301 BUBBLER	6.29
Columbia High School	7/18/2021	7/23/2021	33	HALL BY D301 BUBBLER	6.21
Columbia High School	7/18/2021	7/23/2021	34	HALL BY B338 BUBBLER	<1.00
Columbia High School	7/18/2021	7/23/2021	36	HALL BY B328 BUBBLER	5.63
Columbia High School	7/18/2021	7/23/2021	37	HALL BY B328 BUBBLER	11.9
Columbia High School	7/18/2021	7/23/2021	39	ROOM C128 ICE MACHINE	<1.00
Columbia High School	7/18/2021	7/23/2021	40	ROOM C128 SINK	57.9
Columbia High School	7/18/2021	7/23/2021	41	ROOM 007 SINK (quality control)	<1.00

August 15, 2021

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ug/L) Or ppb
1 st Draw Samples Columbia High School					
Columbia High School	8/15/2021	8/19/2021	4	HALL BY C109 BUBBLER	1.80
Columbia High School	8/15/2021	8/19/2021	31	HALL BY BOYS BATH BUBBLER	<1.0
Columbia High School	8/15/2021	8/19/2021	40	ROOM C128 SINK	,1.0

Appendix D Floor Plan(s)

Appendix E Laboratory Data



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 21-07-02762

Received Date: 07/20/2021
Reported Date: 07/26/2021
Sampled By: Alex Salvador
Tech Certification #:

Project/Test Address: 210552; Columbia High School; 17 Parker Ave; Maplewood, NJ

Client Number:
201327

Fax Number:
Ext 18 Melissa

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02762-001	1	07/18/2021	NURSE OFFICE SINK	1.51	07/23/2021	
21-07-02762-002	2	07/18/2021	NURSE BATH SINK	1.12	07/23/2021	
21-07-02762-003	3	07/18/2021	STAFF BATH SINK	5.60	07/23/2021	
21-07-02762-004	4	07/18/2021	HALL BY C109 BUBBLER	19.8	07/23/2021	
21-07-02762-005	5	07/18/2021	HALL BY C109 BUBBLER	13.4	07/23/2021	
21-07-02762-006	6	07/18/2021	HALL BY B134 BUBBLER	<1.00	07/23/2021	
21-07-02762-007	7	07/18/2021	HALL BY B114 BUBBLER	6.23	07/23/2021	
21-07-02762-008	8	07/18/2021	HALL BY B114 BUBBLER	3.28	07/23/2021	
21-07-02762-009	9	07/18/2021	HALL BY D105 BUBBLER	3.04	07/23/2021	
21-07-02762-010	10	07/18/2021	HALL BY D105 BUBBLER	3.81	07/23/2021	
21-07-02762-011	11	07/18/2021	HALL BY A129 SINK	<1.00	07/23/2021	
21-07-02762-012	12	07/18/2021	KITCHEN SINK	1.16	07/23/2021	
21-07-02762-013	13	07/18/2021	KITCHEN KETTLE	<1.00	07/23/2021	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 21-07-02762

Project/Test Address: 210552; Columbia High School; 17 Parker Ave;
Maplewood, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02762-014	14	07/18/2021	KITCHEN ICE MACHINE	<1.00	07/23/2021	
21-07-02762-015	15	07/18/2021	CAFETERIA BOTTLE FILL	<1.00	07/23/2021	
21-07-02762-016	16	07/18/2021	HALL BY BLACK BOX BUBBLER	5.25	07/23/2021	
21-07-02762-017	17	07/18/2021	HALL BY BLACK BOX BUBBLER	6.57	07/23/2021	
21-07-02762-018	18	07/18/2021	HALL BY A241 BUBBLER	2.62	07/23/2021	
21-07-02762-019	19	07/18/2021	HALL BY A241 BUBBLER	<1.00	07/23/2021	
21-07-02762-020	20	07/18/2021	HALL BY D203 BUBBLER	3.67	07/23/2021	
21-07-02762-021	21	07/18/2021	HALL BY D203 BUBBLER	1.94	07/23/2021	
21-07-02762-022	22	07/18/2021	FACULTY LOUNGE WATER FOUNTAIN	<1.00	07/23/2021	
21-07-02762-023	23	07/18/2021	FACULTY LOUNGE SINK	4.16	07/23/2021	
21-07-02762-024	24	07/18/2021	HALL BY B207 BUBBLER	<1.00	07/23/2021	
21-07-02762-025	25	07/18/2021	HALL BY B230 BUBBLER	3.77	07/23/2021	
21-07-02762-026	26	07/18/2021	HALL BY B230 BUBBLER	2.52	07/23/2021	
21-07-02762-027	27	07/18/2021	HALL BY C207 BUBBLER	<1.00	07/23/2021	
21-07-02762-028	28	07/18/2021	HALL BY C207 BUBBLER	<1.00	07/23/2021	
21-07-02762-029	29	07/18/2021	HALL BY C229 BUBBLER	<1.00	07/23/2021	
21-07-02762-030	30	07/18/2021	HALL BY C229 BUBBLER	<1.00	07/23/2021	
21-07-02762-031	31	07/18/2021	HALL BY BOYS BATH BUBBLER	42.4	07/23/2021	
21-07-02762-032	32	07/18/2021	HALL BY D301 BUBBLER	6.29	07/23/2021	
21-07-02762-033	33	07/18/2021	HALL BY D301 BUBBLER	6.21	07/23/2021	

Environmental Hazards Services, L.L.C

Client Number: 201327
Project/Test Address: 210552; Columbia High School; 17 Parker Ave;
Maplewood, NJ

Report Number: 21-07-02762

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02762-034	34	07/18/2021	HALL BY B338 BUBBLER	<1.00	07/23/2021	
21-07-02762-035	36	07/18/2021	HALL BY B328 BUBBLER	5.63	07/23/2021	
21-07-02762-036	37	07/18/2021	HALL BY B328 BUBBLER	11.9	07/23/2021	
21-07-02762-037	39	07/18/2021	ROOM C128 ICE MACHINE	<1.00	07/23/2021	
21-07-02762-038	40	07/18/2021	ROOM C128 SINK	57.9	07/23/2021	
21-07-02762-039	41	07/18/2021	ROOM 007 SINK	<1.00	07/23/2021	

Method: EPA 200.8
Analyst: Ailea Cabatbat
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode


Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



LEADS
Laboratories™
ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form
SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907
ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com




21-07-02762

Due Date:
07/27/2021
(Tuesday)
AE

Company Name: LEW CORP Account #: 201327
Address: 181 US Highway 46 City/State/Zip: Milne Hill, NJ 07803
Phone: (908-654-8068 Email: labresults@lewcorp.com Fax: 908-654-8069
Project Name / Collection Address: Columbia High School 17 parker Ave City/State/Zip: Maclennan NJ
(required)
Project #: 210552 Sampled By: Alex Salvador License # (if Required):
Water Source: (Check One) Public ☒ Well ☐ Well Tag # (if Applicable):
(required)

X	5 Day Turnaround	3 Day Turnaround	2 Day Turnaround	1 Day Turnaround	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection	Temp. at time of Collection	
No.	Client Sample ID	Collection Location (Exc Kitchen Sink)	Collection Date	Collection Time						
1	1	Nurse office sink	7/18/2021	8:30	AM/PM	X				
2	2	Nurse Bath		31	AM/PM					
3	3	staff bath		32	AM/PM					
4	4	Hall by C109 bubble		34	AM/PM					
5	5	C109		35	AM/PM					
6	6	B134		36	AM/PM					
7	7	B114		38	AM/PM					
8	8	B114		39	AM/PM					
9	9	D105		40	AM/PM					
10	10	D105		41	AM/PM					
Released by: Alex Salvador		Signature: [Signature]		Date/Time: 7/18/21			4:00 pm			
Released by: KTHARRIS		Signature: [Signature]		Date/Time: 7.20.21			11:28 AM			



ENVIRONMENTAL HAZARDS SERVICES, LLC


Water Chain-of-Custody Form
SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907
ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

~ For Lab Use Only ~

Company Name: LEW CORP Account #: 201327
Address: 181 US Highway 46 City/State/Zip: Mine Hill, NJ 07803
Phone: (908-654-8068) Email: labresults@lewcorp.com Fax: 908-654-8069
Project Name / Collection Address: Columbia High School 17 Parker Ave City/State/Zip: Maplewood NJ
(Required)
Project #: 210552 Sampled By: Alex Salvador License # (If Required):
Water Source: (Check One) Public ☒ Well ☐ Well Tag # (If Applicable):

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection	Temp. at time of Collection	
1	11	Hall by A129 Sink	7/18/2021	8:42	AM/PM	X				
2	12	Kitchen Sink		43	AM/PM					
3	13	Kitchen Kettle		44	AM/PM					
4	14	Kitchen Ice Machine		45	AM/PM					
5	15	Captain's bottle fill		46	AM/PM					
6	16	Hall by Black box Bubble		48	AM/PM					
7	17	Black box		49	AM/PM					
8	18	A241		51	AM/PM					
9	19	A241		52	AM/PM					
10	20	0803		53	AM/PM					

Released by: Alex Salvador Signature: [Signature] Date/Time: 7/18/21 4:pm
Released by: KTHAARIS Signature: [Signature] Date/Time: 7.20.21 11:28am



ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form
SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907
ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

~ For Lab Use Only ~

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address: Columbia High School 17 Parker Ave

City/State/Zip: Maplewood NJ

Project #: 210552

Sampled By: Alex Salvador

License # (If Required):


Water Source: (Check One) Public ☒ Well ☐

Well Tag # (If Applicable):

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
1	21	Hall by D203 Bubble	7/18/2021	8:54	AM/PM	X				
2	22	Faculty lounge with fountain		55	AM/PM					
3	23	Faculty lounge sink		56	AM/PM					
4	24	Hall by 8207 Bubble		57	AM/PM					
5	25	B230		58	AM/PM					
6	26	B230		59	AM/PM					
7	27	C207		60	AM/PM					
8	28	C207		9:06	AM/PM					
9	29	C207		07	AM/PM					
10	30	C207		08	AM/PM					

Released by: Alex Salvador Signature: [Signature] Date/Time: 7/18/21 4:pm

Released by: KTHARRIS Signature: [Signature] Date/Time: 7.20.21 11:28 AM



ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form
SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907
ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

~ For Lab Use Only ~

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address: Columbia High School 17 Parker Ave

City/State/Zip: Maplewood NJ

Project #: 210552

Sampled By: Alex Salvador

License # (If Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (If Applicable):

No.	Client Sample ID	Collection Location (Exc. Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection	Temp. at time of Collection	
1	31	Hall by Boys bath	Bubbles 7/18/2021	10:00 PM	X					
2	32	D301		AM/PM						
3	33	↓ D301 ↓		AM/PM						
4	34	Hall by B338	Bubbles	AM/PM						
5	36	Hall by B328	Bubbles	AM/PM						
6	37	B328	Bubbles	AM/PM						
7	39	Room C128	Ice Machine	AM/PM						
8	40	↓ Sink		AM/PM						
9	41	Room 007	Sink	AM/PM						
10				AM/PM						

Released by: Alex Salvador
Signature: [Signature]
Date/Time: 7/18/21 4:00 pm

Released by: KTHARRIS
Signature: [Signature]
Date/Time: 7.20.21 11:28 am

1 Day Turnaround Call Ahead



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 21-08-02672

Received Date: 08/17/2021
Reported Date: 08/20/2021
Sampled By: Alex Salvador
Tech Certification #:

Project/Test Address: 210641; Columbia High School; 17 Parker Avenue; Maplewood, NJ

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-08-02672-001	4	08/15/2021	HALL BY C109 BUBBLER	1.80	08/19/2021	
21-08-02672-002	31	08/15/2021	HALL BY BOYS BATH BUBBLER	<1.00	08/19/2021	
21-08-02672-003	40	08/15/2021	ROOM C128 SINK	<1.00	08/19/2021	

Method: EPA 200.8
Analyst: Ailea Cabatbat
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237

Phone: (800) 347-4010 FAX: (804) 275-4907

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

21-08-02672



Due Date:

08/24/2021

(Tuesday)

AE

Company Name: LEW CORP Account #: 201327

Address: 181 US Highway 46 City/State/Zip: Mine Hill, NJ 07803

Phone: (908-654-8068 Email: labresults@lewcorp.com Fax: 908-654-8069

Project Name / Collection Address: Columbia High School 17 Parker Avenue City/State/Zip: Maplenwood NJ

Project #: 210641

Sampled By: Alex Salvador License # (If Required):

Water Source: (Check One) Public ☒ Well ☐ Well Tag # (If Applicable):

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals		Field Parameters		LAB USE	
					Lead	Copper	Other	Field pH at time of Collection:		Temp. at time of Collection:
1	4	Hall by C109 Bubbler	8/15/21	8:00	AM/PM	X				
2	31	Hall by Boys' bath Bubbler	↓	8:05	AM/PM	↓				
3	40	Roomy C108 Sink	↓	8:07	AM/PM	↓				
4				8:09	AM/PM	↓				
5					AM/PM					
6					AM/PM					
7					AM/PM					
8					AM/PM					
9					AM/PM					
10					AM/PM					
Released by: Alex Salvador		Signature: [Signature]		Date/Time: 8/16/21		Date/Time: 8/17/21		5:10 pm		12:06 pm