

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Follow-up Samples:

Building Name	Date of Sample Events	Total Number Samples Collected	Initial First Draw Samples		Follow-up Samples	
					First Draw Samples	
			Analyzed at or Below Action Level of 15 ppb	Analyzed Above Action Level of 15 ppb	Analyzed at or Below Action Level of 15 ppb	Analyzed Above Action Level of 15 ppb
Ellicott Elementary	10/2/2020	103	95	8	N/A	N/A
	12/11/2020	3	N/A	N/A	3	0
	4/9/2021	5	N/A	N/A	5	0
Total:		111				

** Follow-up samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Sample Results: Initial First Draw and Follow-up First Draw

Sample #	Classroom or other Location	Fixture/Outlet type	Date Sampled	Laboratory Analysis in ppb
126.3-44	A3 Bathroom	Sink	10/2/2020	34.8
			12/11/2020	Not Sampled
			4/9/2021	4.60 - Cleared
126.3-57	E29 Kitchen Corner	Sink	10/2/2020	17.1
			12/11/2020	2.91 - Cleared
126.3-58	E29 Kitchen Center	Sink	10/2/2020	15.6
			12/11/2020	14.6 - Cleared
126.3-70	M14 Work Room	Sink	10/2/2020	29.3
			12/11/2020	Not Sampled
			4/9/2021	4.00 - Cleared
126.3-90	D7	Sink	10/2/2020	36.1
			12/11/2020	Not Sampled
			4/9/2021	3.40 - Cleared
126.3-100	M25	Sink	10/2/2020	55.6
			12/11/2020	Not Sampled
			4/9/2021	5.60 - Cleared
126.3-102	D-Wing Men's Faculty Bath	Sink	10/2/2020	18.9
			12/11/2020	1.42 - Cleared
126.3-118	Small Gym Girl's Locker Room	Sink	10/2/2020	39.7
			12/11/2020	Not Sampled
			4/9/2021	2.29 - Cleared