

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Follow-up Samples:

Building Name	Date of Sample Events	Total Number Samples Collected	Initial First Draw Samples		Follow-up Samples	
					First Draw Samples	
			Analyzed at or Below Action Level of 15 ppb	Analyzed Above Action Level of 15 ppb	Analyzed at or Below Action Level of 15 ppb	Analyzed Above Action Level of 15 ppb
South Davis Elementary	10/1/2020	65	60	5	N/A	N/A
	12/11/2020	2	N/A	N/A	2	0
	4/1/2021	3	N/A	N/A	2	1
Total:		70				

** Follow-up samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Sample Results: Initial First Draw, and Follow-up First Draw

Sample #	Classroom or other Location	Fixture/Outlet type	Date Sampled	Laboratory Analysis in ppb
126.4-34	Kitchen Back Handwash Sink	Sink	10/1/2020	15.7
			12/11/2020	4.91 – Cleared
126.4-56	112 Right White Sink	Sink	10/1/2020	25.6
			12/11/2020	Not Sampled
			4/14/2021	1.98 – Cleared
126.4-59	113 Left White Sink	Sink	10/1/2020	28.9
			12/11/2020	Not Sampled
			4/14/2021	17.3
126.4-60	113 Right White Sink	Sink	10/1/2020	50.9
			12/11/2020	Not Sampled
			4/14/2021	5.86 – Cleared
126.4-63	114 Left White Sink	Sink	10/1/2020	19.4
			12/11/2020	4.82 – Cleared

Note: It is recommended that the District continue to prohibit use of any outlet identified above the action level until further mitigation and additional sampling and analysis is performed.