Shawnee Mission School District
24-021 – Roof Improvement Project - CAA
December 11, 2024

Addendum No. 1

The following response addresses questions submitted as of December 10, 2024; responses to the questions are indicated in **bold**. If you feel that a question has not been addressed, please contact Reed Beebe at purchasing@smsd.org as soon as possible.

1. What is the estimated construction budget?

   The District currently does not have a set budget for the CAA roof improvements, but estimates that the project will range in cost from $100,000 to $150,000.

2. Can a copy of the planholders list be provided?

   Yes. A copy of the District's planholders list can be requested by emailing purchasing@smsd.org.

3. Plan Sheet G1.00, Section 077600, 2.2, A - requires the contractor to engage a professional engineer to design pedestal support system and perimeter containment system. Section 077600 clearly specifies a premanufactured pedestal support system and plan sheet A4.00 clearly indicates the perimeter closure details required. What additional engineering design is required?

   If you use a pre-engineered system from an approved manufacturer, no further engineering is required.

4. We are an MBE/WBE firm in Missouri, and have business licenses in several cities in Missouri. Do we need a business license or anything in Shawnee?

   The District is currently not aware of any contractor business licensing requirements specific to city jurisdictions.

End of Addendum No. 1