Facility or Building Name	Facility or Building Name Hmong Academy Elementry					
Did the facility test using the MDH testing program						
(WIIN)? (Yes or No)	No					
Facility Type (School or Child Care)	School					
School ID Number or Child Care License Number	0001-03-224					
Facility or Building Address	1501 30th Ave N, Minneapolis, MN 55411					
	1225 North 7th Street Minneapolis, MN					
Mailing Address	55411					
_						
Contact Person	Lee Setter					
Title	Manager, EH&S					
Phone	612-668-0308					
	•					
Email	Lee.Setter@mpls.k12.mn.us					

SUMMARY	<b>ANSWER</b>
Total number of samples	40
Total number of fixtures sampled	40
Total number of results above 5 ppb	0
Total number of remediation actions	0
Next Scheduled Sampling Date (Month/Year)	11/2029

Unique Sample				Sample	Laboratory	Date/Time	Date/Time		Unit of	Name of Laboratory		Other	₩as Remediation	Additional Notes or
Site Identification	Fixture Type	Location Description	Fixture Status	Collection Type	Identification	Collected	Analyzed	Numeric Result	Measure	Used For Analysis	Remediation Action	Remediation-	Successful (ie. Follow-up	Comments
Number					Number (optional)		,					Please	testing below 5 ppb)	Comments
0001-03-224-09	Sink	Classroom 154 Sink	Active - Consumption	Initial - First Draw	24-13844	11/8/2024 03:37	12/3/2024 13:11	ND	μg/L	Twin City Water Clinic				
0001-03-224-10	Drinking Fountain	Classroom 153 DF	Active - Consumption	Initial - First Draw	24-13845	11/8/2024 03:38	12/3/2024 13:29	ND	μg/L	Twin City Water Clinic				
0001-03-224-11	Drinking Fountain	Classroom 151 DF	Active - Consumption	Initial - First Draw	24-13846	11/8/2024 03:39	12/3/2024 13:35	ND	μg/L	Twin City Water Clinic				
0001-03-224-12	Drinking Fountain	Classroom 148 DF	Active - Consumption	Initial - First Draw	24-13847	11/8/2024 03:40	12/3/2024 13:41	ND	μg/L	Twin City Water Clinic				
0001-03-224-13	Drinking Fountain	Classroom 146 DF	Active - Consumption	Initial - First Draw	24-13848	11/8/2024 03:42	12/3/2024 13:47	ND	μg/L	Twin City Water Clinic				
0001-03-224-14	Sink	Classroom 145 Sink	Active - Consumption	Initial - First Draw	24-13849	11/8/2024 03:43	12/3/2024 13:53	ND	μg/L	Twin City Water Clinic				
0001-03-224-15	Drinking Fountain	Hallway Outside BR 107 - Left Side DF	Active - Consumption	Initial - First Draw	24-13850	11/8/2024 03:44	12/3/2024 13:59	ND	μg/L	Twin City Water Clinic				
0001-03-224-16	Drinking Fountain	Hallway Outside BR 107 - Right Side DF	Active - Consumption	Initial - First Draw	24-13851	11/8/2024 03:44	12/3/2024 14:05	ND	μg/L	Twin City Water Clinic				
0001-03-224-17	Drinking Fountain	Classroom 108 DF	Active - Consumption	Initial - First Draw	24-13852	11/8/2024 03:45	12/3/2024 14:11	ND	μg/L	Twin City Water Clinic				
0001-03-224-18	Drinking Fountain	Classroom 109 DF	Active - Consumption	Initial - First Draw	24-13853	11/8/2024 03:46	12/3/2024 14:17	ND	μg/L	Twin City Water Clinic				
0001-03-224-19	Sink	Classroom 110 Sink	Active - Consumption	Initial - First Draw	24-13854	11/8/2024 03:47	12/5/2024 11:48	ND	μg/L	Twin City Water Clinic				
0001-03-224-20	Drinking Fountain	Room 114 DF	Active - Consumption	Initial - First Draw	24-13855	11/8/2024 03:48	12/5/2024 11:54	ND	μg/L	Twin City Water Clinic				
0001-03-224-21	Drinking Fountain	Room 116 DF	Active - Consumption	Initial - First Draw	24-13856	11/8/2024 03:49	12/5/2024 12:00	ND	μg/L	Twin City Water Clinic				
0001-03-224-22	Sink	Room 117 Sink	Active - Consumption	Initial - First Draw	24-13857	11/8/2024 03:51	12/5/2024 12:18	ND	μg/L	Twin City Water Clinic				
0001-03-224-23	Sink	Room 140 Sink	Active - Consumption	Initial - First Draw	24-13858	11/8/2024 03:53	12/5/2024 12:36	ND	μg/L	Twin City Water Clinic				
0001-03-224-24	Sink	Room 138 Sink	Active - Consumption	Initial - First Draw	24-13859	11/8/2024 03:54	12/5/2024 12:42	ND	μg/L	Twin City Water Clinic				
0001-03-224-25	Sink	Room 137 Sink	Active - Consumption	Initial - First Draw	24-13860	11/8/2024 03:55	12/5/2024 12:48	ND	μg/L	Twin City Water Clinic				
0001-03-224-26	Sink	Room 135 Sink	Active - Consumption	Initial - First Draw	24-13861	11/8/2024 03:56	12/5/2024 12:54	ND	μg/L	Twin City Water Clinic				
0001-03-224-27	Sink	Room 131 Sink	Active - Consumption	Initial - First Draw	24-13862	11/8/2024 03:57	12/5/2024 13:00	ND	μg/L	Twin City Water Clinic				
0001-03-224-28	Sink	Room 130 Sink	Active - Consumption	Initial - First Draw	24-13863	11/8/2024 03:58	12/5/2024 13:06	ND	μg/L	Twin City Water Clinic				
0001-03-224-29	Sink	Room 129 Sink	Active - Consumption	Initial - First Draw	24-13864	11/8/2024 03:59	12/5/2024 13:12	ND	μg/L	Twin City Water Clinic				
0001-03-224-30	Drinking Fountain	Hallway Outside BR 128 - Left Side DF	Active - Consumption	Initial - First Draw	24-13865	11/8/2024 04:02	12/5/2024 13:18	ND	μg/L	Twin City Water Clinic				
0001-03-224-31	Drinking Fountain	Hallway Outside BR 128 - Right Side DF	Active - Consumption	Initial - First Draw	24-13866	11/8/2024 04:02	12/5/2024 13:24	ND	μg/L	Twin City Water Clinic				
0001-03-224-32	Drinking Fountain	Hallway Outside BR 228 - Left Side DF	Active - Consumption	Initial - First Draw	24-13867	11/8/2024 04:04	12/5/2024 13:42	ND	μg/L	Twin City Water Clinic				
0001-03-224-33	Drinking Fountain	Hallway Outside BR 228 - Right Side DF	Active - Consumption	Initial - First Draw	24-13868	11/8/2024 04:04	12/5/2024 14:00	ND	μg/L	Twin City Water Clinic				
0001-03-224-34	Sink	Room 222 Sink	Active - Consumption	Initial - First Draw	24-13869	11/8/2024 04:05	12/5/2024 14:06	ND	μg/L	Twin City Water Clinic				
0001-03-224-35	Drinking Fountain	Hallway Outside BR 206/207 - Left Side DF	Active - Consumption	Initial - First Draw	24-13870	11/8/2024 04:06	12/5/2024 14:12	ND	μg/L	Twin City Water Clinic				
0001-03-224-36		Hallway Outside BR 206/207 - Right Side DF	Active - Consumption	Initial - First Draw	24-13871	11/8/2024 04:16	12/5/2024 14:18	ND	μg/L	Twin City Water Clinic				
0001-03-224-37	Drinking Fountain	Hallway Outside Room 291 - Left Side DF	Active - Consumption	Initial - First Draw	24-13872	11/8/2024 04:17	12/5/2024 14:24	ND ND	μg/L	Twin City Water Clinic				
0001-03-224-38	Drinking Fountain	Hallway Outside BR 258 DF	Active - Consumption	Initial - First Draw	24-13873	11/8/2024 04:17	12/5/2024 14:30	ND ND	μg/L	Twin City Water Clinic				
0001-03-224-39	Sink	Staff Lounge Room 284 Sink	Active - Consumption	Initial - First Draw	24-13874	11/8/2024 04:18	12/5/2024 14:36	ND ND	µg/L	Twin City Water Clinic				<del></del>
0001-03-224-40	Sink	Health Office 183 Sink	Active - Consumption	Initial - First Draw	24-13875	11/8/2024 04:19	12/5/2024 14:42	ND ND	µg/L	Twin City Water Clinic				
0001-03-224-40	JINK	Fleakir Onice 103 SINK	Active - Consumption	ninuai - i Ifst Draw	24-13013	111012024 04:13	121012024 14:42	IND	μgrt	Twirroity water clinic				-
	<del>                                     </del>													
	1													
	_													

## Definitions of Reporting Fields

Field Name	Field Name Response Needed or Definition			
		information come		
Unique Sample Site Identification Number	A unique number or code using numbers and or letters that a facility assigns to each fixture in the building. This prevents confusion about which sample goes with which fixture.	Facility		
Fixture Type	Describes the type of fixture such as sink, fountain, bottle filler, ice machine, kitchen kettle, coffee machine, etc	Facility		
Location Description	Specific description of the location of the fixture. Ex. Classroom sink in Room 112 or Left drinking fountain in gym	Facility		
Fixture Status	Describes if the fixture is currently being used and how it is used. Examples are Active-Consumption, Inactive-Consumption, Active-Nonconsumption, Inactive-Nonconsumption	Facility		
Sample Collection Type	Initial first draw, Initial Flushed, Follow-up First Draw, Follow-up Flushed, Other	Facility		
Laboratory Identification Number	Number assigned by the laboratory to each sample. It may be helpful for facilities using this spreadsheet to cross reference to their lab results. (Optional)	Lab		
Date/Time Collected	Date and time the sample was collected Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab		
Date/Time Analyzed	Date and time the sample was analyzed Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab		
Numeric Result	This is the number representing the result reported by the lab. Ex. 5.12, 7.03, 89.02, for results that are not detected please use ND	Lab		
Unit of Measure	This is the unit of the result reported by the lab Ex. Parts per billion (ppb), micrograms per liter (ug/L).	Lab		
Name of Laboratory Used For Analysis	The name of the laboratory used for sample analysis.	Lab		
Remediation Action	Describes the type of remediation (if needed). Select from drop down menu. You only need to complete if result is 5ppb or more. If the action you took is not listed select OTHER and	Facility		
	describe			
Other Remediation-Please Describe	Use this field to type in your remediation action if the choice was not listed in the Remediation Action Drop down menu.	Facility		
Was Remediation Successful (ie. Follow-up		Facility		
testing below 5 ppb)	Select from the drop down. Options are Yes, No, Not Applicable(N/A), and Pending Results	Facility		

Other Important Terms	<b>Definitions</b>
Consumption	For the purposes of this testing consumption means a fixture where the water is used for drinking water or food/formula preparation.
Non Commention	A fixture that is not used for drinking water or food preparation such as a laboratory sink or a mop sink in a locked custodial closet. MDH recommends that non-consumption fixtures
Non-Consumption	be labeled as not for drinking if they are not tested.
Active	A fixture currently able to be used.
Inactive	A fixture that has been taken out of service either temporarily or permanantly
First Draw	A type of water sample where the water has been stagnant for 8-18 hours before collecting a sample. The most common type of lead sample type.
Flushed	A type of water sample where the water has been allowed to run before collecting. Typically collected when investigating to source of lead or evaluating remediation options.
Initial	This is typically a first draw sample collected during a round of monitoring. A sample may be an initial-first draw or an initial-flushed
	This is typically collected if an initial sample collected during a round of sampling is 5ppb or more. Follow-up samples can be repeated first draw samples or flushed samples
Follow-up	depending on the type of follow-up activities conducted to reduce lead.