



December 11, 2024

Brian Arias  
Jeff-Lewis BOCES\_Watertown Central School  
District  
532 S. Massey Street  
Watertown, NY 13601

RE: Project: CASE MIDDLE SCOOOL  
Pace Project No.: 70324408

Dear Brian Arias:

Enclosed are the analytical results for sample(s) received by the laboratory on November 26, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Michelle Cohen  
michelle.cohen@pacelabs.com  
516-370-6000  
Project Manager

Enclosures

cc: Ray Filley, Jeff-Lewis BOCES\_Watertown Central School  
District  
Tiffany Oconnor, Jeff-Lewis BOCES\_Watertown Central  
School District  
Linda Shaw, Jeff-Lewis BOCES\_Watertown Central School  
District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## CERTIFICATIONS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

---

### **Pace Analytical Services, LLC - Melville, NY**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 1- KITCHEN 1		Lab ID: 70324408001	Collected: 11/20/24 07:20	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		12/09/24 16:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 2- KITCHEN 2		Lab ID: 70324408002	Collected: 11/20/24 07:21	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 16:27	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 3- KITCHEN 3		Lab ID: 70324408003	Collected: 11/20/24 07:22	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 16:29	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 4- KITCHEN 4		Lab ID: 70324408004	Collected: 11/20/24 07:23	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		12/09/24 16:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 5- DF LR5		Lab ID: 70324408005	Collected: 11/20/24 07:50	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 16:32	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 6-GYM		Lab ID: 70324408006	Collected: 11/20/24 07:35	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 16:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 7- MAIN OFFICE		Lab ID: 70324408007	Collected: 11/20/24 07:39	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		12/09/24 16:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 8- DF CLINIC		Lab ID: 70324408008	Collected: 11/20/24 07:36	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 16:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 9- CLINIC		Lab ID: 70324408009	Collected: 11/20/24 07:35	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		12/09/24 16:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 10- CAFE		Lab ID: 70324408010	Collected: 11/20/24 07:40	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 16:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 11- DF101		Lab ID: 70324408011	Collected: 11/20/24 07:41	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 16:47	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 12- R104		Lab ID: 70324408012	Collected: 11/20/24 07:40	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 16:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 13- R108		Lab ID: 70324408013	Collected: 11/20/24 07:45	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 16:59	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 14- DF LIBRARY		Lab ID: 70324408014	Collected: 11/20/24 08:02	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 17:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: 15- FACULTY RM 2ND FL    Lab ID: 70324408015    Collected: 11/20/24 08:04    Received: 11/26/24 08:00    Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/09/24 17:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 16- DF206		Lab ID: 70324408016	Collected: 11/20/24 08:05	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 17:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 17- DF301		Lab ID: 70324408017	Collected: 11/20/24 08:18	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 17:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 18- DF305		Lab ID: 70324408018	Collected: 11/20/24 08:18	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 17:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 19- HOME EC		Lab ID: 70324408019	Collected: 11/20/24 08:12	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		12/09/24 17:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 20- HOME EC		Lab ID: 70324408020	Collected: 11/20/24 08:12	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		12/09/24 17:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 21- HOME EC		Lab ID: 70324408021	Collected: 11/20/24 08:12	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 17:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 22- HOME EC		Lab ID: 70324408022	Collected: 11/20/24 08:13	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		12/09/24 17:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 23- DF 311		Lab ID: 70324408023	Collected: 11/20/24 08:10	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/09/24 17:18	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 24- DF BOYS+GIRLS 3RD FL Lab ID: 70324408024 Collected: 11/20/24 08:22 Received: 11/26/24 08:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/09/24 17:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 25- CONCESSION		Lab ID: 70324408025	Collected: 11/20/24 08:00	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		12/09/24 17:21	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 26- DF WRESTLING		Lab ID: 70324408026	Collected: 11/20/24 08:29	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.3</b>	ug/L	1.0	1		12/09/24 17:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 27- FACULTY CAFE 1ST FL Lab ID: 70324408027 Collected: 11/20/24 08:28 Received: 11/26/24 08:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		12/10/24 13:26	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: 28A- BOYS LOCKER DF      Lab ID: 70324408028      Collected: 11/20/24 07:51      Received: 11/26/24 08:00      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/10/24 13:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: 28B- BOYS LOCKER DF      Lab ID: 70324408029      Collected: 11/20/24 07:50      Received: 11/26/24 08:00      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/10/24 13:32	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 29A- GIRLS LOCKER DF Lab ID: 70324408030 Collected: 11/20/24 07:50 Received: 11/26/24 08:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/10/24 13:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: 29B- GIRLS LOCKER DF      Lab ID: 70324408031      Collected: 11/20/24 07:50      Received: 11/26/24 08:00      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>20.5</b>	ug/L	1.0	1		12/10/24 13:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 30- KITCHEN ISLAND SINK Lab ID: 70324408032 Collected: 11/20/24 07:55 Received: 11/26/24 08:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>2.2</b>	ug/L	1.0	1		12/10/24 13:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 31-KITCHEN CF		Lab ID: 70324408033	Collected: 11/20/24 07:57	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.2</b>	ug/L	1.0	1		12/10/24 13:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: 32- NURSE CLINIC</b>								
<b>Lab ID: 70324408034</b>								
Collected: 11/20/24 08:27								
Received: 11/26/24 08:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.1	ug/L	1.0	1		12/10/24 13:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 33- CLINIC EXAM RM 1	Lab ID: 70324408035	Collected: 11/20/24 08:25	Received: 11/26/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>4.7</b>	ug/L	1.0	1		12/10/24 13:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: 34- CLINIC EXAM RM 2      Lab ID: 70324408036      Collected: 11/20/24 08:25      Received: 11/26/24 08:00      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>13.2</b>	ug/L	1.0	1		12/10/24 13:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CASE MIDDLE SCHOOL

Pace Project No.: 70324408

Sample: 35- HOME CAREERS		Lab ID: 70324408037	Collected: 11/20/24 08:19	Received: 11/26/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>17.9</b>	ug/L	1.0	1		12/10/24 13:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: CASE MIDDLE SCOOL

Pace Project No.: 70324408

QC Batch:	374490	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70324408001, 70324408002, 70324408003, 70324408004, 70324408005, 70324408006, 70324408007, 70324408008, 70324408009, 70324408010		

METHOD BLANK:	1961128	Matrix:	Water
Associated Lab Samples:	70324408001, 70324408002, 70324408003, 70324408004, 70324408005, 70324408006, 70324408007, 70324408008, 70324408009, 70324408010		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/09/24 15:55	

LABORATORY CONTROL SAMPLE:		1961129				
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.0	102	85-115	

MATRIX SPIKE SAMPLE:		1961131					
Parameter	Units	70324400029 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	51.4	101	70-130	

MATRIX SPIKE SAMPLE:		1961133					
Parameter	Units	70324400030 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	7.5	50	56.3	98	70-130	

SAMPLE DUPLICATE:		1961130				
Parameter	Units	70324400029 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:		1961132				
Parameter	Units	70324400030 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	7.5	7.5	0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.





**QUALITY CONTROL DATA**

Project: CASE MIDDLE SCOOL

Pace Project No.: 70324408

QC Batch:	374493	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70324408011, 70324408012, 70324408013, 70324408014, 70324408015, 70324408016, 70324408017, 70324408018, 70324408019, 70324408020, 70324408021, 70324408022, 70324408023, 70324408024, 70324408025, 70324408026		

METHOD BLANK:	1961141	Matrix:	Water
Associated Lab Samples:	70324408011, 70324408012, 70324408013, 70324408014, 70324408015, 70324408016, 70324408017, 70324408018, 70324408019, 70324408020, 70324408021, 70324408022, 70324408023, 70324408024, 70324408025, 70324408026		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/09/24 16:44	

LABORATORY CONTROL SAMPLE:	1961142					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.6	103	85-115	

MATRIX SPIKE SAMPLE:	1961144						
Parameter	Units	70324408011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	49.1	97	70-130	

MATRIX SPIKE SAMPLE:	1961147						
Parameter	Units	70324408012 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	51.5	102	70-130	

SAMPLE DUPLICATE:	1961143				
Parameter	Units	70324408011 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	1961145				
Parameter	Units	70324408012 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: CASE MIDDLE SCOOL

Pace Project No.: 70324408

QC Batch:	374636	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70324408027, 70324408028, 70324408029, 70324408030, 70324408031, 70324408032, 70324408033, 70324408034, 70324408035, 70324408036, 70324408037		

METHOD BLANK:	1962078	Matrix:	Water
Associated Lab Samples:	70324408027, 70324408028, 70324408029, 70324408030, 70324408031, 70324408032, 70324408033, 70324408034, 70324408035, 70324408036, 70324408037		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/10/24 13:07	

LABORATORY CONTROL SAMPLE: 1962079						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.7	105	85-115	

MATRIX SPIKE SAMPLE: 1962081							
Parameter	Units	70326114002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	53.3	105	70-130	

MATRIX SPIKE SAMPLE: 1962083							
Parameter	Units	70326118002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.4	50	66.8	127	70-130	

SAMPLE DUPLICATE: 1962080					
Parameter	Units	70326114002 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1962082					
Parameter	Units	70326118002 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.4	3.4	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



## QUALIFIERS

Project: CASE MIDDLE SCOOOL

Pace Project No.: 70324408

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CASE MIDDLE SCOOL

Pace Project No.: 70324408

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70324408001	1- KITCHEN 1	EPA 200.8	374490		
70324408002	2- KITCHEN 2	EPA 200.8	374490		
70324408003	3- KITCHEN 3	EPA 200.8	374490		
70324408004	4- KITCHEN 4	EPA 200.8	374490		
70324408005	5- DF LR5	EPA 200.8	374490		
70324408006	6-GYM	EPA 200.8	374490		
70324408007	7- MAIN OFFICE	EPA 200.8	374490		
70324408008	8- DF CLINIC	EPA 200.8	374490		
70324408009	9- CLINIC	EPA 200.8	374490		
70324408010	10- CAFE	EPA 200.8	374490		
70324408011	11- DF101	EPA 200.8	374493		
70324408012	12- R104	EPA 200.8	374493		
70324408013	13- R108	EPA 200.8	374493		
70324408014	14- DF LIBRARY	EPA 200.8	374493		
70324408015	15- FACULTY RM 2ND FL	EPA 200.8	374493		
70324408016	16- DF206	EPA 200.8	374493		
70324408017	17- DF301	EPA 200.8	374493		
70324408018	18- DF305	EPA 200.8	374493		
70324408019	19- HOME EC	EPA 200.8	374493		
70324408020	20- HOME EC	EPA 200.8	374493		
70324408021	21- HOME EC	EPA 200.8	374493		
70324408022	22- HOME EC	EPA 200.8	374493		
70324408023	23- DF 311	EPA 200.8	374493		
70324408024	24- DF BOYS+GIRLS 3RD FL	EPA 200.8	374493		
70324408025	25- CONCESSION	EPA 200.8	374493		
70324408026	26- DF WRESTLING	EPA 200.8	374493		
70324408027	27- FACULTY CAFE 1ST FL	EPA 200.8	374636		
70324408028	28A- BOYS LOCKER DF	EPA 200.8	374636		
70324408029	28B- BOYS LOCKER DF	EPA 200.8	374636		
70324408030	29A- GIRLS LOCKER DF	EPA 200.8	374636		
70324408031	29B- GIRLS LOCKER DF	EPA 200.8	374636		
70324408032	30- KITCHEN ISLAND SINK	EPA 200.8	374636		
70324408033	31-KITCHEN CF	EPA 200.8	374636		
70324408034	32- NURSE CLINIC	EPA 200.8	374636		
70324408035	33- CLINIC EXAM RM 1	EPA 200.8	374636		
70324408036	34- CLINIC EXAM RM 2	EPA 200.8	374636		
70324408037	35- HOME CAREERS	EPA 200.8	374636		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

**CHAIN-OF-CUSTODY Analytical Request Document**  
Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

**WO#: 70324408**  
  
70324408

Company Name: **Jefferson Lewis BOCES, Watertown CSD**  
Street Address: **1351 Washington Street, Watertown NY 13601**  
Customer Project #: **08215607**  
Project Name: **CASE MID DUE SCHED**  
Site Collection Info/Facility ID (as applicable):

Contact/Report To: **Brian Arias**  
Phone #: **315-661-4351**  
E-Mail: **barias@watertowncsd.org**  
Cc E-Mail:  
Invoice To: **Brian Arias**  
Invoice E-Mail: **barias@watertowncsd.org**  
Purchase Order # (if applicable):  
Quote #:

Specify Container Size \*\*  
Identify Container Preservative Type\*\*\*  
Analysis Requested

Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) Encore, (8) TerraCore, (9) Other  
Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

County / State origin of sample(s): **New York**  
Regulatory Program (DW, RCRA, etc.) as applicable: **NY Lead in School DW**  
Rush (Pre-approval required):  
Field Filtered (if applicable): [ ] Yes [ ] No  
Date Results Requested: **Standard 10 business day**  
Analysis:

Customer Sample ID	Matrix *	Collected		Res. CL2	Number & Type of Containers	Preservation non-conformance identified for sample
		Comp / Grab	Time			
1- Kitchen 1	DW	G	11:20 12/21/20		1	
2- Kitchen 2			7:21			
3- Kitchen 3			7:22			
4- Kitchen 4			7:23			
5- DF LR'S			7:50			
6- gym			7:35			
7- main office			7:39			
8- DF clinic			7:36			
9- clinic			7:35			
10- cafe			7:40			

Additional Instructions from Pace\*:  
Collected By: **Thomas Rankin**  
Printed Name: **Thomas Rankin**  
Signature:  
Date/Time: **11/25 13:35**  
Received by/Company: **[Signature] Pace**  
Date/Time: **11/25 14:00**  
Received by/Company: **[Signature] Pace**  
Date/Time: **11/26 8:00**  
Received by/Company: **[Signature] Pace**  
Date/Time: **11/26 8:00**  
Received by/Company: **[Signature] Pace**  
Tracking Number: **13:35**  
Delivered by: [ ] In-Person [ ] Courier [ ] FedEx [ ] UPS [ ] Other  
Page: **13** of **18**

Company Name: **Jefferson Lewis BOCCES, Watertown CSD**  
 Street Address: **1351 Washington Street, Watertown NY 13601**

Customer Project #: **08217607**  
 Project Name: **CASE MIDDLE SCHOOL**

Site Collection Info/Facility ID (as applicable):

Time Zone Collected: [ ] AK [ ] MT [ ] CT [X] ET  
 Data Deliverables:  
 [ ] Level II [ ] Level III [ ] Level IV  
 [ ] EQUIS  
 [ ] Other

Regulatory Program (DW, RCRA, etc.) as applicable: **NY Lead in School DW**

Rush (Pre-approval required):  
 [ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other

Date Results Requested: **Standard 10 business day**

Field Filtered (# applicable): [ ] Yes [ ] No

Analyst:

DW PWSID # or WW Permit # as applicable:

County / State origin of sample(s): **New York**

Contact/Report To: **Brian Arias**

Phone #: **315-661-4351**

E-Mail: **barias@watertowncswd.org**

Cc E-Mail:

Invoice To: **Brian Arias**

Invoice E-Mail: **barias@watertowncswd.org**

Purchase Order # (if applicable):

Quote #:

**CHAIN-OF-CUSTODY Analytical Request Document**  
 Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields



Scan QR Code for instructions

Specify Container Size \*\*  
 Identify Container Preservative Type\*\*\*  
 Analysis Requested

\*\*Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) Encore, (8) TerraCore, (9) Other  
 \*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Soot, Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Proj. Mgr:  
**Randy Budhu**  
 AcctNum / Client ID:

Table #:  
 Profile / Template:  
 Prelog / Bottle Ord. ID:

Lab Use Only  
 Preservation non-conformance identified for sample.

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start) Date	Time	Composite End Date	Time	Res. CL2	Number & Type of Containers Plastic Glass	200.6 Drinking Water (Pb only)	Sample Comment
11- DF 101	DW	G	11/20/24	7:41				1	X	
12- R104				7:40						
13- R108				7:45						
14- DF LIBRARY				8:02						
15- Faculty Rm. 2hdA				8:04						
16- DF 206				8:05						
17- DF 301				8:18						
18- DF 305				8:18						
19- home ec				8:12						
20- home ec.				8:12						

Additional Instructions from Pace\*:  
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number:  
 Date/Time: 11/25 13:35  
 Date/Time: 11/26 4:00  
 Date/Time: 11/26 24:00  
 Delivered by: [ ] In. Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other  
 Page: 14 of 18

Collected By: Thomas Rankin  
 Printed Name: Thomas Rankin  
 Signature:

Received by/Company (Signature):  
 Received by/Company (Signature):  
 Received by/Company (Signature):  
 Received by/Company (Signature):

Date/Time: 11/24 13:35  
 Date/Time: 11/25 14:00  
 Date/Time: 11/26 03:00

Received by/Company (Signature):  
 Received by/Company (Signature):  
 Received by/Company (Signature):

Date/Time: 11/24 13:35  
 Date/Time: 11/25 14:00  
 Date/Time: 11/26 03:00

Received by/Company (Signature):  
 Received by/Company (Signature):  
 Received by/Company (Signature):

Date/Time: 11/24 13:35  
 Date/Time: 11/25 14:00  
 Date/Time: 11/26 03:00





# CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY - Affix Workorder/Login Label Here



Scan QR Code for instructions

Company Name: **Jefferson Lewis BOCES Watertown CSD**  
 Street Address: **1351 Washington Street, Watertown NY 13601**

Contact/Report To: **Brian Arias**  
 Phone #: **315-661-4351**  
 E-Mail: **barias@watertowncsd.org**

Customer Project #: **05215607**  
 Project Name: **CASE middle school**

Invoice To: **Brian Arias**  
 Invoice E-Mail: **barias@watertowncsd.org**

Purchase Order # (if applicable):  
 Quote #:

County / State origin of sample(s): **New York**

**Rush (Pre-approval required):**  
 [ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other \_\_\_\_\_  
**Date Results Requested:** Standard 10 business day

Field Filtered (if applicable): [ ] Yes [ ] No  
 Analysis:

\* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Collected		Res. CL2	Number & Type of Containers	Preservation non-conformance identified for sample.
		Comp / Grab	(or Composite Start) Time			
21- Home ec.	DW	G	11/20/24 8:12		1	
22- Home ec.			8:13			
23- DF 311			8:10			
24- DF boys + girls 3rd fl.			8:22			
25- Concession			8:00			
26- DF Wrestling			8:29			
27- Faculty cafe 1st fl.			8:28			
28A- Boys Locker DF			7:51			
28B- Boys Locker DF			7:50			
29A- Girls Locker DF			7:50			

Additional Instructions from Pace:  
 Collected By: Thomas Rankin  
 Printed Name: Thomas Rankin  
 Signature:

Relinquished by/Company (Signature)	Date/Time	Relinquished by/Company (Signature)	Date/Time
<i>[Signature]</i>	11/26/24 13:35	<i>[Signature]</i>	11/26/24 13:35
<i>[Signature]</i>	11/25/24 14:00	<i>[Signature]</i>	11/26/24 4:20
<i>[Signature]</i>	11/26/24 9:30	<i>[Signature]</i>	11/26/24 8:00

Customer Remarks / Special Conditions / Possible Hazards:  
 Lead

Tracking Number: 13135  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other  
 Page: 15 of 18

Company Name: **Jefferson Lewis BOCES, Watertown CSD**  
 Street Address: **1351 Washington Street, Watertown NY 13601**

Customer Project #: **08215607**  
 Project Name: **CBE MIDDLE SCHOOL**

Site Collection Info/Facility ID (as applicable):

Contact/Report To: **Brian Arias**  
 Phone #: **315-661-4351**  
 E-Mail: **barias@watertowncso.org**  
 Cc E-Mail:

Invoice To: **Brian Arias**  
 Invoice E-Mail: **barias@watertowncso.org**

Purchase Order # (if applicable):  
 Quote #:

County / State origin of sample(s): **New York**

Regulatory Program (DW, RCRA, etc.) as applicable: **NY Lead in School DW**  
 Rush (Pre-approval required):  
 DW PWSID # or WW Permit # as applicable:  
 Date Results Requested: **Standard 10 business day**  
 Field Filtered (if applicable): [ ] Yes [ ] No  
 Analysis:

\* Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Biossary (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected		Composite End Date	Time	Res. CL2	Number & Type of Containers		Sample Comment
			Date	Time				Plastic	Glass	
29B-GIRLS LOCKER DF	DW	G	11/20/24	7:50				1		
30-KITCHEN ISLAND SINK				7:55						
31-KITCHEN ICE				7:57						
32-NURSE CLINIC KIBLER				8:27						
33-CLINIC EXAM ROOM 1				8:25						
34-CLINIC EXAM RM 2				8:25						
35-HOME CARE'S				8:19						

200.8 Drinking Water (Pb only) X

LAB USE ONLY - Affix Workorder/Login Label Here



Scan QR Code for instructions

Specify Container Size \*\*  
 Identify Container Preservative Type\*\*\*  
 Analysis Requested

Proj. Mgr: **Randy Budhu**  
 AcctNum / Client ID:  
 Table #:  
 Profile / Template:  
 Prelog / Bottle Ord. ID:  
 Lab Use Only  
 Preservation non-conformance identified for sample.

Customer Remarks / Special Conditions / Possible Hazards:  
 Lead  
 Collected By: **Thomas Rankin**  
 Signature:  
 Received by/Company: (Signature) **Thomas Rankin Pace**  
 Date/Time: **11/25 13:35**  
 Received by/Company: (Signature) **Thomas Rankin Pace**  
 Date/Time: **11/25 14:00**  
 Received by/Company: (Signature) **Thomas Rankin Pace**  
 Date/Time: **11/26 8:00**  
 Received by/Company: (Signature)

Additional Instructions from Pace\*:  
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)  
 Tracking Number: **13135**  
 Date/Time: **11/25 13:35**  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other  
 Date/Time: **11/26 4:00**  
 Date/Time: **11/26 24:00**  
 Page: **16** of **18**





**WO#: 70324408**

Client Name: WATERTOWN

Project #

PM: MC1 Due Date: 12/12/24  
 CLIENT: WATERTOWN

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pac  Other

Tracking #:

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No Temperature Blank Present:  Yes  No  
 Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other Type of Ice: Wet Blue  None

Thermometer Used: TH211 Correction Factor: +0  Samples on ice, cooling process has begun  
 Cooler Temperature(°C): 16.8 Cooler Temperature Corrected(°C): 16.8 Date/Time 5035A kits placed in freezer \_\_\_\_\_

Temp should be above freezing to 6.0°C

USDA Regulated Soil ( N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: ABB 11/26/24

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: SL <input checked="" type="checkbox"/> WT <input type="checkbox"/> OIL OTHER	

Date and Initials of person checking preservation: ABB 11/26/24

All containers needing preservation have been pH paper Lot # <u>213624</u> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH>12 Cyanide)	Sample #
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #	
Residual chlorine strips Lot #	
SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15. Positive for Sulfide? Y N
Lead Acetate Strips Lot #	
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted: \_\_\_\_\_

Date/Time: \_\_\_\_\_

Comments/ Resolution: \_\_\_\_\_

\* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.