



COLUMBIA PUBLIC SCHOOLS
COLUMBIA, MO
LEAD AND COPPER MONITORING
SUMMARY REPORT

DATE: JANUARY 6, 2022

FACILITY NAME: **ROCK BRIDGE HIGH SCHOOL**

A. SAMPLE COLLECTION

- | | |
|--|--------|
| 1. NUMBER OF SAMPLES COLLECTED AT THIS FACILITY | 72 |
| 2. PERCENTAGE OF SAMPLES BELOW COPPER ACTION LIMITS | 100.0% |
| 1. COPPER ACTION LIMIT = 1,300 UG/ | |
| 3. PERCENTAGE OF SAMPLES BELOW LEAD ACTION LIMITS | 100.0% |
| 1. LEAD ACTION LIMIT = 15 UG/L | |
| (The requirement in the USEPA Lead and Copper Rule for public water supplies is 90% passing) | |

B. SAMPLE EXCEEDANCE

- | | |
|--|---|
| 1. NUMBER OF SAMPLES EXCEEDING COPPER ACTION LIMIT | 0 |
| 2. NUMBER OF SAMPLES EXCEEDING LEAD ACTION LIMIT | 0 |

C. CONCLUSION

This facility meets the (recommended) requirements of the United States Environmental Protection Agency (USEPA) and the published Lead and Copper Rule (LCR) of 1991 (reference: 40 CFR Part 141 Subpart I). Public Run Water Suppliers must comply with the USEPA law and the LCR. Columbia Water & Light is the publicly run water utility that serves this school.

Initially failed tests were resampled using the first flush method and tested for verification. Should the laboratory analysis reveal results that exceed the LCR action limits, you can utilize the recommendations within the LCR to address those specific locations. They include but are not limited to: flushing prior to use (make it a practice to run the water at each tap before use), repairing and/or replacing fixtures and/or piping and by not using the water for consumption. All are recommended by the Lead and Copper Rule.

Although the Lead and Copper Rule may not directly apply to Columbia Public Schools and each of its schools or support buildings that are part of the 2020 City of Columbia Water Quality Assessment Report; it is a common practice for experts in the field and members of the known industry to use the standard as a guideline for water assessment studies.

Prepared By:

Joshua D. Lehmen, PE



August 19, 2021

Josh Lehmen
Engineering Surveys & Services
1113 Fay Street
Columbia, MO 65201

RE: L14571

Dear Josh Lehmen:

Please find enclosed the analytical results for the **72** sample(s) the laboratory received on **8/2/21 12:40 pm** and logged in under work order **EG06158**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Director of Client Services, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lgrant@pdclab.com.

Sincerely,

Erin Lane
Project Manager



**SAMPLE RECEIPT CHECK LIST****Items not applicable will be marked as in compliance**

Work Order EG06158

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
NO	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
NO	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
NO	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: EG06158-01
Name: 1. Hall by 141
Alias: RBHS-H141-EWC-1

Sampled: 07/29/21 07:20
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	160	ug/L		1300	08/06/21 11:14	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 11:14	sjw	EPA 200.8 REV 5.4

Sample: EG06158-02
Name: 2. Training Room
Alias: RBHS-115-CF-1

Sampled: 07/29/21 07:20
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	120	ug/L		1300	08/06/21 11:16	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 11:16	sjw	EPA 200.8 REV 5.4

Sample: EG06158-03
Name: 3. Girls Locker Room
Alias: RBHS-112-EWC-2

Sampled: 07/29/21 07:10
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	160	ug/L		1300	08/06/21 11:17	sjw	EPA 200.8 REV 5.4
Lead	32	ug/L		**15	08/06/21 11:17	sjw	EPA 200.8 REV 5.4

Sample: EG06158-04
Name: 4. Boys Locker Room
Alias: RBHS-113-EWC-2

Sampled: 07/29/21 07:10
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	330	ug/L		1300	08/06/21 11:19	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 11:19	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-05
Name: 5. Hall by 100
Alias: RBHS-H100-EWC-4

Sampled: 07/29/21 07:08
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	170	ug/L		1300	08/06/21 11:28	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 11:28	sjw	EPA 200.8 REV 5.4

Sample: EG06158-06
Name: 6. Room 103
Alias: RBHS-102-CF-2

Sampled: 07/29/21 07:00
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	160	ug/L		1300	08/06/21 11:29	sjw	EPA 200.8 REV 5.4
Lead	3.4	ug/L		15	08/06/21 11:29	sjw	EPA 200.8 REV 5.4

Sample: EG06158-07
Name: 7. Room 103
Alias: RBHS-101-CF-3

Sampled: 07/29/21 07:00
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	250	ug/L		1300	08/06/21 11:31	sjw	EPA 200.8 REV 5.4
Lead	18	ug/L		**15	08/06/21 11:31	sjw	EPA 200.8 REV 5.4

Sample: EG06158-08
Name: 8. Room 103
Alias: RBHS-103-CF-4

Sampled: 07/29/21 07:00
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	160	ug/L		1300	08/06/21 11:32	sjw	EPA 200.8 REV 5.4
Lead	6.9	ug/L		15	08/06/21 11:32	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-09
Name: 9. Room 103
Alias: RBHS-103-CF-5

Sampled: 07/29/21 07:00
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	130	ug/L		1300	08/06/21 11:34	sjw	EPA 200.8 REV 5.4
Lead	3.2	ug/L		15	08/06/21 11:34	sjw	EPA 200.8 REV 5.4

Sample: EG06158-10
Name: 10. Room 103
Alias: RBHS-103-CF-6

Sampled: 07/29/21 07:00
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	190	ug/L		1300	08/06/21 11:35	sjw	EPA 200.8 REV 5.4
Lead	4.5	ug/L		15	08/06/21 11:35	sjw	EPA 200.8 REV 5.4

Sample: EG06158-11
Name: 11. Hall by 126
Alias: RBHS-H126-EWC-5

Sampled: 07/29/21 07:00
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	260	ug/L		1300	08/06/21 11:37	sjw	EPA 200.8 REV 5.4
Lead	1.9	ug/L		15	08/06/21 11:37	sjw	EPA 200.8 REV 5.4

Sample: EG06158-12
Name: 12. Hall by 127
Alias: RBHS-H127-EWC-6

Sampled: 07/29/21 07:00
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	450	ug/L		1300	08/06/21 11:38	sjw	EPA 200.8 REV 5.4
Lead	4.2	ug/L		15	08/06/21 11:38	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-13
Name: 13. Room 349
Alias: RBHS-349-CF-7

Sampled: 07/29/21 05:45
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	460	ug/L		1300	08/06/21 12:16	sjw	EPA 200.8 REV 5.4
Lead	5.7	ug/L		15	08/06/21 12:16	sjw	EPA 200.8 REV 5.4

Sample: EG06158-14
Name: 14. Room 349
Alias: RBHS-349-CF-8

Sampled: 07/29/21 05:45
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	230	ug/L		1300	08/06/21 12:17	sjw	EPA 200.8 REV 5.4
Lead	2.6	ug/L		15	08/06/21 12:17	sjw	EPA 200.8 REV 5.4

Sample: EG06158-15
Name: 15. Room 349
Alias: RBHS-349-CF-9

Sampled: 07/29/21 05:45
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	150	ug/L		1300	08/06/21 12:19	sjw	EPA 200.8 REV 5.4
Lead	1.6	ug/L		15	08/06/21 12:19	sjw	EPA 200.8 REV 5.4

Sample: EG06158-16
Name: 16. Room 348
Alias: RBHS-348-CF-10

Sampled: 07/29/21 05:50
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	1100	ug/L		1300	08/06/21 12:20	sjw	EPA 200.8 REV 5.4
Lead	7.3	ug/L		15	08/06/21 12:20	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-17
Name: 17. Room 347
Alias: RBHS-347-CF-11

Sampled: 07/29/21 05:55
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	390	ug/L		1300	08/06/21 12:22	sjw	EPA 200.8 REV 5.4
Lead	1.6	ug/L		15	08/06/21 12:22	sjw	EPA 200.8 REV 5.4

Sample: EG06158-18
Name: 18. Room 347
Alias: RBHS-347-CF-12

Sampled: 07/29/21 05:55
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	160	ug/L		1300	08/06/21 12:23	sjw	EPA 200.8 REV 5.4
Lead	1.2	ug/L		15	08/06/21 12:23	sjw	EPA 200.8 REV 5.4

Sample: EG06158-19
Name: 19. Room 347
Alias: RBHS-347-CF-13

Sampled: 07/29/21 05:55
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	460	ug/L		1300	08/06/21 12:25	sjw	EPA 200.8 REV 5.4
Lead	5.8	ug/L		15	08/06/21 12:25	sjw	EPA 200.8 REV 5.4

Sample: EG06158-20
Name: 20. Room 345
Alias: RBHS-345-CF-14

Sampled: 07/29/21 06:00
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	350	ug/L		1300	08/06/21 12:26	sjw	EPA 200.8 REV 5.4
Lead	1.2	ug/L		15	08/06/21 12:26	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-21
Name: 21. Room 345
Alias: RBHS-345-CF-15

Sampled: 07/29/21 06:00
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	390	ug/L		1300	08/06/21 12:35	sjw	EPA 200.8 REV 5.4
Lead	1.5	ug/L		15	08/06/21 12:35	sjw	EPA 200.8 REV 5.4

Sample: EG06158-22
Name: 22. Room 345
Alias: RBHS-345-CF-16

Sampled: 07/29/21 06:00
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	140	ug/L		1300	08/06/21 12:37	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 12:37	sjw	EPA 200.8 REV 5.4

Sample: EG06158-23
Name: 23. Room 344
Alias: RBHS-344-CF-17

Sampled: 07/29/21 06:05
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	460	ug/L		1300	08/06/21 12:38	sjw	EPA 200.8 REV 5.4
Lead	1.8	ug/L		15	08/06/21 12:38	sjw	EPA 200.8 REV 5.4

Sample: EG06158-24
Name: 24. Room 344
Alias: RBHS-344-CF-18

Sampled: 07/29/21 06:05
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	300	ug/L		1300	08/06/21 12:40	sjw	EPA 200.8 REV 5.4
Lead	1.6	ug/L		15	08/06/21 12:40	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-25
Name: 25. Room 344
Alias: RBHS-344-CF-19

Sampled: 07/29/21 06:05
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	540	ug/L		1300	08/06/21 12:41	sjw	EPA 200.8 REV 5.4
Lead	4.1	ug/L		15	08/06/21 12:41	sjw	EPA 200.8 REV 5.4

Sample: EG06158-26
Name: 26. Room 245
Alias: RBHS-245-CF-20

Sampled: 07/29/21 06:20
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	340	ug/L		1300	08/06/21 12:43	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 12:43	sjw	EPA 200.8 REV 5.4

Sample: EG06158-27
Name: 27. Room 245
Alias: RBHS-245-CF-21

Sampled: 07/29/21 06:20
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	260	ug/L		1300	08/06/21 12:44	sjw	EPA 200.8 REV 5.4
Lead	1.2	ug/L		15	08/06/21 12:44	sjw	EPA 200.8 REV 5.4

Sample: EG06158-28
Name: 28. Room 245
Alias: RBHS-245-CF-22

Sampled: 07/29/21 06:20
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	430	ug/L		1300	08/06/21 12:46	sjw	EPA 200.8 REV 5.4
Lead	15	ug/L		15	08/06/21 12:46	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-29
Name: 29. Room 244
Alias: RBHS-244-CF-23

Sampled: 07/29/21 06:25
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	230	ug/L		1300	08/06/21 12:55	sjw	EPA 200.8 REV 5.4
Lead	4.6	ug/L		15	08/06/21 12:55	sjw	EPA 200.8 REV 5.4

Sample: EG06158-30
Name: 30. Room 244
Alias: RBHS-244-CF-24

Sampled: 07/29/21 06:25
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	260	ug/L		1300	08/06/21 12:57	sjw	EPA 200.8 REV 5.4
Lead	5.2	ug/L		15	08/06/21 12:57	sjw	EPA 200.8 REV 5.4

Sample: EG06158-31
Name: 31. Room 244
Alias: RBHS-244-CF-25

Sampled: 07/29/21 06:25
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	530	ug/L		1300	08/06/21 12:58	sjw	EPA 200.8 REV 5.4
Lead	30	ug/L		**15	08/06/21 12:58	sjw	EPA 200.8 REV 5.4

Sample: EG06158-32
Name: 32. Room 243
Alias: RBHS-243-CF-26

Sampled: 07/29/21 06:30
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	330	ug/L		1300	08/06/21 12:59	sjw	EPA 200.8 REV 5.4
Lead	3.3	ug/L		15	08/06/21 12:59	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-33
Name: 33. Room 242
Alias: RBHS-242-CF-27

Sampled: 07/29/21 06:35
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	240	ug/L		1300	08/06/21 13:01	sjw	EPA 200.8 REV 5.4
Lead	9.4	ug/L		15	08/06/21 13:01	sjw	EPA 200.8 REV 5.4

Sample: EG06158-34
Name: 34. Room 242
Alias: RBHS-242-CF-28

Sampled: 07/29/21 06:35
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	440	ug/L		1300	08/06/21 13:02	sjw	EPA 200.8 REV 5.4
Lead	9.9	ug/L		15	08/06/21 13:02	sjw	EPA 200.8 REV 5.4

Sample: EG06158-35
Name: 35. Room 242
Alias: RBHS242-CF-29

Sampled: 07/29/21 06:35
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	280	ug/L		1300	08/06/21 13:04	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 13:04	sjw	EPA 200.8 REV 5.4

Sample: EG06158-36
Name: 36. Hall by 232
Alias: RBHS-H232-EWC-7

Sampled: 07/29/21 06:45
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	130	ug/L		1300	08/06/21 13:05	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 13:05	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-37
Name: 37. Room 232
Alias: RBHS-232-CF-30

Sampled: 07/29/21 06:45
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	330	ug/L		1300	08/06/21 13:24	sjw	EPA 200.8 REV 5.4
Lead	2.7	ug/L		15	08/06/21 13:24	sjw	EPA 200.8 REV 5.4

Sample: EG06158-38
Name: 38. Hall by 216
Alias: RBHS-H216-EWC-8

Sampled: 07/29/21 06:45
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	180	ug/L		1300	08/06/21 13:26	sjw	EPA 200.8 REV 5.4
Lead	1.8	ug/L		15	08/06/21 13:26	sjw	EPA 200.8 REV 5.4

Sample: EG06158-39
Name: 39. Hall by 224
Alias: RBHS-H224-EWC-9

Sampled: 07/29/21 06:50
Received: 07/30/21 15:08
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	170	ug/L		1300	08/06/21 13:27	sjw	EPA 200.8 REV 5.4
Lead	2.2	ug/L		15	08/06/21 13:27	sjw	EPA 200.8 REV 5.4

Sample: EG06158-40
Name: 40.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 05:40
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	280	ug/L		1300	08/06/21 13:29	sjw	EPA 200.8 REV 5.4
Lead	13	ug/L		15	08/06/21 13:29	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-41
Name: 41.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 05:40
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	300	ug/L		1300	08/06/21 13:30	sjw	EPA 200.8 REV 5.4
Lead	9.6	ug/L		15	08/06/21 13:30	sjw	EPA 200.8 REV 5.4

Sample: EG06158-42
Name: 42.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 05:40
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	340	ug/L		1300	08/06/21 13:32	sjw	EPA 200.8 REV 5.4
Lead	20	ug/L		**15	08/06/21 13:32	sjw	EPA 200.8 REV 5.4

Sample: EG06158-43
Name: 43.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 05:30
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	200	ug/L		1300	08/06/21 13:33	sjw	EPA 200.8 REV 5.4
Lead	12	ug/L		15	08/06/21 13:33	sjw	EPA 200.8 REV 5.4

Sample: EG06158-44
Name: 44.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 05:12
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	330	ug/L		1300	08/06/21 13:34	sjw	EPA 200.8 REV 5.4
Lead	5.2	ug/L		15	08/06/21 13:34	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-45
Name: 45.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 05:12
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	250	ug/L		1300	08/06/21 13:44	sjw	EPA 200.8 REV 5.4
Lead	6.6	ug/L		15	08/06/21 13:44	sjw	EPA 200.8 REV 5.4

Sample: EG06158-46
Name: 46.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 05:12
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	260	ug/L		1300	08/06/21 13:45	sjw	EPA 200.8 REV 5.4
Lead	17	ug/L		**15	08/06/21 13:45	sjw	EPA 200.8 REV 5.4

Sample: EG06158-47
Name: 47.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 05:10
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	970	ug/L		1300	08/06/21 13:47	sjw	EPA 200.8 REV 5.4
Lead	23	ug/L		**15	08/06/21 13:47	sjw	EPA 200.8 REV 5.4

Sample: EG06158-48
Name: 48.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 05:10
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	1000	ug/L		1300	08/06/21 13:48	sjw	EPA 200.8 REV 5.4
Lead	35	ug/L		**15	08/06/21 13:48	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-49
Name: 49.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 05:10
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	370	ug/L		1300	08/06/21 13:50	sjw	EPA 200.8 REV 5.4
Lead	11	ug/L		15	08/06/21 13:50	sjw	EPA 200.8 REV 5.4

Sample: EG06158-50
Name: 50.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 05:00
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	180	ug/L		1300	08/06/21 13:51	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 13:51	sjw	EPA 200.8 REV 5.4

Sample: EG06158-51
Name: 51.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:55
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	190	ug/L		1300	08/06/21 13:53	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 13:53	sjw	EPA 200.8 REV 5.4

Sample: EG06158-52
Name: 52.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:45
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	130	ug/L		1300	08/06/21 13:54	sjw	EPA 200.8 REV 5.4
Lead	25	ug/L		**15	08/06/21 13:54	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-53
Name: 53.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:45
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	170	ug/L		1300	08/06/21 14:03	sjw	EPA 200.8 REV 5.4
Lead	32	ug/L		**15	08/06/21 14:03	sjw	EPA 200.8 REV 5.4

Sample: EG06158-54
Name: 54.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:45
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	120	ug/L		1300	08/06/21 14:05	sjw	EPA 200.8 REV 5.4
Lead	11	ug/L		15	08/06/21 14:05	sjw	EPA 200.8 REV 5.4

Sample: EG06158-55
Name: 55.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:40
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	220	ug/L		1300	08/06/21 14:06	sjw	EPA 200.8 REV 5.4
Lead	9.2	ug/L		15	08/06/21 14:06	sjw	EPA 200.8 REV 5.4

Sample: EG06158-56
Name: 56.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:40
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	300	ug/L		1300	08/06/21 14:08	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 14:08	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-57
Name: 57.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:35
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	180	ug/L		1300	08/06/21 14:09	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 14:09	sjw	EPA 200.8 REV 5.4

Sample: EG06158-58
Name: 58.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:35
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	14	ug/L		1300	08/06/21 14:11	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 14:11	sjw	EPA 200.8 REV 5.4

Sample: EG06158-59
Name: 59.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:28
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	200	ug/L		1300	08/06/21 14:12	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 14:12	sjw	EPA 200.8 REV 5.4

Sample: EG06158-60
Name: 60.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:25
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	200	ug/L		1300	08/06/21 14:14	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 14:14	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-61
Name: 61.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:20
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	160	ug/L		1300	08/06/21 14:23	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 14:23	sjw	EPA 200.8 REV 5.4

Sample: EG06158-62
Name: 62.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:17
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	180	ug/L		1300	08/06/21 14:24	sjw	EPA 200.8 REV 5.4
Lead	5.1	ug/L		15	08/06/21 14:24	sjw	EPA 200.8 REV 5.4

Sample: EG06158-63
Name: 63.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:17
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	91	ug/L		1300	08/06/21 14:26	sjw	EPA 200.8 REV 5.4
Lead	19	ug/L		**15	08/06/21 14:26	sjw	EPA 200.8 REV 5.4

Sample: EG06158-64
Name: 64.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:13
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	170	ug/L		1300	08/06/21 14:27	sjw	EPA 200.8 REV 5.4
Lead	1.5	ug/L		15	08/06/21 14:27	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-65
Name: 65.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:10
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	270	ug/L		1300	08/06/21 14:29	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 14:29	sjw	EPA 200.8 REV 5.4

Sample: EG06158-66
Name: 66.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:07
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	170	ug/L		1300	08/06/21 14:30	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 14:30	sjw	EPA 200.8 REV 5.4

Sample: EG06158-67
Name: 67.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:05
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	210	ug/L		1300	08/06/21 14:32	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 14:32	sjw	EPA 200.8 REV 5.4

Sample: EG06158-68
Name: 68.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 04:00
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	220	ug/L		1300	08/06/21 14:33	sjw	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/06/21 14:33	sjw	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EG06158-69
Name: 69.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 00:00
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
<u>Total Metals - PIA</u>							
Copper	570	ug/L		1300	08/06/21 15:04	sjw	EPA 200.8 REV 5.4
Lead	1.5	ug/L		15	08/06/21 15:04	sjw	EPA 200.8 REV 5.4

Sample: EG06158-72
Name: 72.
Matrix: Drinking Water - Regular Sample

Sampled: 07/29/21 05:10
Received: 07/30/21 15:08

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
<u>Total Metals - PIA</u>							
Copper	190	ug/L		1300	08/06/21 15:05	sjw	EPA 200.8 REV 5.4
Lead	1.1	ug/L		15	08/06/21 15:05	sjw	EPA 200.8 REV 5.4



NOTES

Specifications regarding method revisions and method modifications used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Erin Lane, Project Manager





CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

ALLI TDAV 2210 DEVE

PAGE

05

21217074

Location:	Rock Bridge High School
Sample Date:	7/29/2021
Sample Time:	Various
Sampled By:	Kyle Vidusic

Sample No.	Coding System	Description	Sample Collected
1	RBHS-H141-EWC-1	Hall by 141 - Electric Water Cooler	Yes
2	RBHS-115-CF-1	Training Room - Classroom Faucet	Yes
3	RBHS-112-EWC-2	Girls Locker Room - Electric Water Cooler	Yes
4	RBHS-113-EWC-3	Boys Locker Room - Electric Water Cooler	Yes
5	RBHS-H100-EWC-4	Hall by 100 - Electric Water Cooler	Yes
6	RBHS-102-CF-2	Room 103 - Classroom Faucet	Yes
7	RBHS-101-CF-3	Room 103 - Classroom Faucet	Yes
8	RBHS-103-CF-4	Room 103 - Classroom Faucet	Yes
9	RBHS-103-CF-5	Room 103 - Classroom Faucet	Yes
10	RBHS-103-CF-6	Room 103 - Classroom Faucet	Yes
11	RBHS-H126-EWC-5	Hall by 126 - Electric Water Cooler	Yes
12	RBHS-H127-EWC-6	Hall by 127 - Electric Water Cooler	Yes
13	RBHS-349-CF-7	Room 349 - Classroom Faucet	Yes
14	RBHS-349-CF-8	Room 349 - Classroom Faucet	Yes
15	RBHS-349-CF-9	Room 349 - Classroom Faucet	Yes
16	RBHS-348-CF-10	Room 348 - Classroom Faucet	Yes
17	RBHS-347-CF-11	Room 347 - Classroom Faucet	Yes
18	RBHS-347-CF-12	Room 347 - Classroom Faucet	Yes
19	RBHS-347-CF-13	Room 347 - Classroom Faucet	Yes
20	RBHS-345-CF-14	Room 345 - Classroom Faucet	Yes
21	RBHS-345-CF-15	Room 345 - Classroom Faucet	Yes
22	RBHS-345-CF-16	Room 345 - Classroom Faucet	Yes
23	RBHS-344-CF-17	Room 344 - Classroom Faucet	Yes
24	RBHS-344-CF-18	Room 344 - Classroom Faucet	Yes
25	RBHS-344-CF-19	Room 344 - Classroom Faucet	Yes
26	RBHS-245-CF-20	Room 245 - Classroom Faucet	Yes
27	RBHS-245-CF-21	Room 245 - Classroom Faucet	Yes
28	RBHS-245-CF-22	Room 245 - Classroom Faucet	Yes
29	RBHS-244-CF-23	Room 244 - Classroom Faucet	Yes
30	RBHS-244-CF-24	Room 244 - Classroom Faucet	Yes
31	RBHS-244-CF-25	Room 244 - Classroom Faucet	Yes
32	RBHS-243-CF-26	Room 243 - Classroom Faucet	Yes
33	RBHS-242-CF-27	Room 242 - Classroom Faucet	Yes
34	RBHS-242-CF-28	Room 242 - Classroom Faucet	Yes
35	RBHS-242-CF-29	Room 242 - Classroom Faucet	Yes
36	RBHS-H232-EWC-7	Hall by 232 - Electric Water Cooler	Yes
37	RBHS-232-CF-30	Room 232 - Classroom Faucet	Yes
38	RBHS-H216-EWC-8	Hall by 216 - Electric Water Cooler	Yes
39	RBHS-H224-EWC-9	Hall by 224 - Electric Water Cooler	Yes

40	RBHS-339-CF-31	Room 339 - Classroom Faucet	Yes
41	RBHS-339-CF-32	Room 339 - Classroom Faucet	Yes
42	RBHS-339-CF-33	Room 339 - Classroom Faucet	Yes
43	RBHS-338-CF-34	Room 338 - Classroom Faucet	Yes
44	RBHS-337-CF-35	Room 337 - Classroom Faucet	Yes
45	RBHS-337-CF-36	Room 337 - Classroom Faucet	Yes
46	RBHS-337-CF-37	Room 337 - Classroom Faucet	Yes
47	RBHS-336-CF-38	Room 336 - Classroom Faucet	Yes
48	RBHS-336-CF-39	Room 336 - Classroom Faucet	Yes
49	RBHS-336-CF-40	Room 336 - Classroom Faucet	Yes
50	RBHS-H336-EWC-10	Hall by 336 - Electric Water Cooler	Yes
51	RBHS-333-NSF-1	Nurses Office Sink	Yes
52	RBHS-319-CF-41	Room 319 - Classroom Faucet	Yes
53	RBHS-318-CF-42	Room 318 - Classroom Faucet	Yes
54	RBHS-317-CF-43	Room 317 - Classroom Faucet	Yes
55	RBHS-H315-EWC-11	Hall by 315 - Electric Water Cooler	Yes
56	RBHS-H309-EWC-12	Hall by 309 - Electric Water Cooler	Yes
57	RBHS-309-TFL-1	Teachers Lounge Faucet	Yes
58	RBHS-309-TFL-2	Teachers Lounge Fridge	Yes
59	RBHS-307-CF-44	Room 307 Kitchenet - Classroom Faucet	Yes
60	RBHS-COM-EWC-13	In Commons - Electric Water Cooler	Yes
61	RBHS-GYM-EWC-14	Hall by Aux Gym - Electric Water Cooler	Yes
62	RBHS-KIT-KF-1	Kitchen Faucet North	Yes
63	RBHS-KIT-KF-2	Kitchen Faucet South	Yes
64	RBHS-CON-KF-3	Concession Stand in Building	Yes
65	RBHS-SER-EWC-15	Hall by Serving Area - Electric Water Cooler	Yes
66	RBHS-H400-EWC-16	Hall by 400 - Electric Water Cooler	Yes
67	RBHS-400-EWC-17	Room 400 - Electric Water Cooler	Yes
68	RBHS-404-EWC-18	Room 404 - Electric Water Cooler	Yes
69	RBHS-FTB-KF-4	Football Concession Stand	Yes
70	RBHS-FTB-DWF-1	Football Concession Stand	Yes
71	RBHS-BSB-KF-5	Baseball Concession Stand	Yes
72	RBHS-H119-EWC-19	Hall by Room 119 - Electric Water Cooler	Yes
73	RBHS-		
74	RBHS-		
75	RBHS-		
76	RBHS-		
77	RBHS-		
78	RBHS-		
79	RBHS-		
80	RBHS-		



"FIRST FLUSH" RESAMPLING

ANALYTICAL RESULTS

Sample: EL04058-77
Name: 3. Girls Locker Room
Alias: RBHS-112-EWC-2

Sampled: 12/15/21 05:59
Received: 12/20/21 15:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Copper	110	ug/L		01/06/22 09:26	1	3.0	01/06/22 13:02	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		01/06/22 09:26	1	1.0	01/06/22 13:02	KMC	EPA 200.8 REV 5.4

Sample: EL04058-78
Name: 7. Room 103
Alias: RBHS-101-CF-3

Sampled: 12/15/21 06:00
Received: 12/20/21 15:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Copper	84	ug/L		01/06/22 09:26	1	3.0	01/06/22 13:03	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		01/06/22 09:26	1	1.0	01/06/22 13:03	KMC	EPA 200.8 REV 5.4

Sample: EL04058-79
Name: 31. Room 244
Alias: RBHS-244-CF-25

Sampled: 12/15/21 06:01
Received: 12/20/21 15:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Copper	400	ug/L		01/06/22 09:26	1	3.0	01/06/22 13:05	KMC	EPA 200.8 REV 5.4
Lead	4.1	ug/L		01/06/22 09:26	1	1.0	01/06/22 13:05	KMC	EPA 200.8 REV 5.4

Sample: EL04058-80
Name: 42. Room 339
Alias: RBHS-339-CF-33

Sampled: 12/15/21 05:59
Received: 12/20/21 15:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Copper	860	ug/L		01/06/22 09:26	1	3.0	01/06/22 13:06	KMC	EPA 200.8 REV 5.4
Lead	9.8	ug/L		01/06/22 09:26	1	1.0	01/06/22 13:06	KMC	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EL04058-81
Name: 46. Room 337
Alias: RBHS-337-CF-37

Sampled: 12/15/21 05:58
Received: 12/20/21 15:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Copper	200	ug/L		01/06/22 09:26	1	3.0	01/06/22 13:08	KMC	EPA 200.8 REV 5.4
Lead	4.0	ug/L		01/06/22 09:26	1	1.0	01/06/22 13:08	KMC	EPA 200.8 REV 5.4

Sample: EL04058-82
Name: 47. Room 336
Alias: RBHS-336-CF-38

Sampled: 12/15/21 05:55
Received: 12/20/21 15:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Copper	300	ug/L		01/06/22 09:26	1	3.0	01/06/22 13:16	KMC	EPA 200.8 REV 5.4
Lead	11	ug/L		01/06/22 09:26	1	1.0	01/06/22 13:16	KMC	EPA 200.8 REV 5.4

Sample: EL04058-83
Name: 48. Room 336
Alias: RBHS-336-CF-39

Sampled: 12/15/21 05:53
Received: 12/20/21 15:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Copper	210	ug/L		01/06/22 09:26	1	3.0	01/06/22 13:17	KMC	EPA 200.8 REV 5.4
Lead	3.0	ug/L		01/06/22 09:26	1	1.0	01/06/22 13:17	KMC	EPA 200.8 REV 5.4

Sample: EL04058-84
Name: 52. Room 319
Alias: RBHS-319-CF-41

Sampled: 12/15/21 05:51
Received: 12/20/21 15:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Copper	64	ug/L		01/06/22 09:26	1	3.0	01/06/22 13:19	KMC	EPA 200.8 REV 5.4
Lead	3.4	ug/L		01/06/22 09:26	1	1.0	01/06/22 13:19	KMC	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: EL04058-85
Name: 53. Room 318
Alias: RBHS-318-CF-42


Sampled: 12/15/21 05:50
Received: 12/20/21 15:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Copper	87	ug/L		01/06/22 09:26	1	3.0	01/06/22 13:20	KMC	EPA 200.8 REV 5.4
Lead	1.1	ug/L		01/06/22 09:26	1	1.0	01/06/22 13:20	KMC	EPA 200.8 REV 5.4

Sample: EL04058-86
Name: 63. Kitchen South
Alias: RBHS-__-KF-2

Sampled: 12/15/21 05:48
Received: 12/20/21 15:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Copper	41	ug/L		01/06/22 09:26	1	3.0	01/06/22 13:22	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		01/06/22 09:26	1	1.0	01/06/22 13:22	KMC	EPA 200.8 REV 5.4



Missouri Department of dnr.mo.gov
NATURAL RESOURCES

Michael L. Parson, Governor

Dru Buntin, Director

January 6, 2022

Mr. Michael Travis
Corporate Director of Quality Assurance
Pace Analytical Services, LLC – Peoria, Illinois (Lab #870)
2231 West Altorfer Drive
Peoria, IL 61615-1807

Dear Mr. Travis:

The Missouri Department of Natural Resources has received your notification that PDC Laboratories, LLC was purchased by Pace Analytical Services, LLC effective December 13, 2021 and that the new laboratory name is Pace Analytical Services, LLC – Peoria, Illinois. The Department has also received a copy of the new Environmental Laboratory Accreditation granted by the State of Illinois with your new laboratory name. Therefore, the Department hereby reciprocally certifies Pace Analytical Services, LLC – Peoria, Illinois under the provisions of the Missouri Safe Drinking Water Regulations to perform chemical analyses for public water systems in the State of Missouri.

Enclosed please find a certificate of approval and a certified parameter list for your laboratory. The certified parameter list references the parameters and methods of analysis that the Department has approved. Your certification will expire on June 30, 2022, and is contingent upon no changes of the approved methods or equipment and maintenance of certification from the primary certification authority.

Thank you for your efforts to comply with Missouri's laboratory certification requirements. Should there be any changes to your Illinois certification status, please notify this office within 30 days. Direct any notifications or inquiries related to the approval to Lauren Ferland of my staff, who may be reached at P.O. Box 176, Jefferson City, MO 65102, or by telephone at 573-526-0135.

Sincerely,

WATER PROTECTION PROGRAM

David J. Lamb
Public Drinking Water Branch Chief

DJL/lf

Enclosures

c: Mr. Richard Kirsch, Environmental Services Program



MISSOURI DEPARTMENT OF NATURAL RESOURCES

DRINKING WATER LABORATORY

CERTIFIED PARAMETER LIST

This is to certify that

Pace Analytical Services, LLC
- Peoria, Illinois

located at

2231 West Altorfer Drive, Peoria, Illinois 61615-1807

has been approved to perform the indicated procedures on drinking water under the Missouri Public Drinking Water Regulations (10 CSR 60-5.020). Specific method numbers or references are included in parenthesis when appropriate.

INORGANIC

SM 4500F-C

Fluoride

EPA 245.1

Mercury

SM 4500NO3-F

Nitrate, Nitrite

EPA 300.0

Fluoride, Nitrate, Nitrite

EPA 200.7

Barium, Beryllium, Cadmium,
Chromium, Copper, Nickel

EPA 335.4

Total cyanide

EPA 200.8

Antimony, Arsenic, Barium, Beryllium,
Cadmium, Chromium, Copper, Lead,
Mercury, Nickel, Selenium, Thallium

EPA 353.2

Nitrate, Nitrite, Total Nitrate and Nitrite

ORGANIC

EPA 504.1

Dibromochloropropane (DBCP), Ethylene dibromide (EDB)

EPA 515.3

2,4-D, Dalapon, Dinoseb, Pentachlorophenol, Picloram, 2,4,5-TP (Silvex)

EPA 524.2

Benzene, Carbon tetrachloride, Monochlorobenzene, o-Dichlorobenzene, para-Dichlorobenzene, 1,2-Dichloroethane, 1,1-Dichloroethylene, cis-1-2-Dichloroethylene, trans-1-2-Dichloroethylene, Dichloromethane, 1,2-Dichloropropane, Ethylbenzene, Styrene, Tetrachloroethylene, Toluene, 1,2,4-Trichlorobenzene, 1,1,1-Trichloroethane, 1,1,2-Trichloroethane, Trichloroethylene, Vinyl Chloride, Xylenes (total), Bromodichloromethane, Bromoform, Chloroform, Dibromochloromethane, Total THMs

EPA 525.2

Alachlor, Atrazine, Chlordane, Di(2-ethylhexyl)adipate, Di(2-ethylhexyl)phthalate, Endrin, Heptachlor, Heptachlor Epoxide, Hexachlorobenzene, Hexachlorocyclopentadiene, Lindane, Methoxychlor, Simazine, Toxaphene, PCBs (as Aroclors, qualitative, screening)

EPA 531.1

Carbofuran, Oxamyl (Vydate)

EPA 547

Glyphosate

EPA 548.1

Endothall

EPA 549.2

Diquat

EPA 550

Benzo(a)pyrene

EPA 552.2

Dibromoacetic acid, Dichloroacetic acid, Monobromoacetic acid, Monochloroacetic acid, Trichloroacetic acid

Pace Analytical Services, LLC – Peoria, Illinois

Expiration Date: June 30, 2022

Missouri Certificate No.: 870

Original Certifying State: Illinois

State of Missouri
Department of Natural Resources

**Certificate of Approval
for Chemical Laboratory Service**

This is to certify that


Pace Analytical Services, LLC – Peoria, Illinois

is hereby approved to perform the analysis of drinking water as specified on the
Certified Parameter List, which must accompany this certificate to be valid.

Certification Number 870

Date Issued January 6, 2022

Expiration Date June 30, 2022



Laboratory Certification Authority, Public Drinking Water Branch
Missouri Department of Natural Resources



Certification Program Manager, Environmental Services Program
Missouri Department of Natural Resources