Lead in School Drinking Water Report

Emerson Elementary School

Date(s) collected: 2024-05-29
Date(s) analyzed: 2024-06-17

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371506	Main Building	Fountain /Tap Combo	Rm 210	1 of 1	Tap	center	2
389118	Main Building	Pot Filler	Kitchen	2 of 2	Tap	center	2
389124	Main Building	Sink	Rm 149a	1 of 1	Tap	center	2
371507	Main Building	Fountain /Tap Combo	Rm 134	1 of 1	Tap	center	1
371534	Main Building	Fountain /Tap Combo	Rm 131	1 of 1	Tap	center	1
371543	Portable 4/5	Fountain /Tap Combo	P4	1 of 1	Water Fountain	right	1
389116	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	right	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389130	Main Building	Fountain /Tap Combo	Rm 144	1 of 1	Tap	center	1
389132	Main Building	Fountain /Tap Combo	Rm 144	1 of 1	Water Fountain	right	1
371500	Main Building	Fountain /Tap Combo	Rm 208	1 of 1	Water Fountain	right	<1
371501	Main Building	Fountain /Tap Combo	Rm 133	1 of 1	Water Fountain	right	<1
371502	Main Building	Fountain	Between 208 And 210	1 of 2	Water Fountain	left	<1
371503	Main Building	Fountain /Tap Combo	Rm 135	1 of 1	Tap	center	<1
371504	Main Building	Fountain	Between 208 And 210	2 of 2	Water Fountain	right	<1
371505	Main Building	Fountain /Tap Combo	Rm 135	1 of 1	Water Fountain	right	<1
371508	Main Building	Fountain /Tap Combo	Rm 210	1 of 1	Water Fountain	right	<1
371509	Main Building	Fountain /Tap Combo	Rm 134	1 of 1	Water Fountain	right	<1
371510	Main Building	Fountain /Tap Combo	Rm 209	1 of 1	Tap	center	<1
371511	Main Building	Fountain	Between 134 And 136	1 of 1	Water Fountain	center	<1
371512	Main Building	Fountain /Tap Combo	Rm 209	1 of 1	Water Fountain	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371513	Main Building	Fountain /Tap Combo	Rm 136	1 of 1	Tap	center	<1
371514	Main Building	Fountain /Tap Combo	Rm 211	1 of 1	Tap	center	<1
371515	Main Building	Fountain /Tap Combo	Rm 136	1 of 1	Water Founta in	right	<1
371516	Main Building	Fountain /Tap Combo	Rm 211	1 of 1	Water Founta in	right	<1
371517	Main Building	Fountain /Tap Combo	Rm 137	1 of 1	Tap	center	<1
371518	Main Building	Fountain /Tap Combo	Rm 213	1 of 1	Tap	center	<1
371519	Main Building	Fountain /Tap Combo	Rm 137	1 of 1	Water Founta in	right	<1
371520	Main Building	Fountain /Tap Combo	Rm 213	1 of 1	Water Founta in	right	<1
371521	Main Building	Fountain /Tap Combo	Rm 141	1 of 1	Tap	center	<1
371522	Main Building	Sink	Rm 215	1 of 1	Tap	center	<1
371523	Main Building	Fountain /Tap Combo	Rm 141	1 of 1	Water Founta in	right	<1
371524	Main Building	Fountain /Tap Combo	Rm 214	1 of 1	Tap	center	<1
371525	Main Building	Fountain /Tap Combo	Rm 140	1 of 1	Tap	center	<1
371526	Main	Fountain	Rm 214	1 of 1	Water	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building	/Tap Combo			Fountain		
371527	Main Building	Fountain /Tap Combo	Rm 140	1 of 1	Water Fountain	right	<1
371528	Main Building	Fountain /Tap Combo	Rm 212	1 of 1	Tap	center	<1
371529	Main Building	Fountain /Tap Combo	Rm 138	1 of 1	Tap	center	<1
371530	Main Building	Fountain /Tap Combo	Rm 212	1 of 1	Water Fountain	right	<1
371531	Main Building	Fountain /Tap Combo	Rm 138	1 of 1	Water Fountain	right	<1
371532	Main Building	Sink	Library Workroom	1 of 1	Tap	center	<1
371533	Portable 2/3	Fountain /Tap Combo	P2	1 of 1	Tap	center	<1
371535	Portable 2/3	Fountain /Tap Combo	P2	1 of 1	Water Fountain	right	<1
371536	Main Building	Fountain /Tap Combo	Rm 131	1 of 1	Water Fountain	right	<1
371537	Portable 2/3	Fountain /Tap Combo	P3	1 of 1	Tap	center	<1
371538	Main Building	Fountain /Tap Combo	Rm 133	1 of 1	Tap	center	<1
371539	Portable 2/3	Fountain /Tap Combo	P3	1 of 1	Water Fountain	right	<1
371541	Portabl	Fountain	P4	1 of 1	Tap	center	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	e 4/5	/Tap Combo					
371545	Portable 4/5	Fountain /Tap Combo	P5	1 of 1	Tap	center	<1
371547	Portable 4/5	Fountain /Tap Combo	P5	1 of 1	Water Fountain	left	<1
371549	Portable 6/7	Fountain /Tap Combo	P6	1 of 1	Tap	center	<1
371551	Portable 6/7	Fountain /Tap Combo	P6	1 of 1	Water Fountain	right	<1
371553	Portable 6/7	Fountain /Tap Combo	P7	1 of 1	Tap	center	<1
371555	Portable 6/7	Fountain /Tap Combo	P7	1 of 1	Water Fountain	right	<1
389101	Main Building	Fountain /Tap Combo	Rm 125	1 of 1	Tap	center	<1
389103	Main Building	Fountain /Tap Combo	Rm 125	1 of 1	Water Fountain	right	<1
389105	Main Building	Fountain	Outside Rm 125	1 of 1	Water Fountain	center	<1
389107	Main Building	Fountain /Tap Combo	Rm 124	1 of 1	Tap	center	<1
389109	Main Building	Fountain /Tap Combo	Rm 124	1 of 1	Water Fountain	right	<1
389111	Main Building	Fountain	Between 124 And 123	1 of 1	Water Fountain	center	<1
389113	Main	Fountain	Rm 123	1 of 1	Tap	center	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building	/Tap Combo					
389114	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	left	<1
389115	Main Building	Fountain /Tap Combo	Rm 123	1 of 1	Water Fountain	right	<1
389117	Main Building	Fountain /Tap Combo	Rm 122	1 of 1	Tap	center	<1
389119	Main Building	Fountain /Tap Combo	Rm 122	1 of 1	Water Fountain	right	<1
389120	Main Building	Fountain	Gym	1 of 1	Water Fountain	center	<1
389121	Main Building	Fountain	Between 122 And 121	1 of 1	Water Fountain	center	<1
389122	Main Building	Fountain	Outside Gym Fountain	1 of 1	Water Fountain	center	<1
389123	Main Building	Fountain /Tap Combo	Rm 121	1 of 1	Tap	center	<1
389125	Main Building	Fountain /Tap Combo	Rm 121	1 of 1	Water Fountain	right	<1
389126	Main Building	Fountain	Cafeteria Hallway	1 of 2	Water Fountain	left	<1
389127	Main Building	Fountain /Tap Combo	Rm 120	1 of 1	Tap	center	<1
389128	Main Building	Fountain	Cafeteria	2 of 2	Water Founta	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
			Hallway		in		
389129	Main Building	Fountain /Tap Combo	Rm 120	1 of 1	Water Founta in	right	<1
389131	Main Building	Fountain /Tap Combo	Rm 204	1 of 1	Tap	center	<1
389133	Main Building	Fountain /Tap Combo	Rm 204	1 of 1	Water Founta in	right	<1
389134	Main Building	Sink	Health Rm 105	1 of 1	Tap	center	<1
389135	Main Building	Fountain /Tap Combo	Rm 207	1 of 1	Tap	center	<1
389136	Main Building	Fountain	Staff Lounge	1 of 1	Water Founta in	center	<1
389137	Main Building	Fountain /Tap Combo	Rm 207	1 of 1	Water Founta in	right	<1
389138	Main Building	Sink	Staff Lounge Kitchen	1 of 1	Tap	center	<1
389139	Main Building	Fountain /Tap Combo	Rm 208	1 of 1	Tap	center	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**