

- 1. Read the IAQ

 Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response requires
 further attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Building and Grounds Maintenance Checklist

Scl	me: Michele Williams 4 Tom Bingham nool: Charles Barnum om or Area: Date Completed: _7/18/24		
Ro	om or Area: Date Completed:	/	
Sig	gnature:		
1.	BUILDING MAINTENANCE SUPPLIES	No	Nt /
а. b.	Developed appropriate procedures and stocked supplies for spill control		
	Ensured that air from chemical and trash storage areas vents to the outdoors	, 5	
d _s	Stored chemical products and supplies in sealed, clearly labeled containers	/_	
	Researched and selected the safest products available	, <u> </u>	
g.	Ensured that chemicals, chemical-containing wastes, and containers are disposed of according to manufacturers' instructions.	 !	
h.	Substituted less- or non-hazardous materials (where possible)	/	
j.	when the school is unoccupied	/=	Ε
J -	hazardous chemicals	コ	
2.	GROUNDS MAINTENANCE SUPPLIES		
	Stored grounds maintenance supplies in appropriate area(s)	コ	
	instructions Established and followed procedures to minimize exposure to fumes		
	from supplies		
	Replaced portable gas cans with low-emission cans Stored chemical products and supplies in sealed, clearly-labeled		5
	containers	٦	
2 g .	disposed of according to manufacturers' instructions		
3.	DUST CONTROL	<i>'</i>	
3a. 3b.	Installed and maintained barrier mats for entrances Used high efficiency vacuum bags	, _ , _	J
3c.	Used proper dusting techniques		

3e. Cleaned air return grilles and air supply vents

4.	FLOOR CLEANING Yes/	No N/A	
4b.	Established and followed schedule for vacuuming and mopping floors Cleaned spills on floors promptly (as necessary) Performed restorative maintenance (as necessary)		
5.	DRAIN TRAPS		
5b.	Poured water down floor drains once per week (about 1 quart of water) Ran water in sinks at least once per week (about 2 cups of water) Flushed toilets once each week (if not used regularly)		6-01-
6.	MOISTURE, LEAKS, AND SPILLS	/	
6a.	Checked for moldy odors	□ d ,	
6b.	Inspected ceiling tiles, floors, and walls for leaks or discoloration (may indicate periodic leaks)		
6c.	Checked areas where moisture is commonly generated (e.g., kitchens, locker rooms, and bathrooms)	□ 1 ,	
6d	Checked that windows, windowsills, and window frames are free of condensate	p 1	
6e.	Checked that indoor surfaces of exterior walls and cold water pipes are free of condensate		
6f	Ensured the following areas are free from signs of leaks and water damage:	1	
	Indoor areas near known roof or wall leaks		ű
-	Walls around leaky or broken windows	- 1 · 5	į.
J	Duct interiors near humidifiers, cooling coils, and outdoor air intakes	5 %	
7.	COMBUSTION APPLIANCES	,	
7a.	Checked for odors from combustion appliances	#/ •	
	Checked appliances for backdrafting (using chemical smoke)		
	Inspected exhaust components for leaks, disconnections, or deterioration	2/3	
8.	PEST CONTROL	ut.	
8a	Completed the Integrated Pest Management Checklist	∋n □	G



- 1. Read the IAQ
 Backgrounder and the Background
 Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Waste Management Checklist

Name: Ton Bingles
School: Charles Barnen
Room or Area: July - unde Date Completed: 700 15, 3024
Signature: 7-73

1.	WASTE MANAGEMENT	s I	No	N/A
la.	Ensured that waste containers are appropriate for use (for example, food waste containers should have lids)	/		
1b.	Ensured that waste containers are lined			
lc.	Ensured that waste from art, science, vocational classes, etc., are handled separately	1		٦
1 d.	Labeled recycling bins clearly	,		
	Ensured number of bins and dumpsters is adequate			
1 f.	Ensured appropriate location of dumpsters (i.e., away from air intakes, doors, and operable windows in relation to prevailing winds)	1		a
1 g.	Ensured waste containers are emptied regularly	,		
1h.	Ensured appropriate waste removal schedule	,		
1i.	Ensured waste is stored in a well-ventilated room	,		
1j.	Ensured any exhaust fans in the room are operating properly	-		
1k.	Checked waste storage areas for odors, contaminants, or signs of vermin	-		




- Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 this checklist for
 each ventilation
 unit in your school,
 as well as a
 copy for future
 reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Ventilation Checklist


Na	me: David Zuzuslu			_
Sch	OHATLES BArnom			
Un	it Ventilator/AHU No:			
Ro	om or Area: Date Completed: 7-10-2	20	24	
Sid	spature:			
Oig	mature.			
1.	OUTDOOR AIR INTAKES			
la.	Marked locations of all outdoor air intakes on a small floor plan (for example, a fire escape floor plan)		No □	N/A
1 b.	Ensured that the ventilation system was on and operating in "occupied" mode	×		`
AC	TIVITY 1: OBSTRUCTIONS			
	Ensured that outdoor air intakes are clear of obstructions, debris, clogs,			
1.d	Installed corrective devices as necessary (e.g., if snowdrifts or leaves	Ø.		J
14.	,		۵	Ą
AC	TIVITY 2: POLLUTANT SOURCES			
le.	Checked ground-level intakes for pollutant sources (dumpsters, loading	her:	_	_
1 F	docks, and bus-idling areas)	12 1,	ш	٦
	toilet, or laboratory exhaust fans; puddles; and mist from		_	_
lα	air-conditioning cooling towers)	123		J
ıg.		4		_
AC	TIVITY 3: AIRFLOW			
1h.	Obtained chemical smoke (or a small piece of tissue paper or light plastic)			\supset
li∍	Confirmed that outdoor air is entering the intake appropriately	X		
2.	SYSTEM CLEANLINESS			
	TIVITY 4: AIR FILTERS	,		
	replaced inters per maintenance somedate	Ø.]
26.	Shut off ventilation system fans while replacing filters (prevents dirt from blowing downstream)	Ø		٦
2c.	•	X	3	٦
2d.	Confirmed proper fit of filters to prevent air from bypassing (flowing around) the air filter	Z	<u> </u>	\neg
2e.	Confirmed proper installation of filters (correct direction for airflow)			

2. SYSTEM CLEANLINESS (continued)

.CTIVITY 5: DRAIN PANS 2f. Ensured that drain pans slant toward the drain (to prevent water from Yes No N/A 2g. Cleaned drain pans 2h. Checked drain pans for mold and mildew **ACTIVITY 6: COILS** \Box **ACTIVITY 7: AIR-HANDLING UNITS, UNIT VENTILATORS** 2j. Ensured that the interior of air-handling unit(s) or unit ventilator 2k. Ensured that ducts are clean **ACTIVITY 8: MECHANICAL ROOMS** 2m. Ensured that mechanical rooms and air-mixing chambers are free of trash, chemical products, and supplies 3. CONTROLS FOR OUTDOOR AIR SUPPLY 3a. Ensured that air dampers are at least partially open (minimum position) 3b. Ensured that minimum position provides adequate outdoor air **ACTIVITY 9: CONTROLS INFORMATION** 3c. Obtained and reviewed all design inside/outside temperature and humidity requirements, controls specifications, as-built mechanical drawings, and controls operations manuals (often uniquely designed) **ACTIVITY 10: CLOCKS, TIMERS, SWITCHES** 3f. Ensured that settings fit the actual schedule of building use (including **ACTIVITY 11: CONTROL COMPONENTS** 3g. Ensured appropriate system pressure by testing line pressure at both the occupied (day) setting and the unoccupied (night) setting 3h. Checked that the line dryer prevents moisture buildup 3i. Replaced control system filters at the compressor inlet based on the compressor manufacturer's recommendation (for example, when you blow down the tank)...... 3i. Set the line pressure at each thermostat and damper actuator at the proper level (no leakage or obstructions) \Box **ACTIVITY 12: OUTDOOR AIR DAMPERS** 1. Ensured that the recirculating relief and/or exhaust dampers are visible 3m. Ensured that air temperature in the indoor area(s) served by each



NOTE: It is necessary to ensure that the damper is operating properly and within the normal range to continue.




3.	CONTROLS FOR OUTDOOR AIR SUPPLY (continued)		
3n.	Checked that the outdoor air damper fully closes within a few minutes of shutting off appropriate air handler	No □	N/A
30.	Checked that the outdoor air damper opens (at least partially with no delay) when the air handler is turned on		コ
	If in heating mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room thermostat is set to 85°F	9	٦
	If in cooling mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room thermostat is set to 60°F and mixed air thermostat is set to 45°F	٦	٦
3r.	 The damper actuator links to the damper shaft, and any linkage set screws or bolts are tight		4 四日
Pro	ceed to Activities 13–16 if the damper seems to be operating properly.		
3s.	TIVITY 13: FREEZE STATS Disconnected power to controls (for automatic reset only) to test continuity across terminals	_	Ð
OR 3t.		٥	to
3u.	Assessed the feasibility of replacing all manual reset freeze-stats with automatic reset freeze-stats		\$
clos	TE: HVAC systems with water coils need protection from the cold. The freeze-stose the outdoor air damper and disconnect the supply air when tripped. The typic ge is $35^{\circ}F$ to $42^{\circ}F$.		
AC	TIVITY 14: MIXED AIR THERMOSTATS		
3 v.	Ensured that the mixed air stat for heating mode is set no higher than 65°F	٦	٦
3w.	Ensured that the mixed air stat for cooling mode is set no lower than the room thermostat setting		٦
10	TIVITY 15: ECONOMIZERS		
	Confirmed proper economizer settings based on design specifications or local practices		٦
NO	TE: The dry-bulb is typically set at 65°F or lower.		
	Checked that sensor on the economizer is shielded from direct sunlight		
loa Drj and	TE. Economizers use varying amounts of cool outdoor air to assist with the cood of the room or rooms. There are two types of economizers, dry-bulb and enthaty-bulb economizers vary the amount of outdoor air based on outdoor temperated enthalpy economizers vary the amount of outdoor air based on outdoor temperated humidity level.	oling lpy re,	

3. CONTROLS FOR OUTDOOR AIR SUPPLY (continued) CTIVITY 16: FANS 3aa. Ensured that all fans (supply fans and associated return or relief fans) Yes No N/A that move outside air indoors continuously operate during occupied hours (even when room thermostat is satisfied) NOTE: If fan shuts off when the thermostat is satisfied, adjust control cycle as necessary to ensure sufficient outdoor air supply. 4. AIR DISTRIBUTION **ACTIVITY 17: AIR DISTRIBUTION** 4a. Ensured that supply and return air pathways in the existing ventilation system 4b. Ensured that passive gravity relief ventilation systems and transfer grilles between rooms and corridors are functioning ________ NOTE: If ventilation system is closed or blocked to meet current fire codes, consult with a professional engineer for remedies. 4c. Made sure every occupied space has supply of outdoor air (mechanical system or operable windows) 4d. Ensured that supply and return vents are open and unblocked NOTE: If outlets have been blocked intentionally to correct drafts or discomfort, investigate and correct the cause of the discomfort and reopen the vents. 4e. Modified the HVAC system to supply outside air to areas without an outdoor Modified existing HVAC systems to incorporate any room or zone layout 4g. Moved all barriers (for example, room dividers, large free-standing blackboards or displays, bookshelves) that could block movement of air in the room, especially those blocking air vents 4h. Ensured that unit ventilators are quiet enough to accommodate classroom 4i. Ensured that classrooms are free of uncomfortable drafts produced by air **' ACTIVITY 18: PRESSURIZATION IN BUILDINGS** NOTE: To prevent infiltration of outdoor pollutants, the ventilation system is designed to maintain positive pressurization in the building. Therefore, ensure that the system, including any exhaust fans, is operating on the "occupied" cycle when doing this activity. 4j. Ensured that air flows out of the building (using chemical smoke) through windows, doors, or other cracks and holes in exterior wall (for example, 5. EXHAUST SYSTEMS **ACTIVITY 19: EXHAUST FAN OPERATION** If fans are running but air is not flowing toward the exhaust intake, check for the following: • Inoperable dampers · Obstructed, leaky, or disconnected ductwork

Undersized or improperly installed fan

· Broken fan belt





5. EXHAUST SYSTEMS (continued)

ACTIVITY 20: EXHAUST AIRFLOW

NOTE: Prevent migration of indoor contaminants from areas such as bathrooms, kitchens, and labs by keeping them under negative pressure (as compared to surrounding spaces).

5b.	Checked (using chemical smoke) that air is drawn into the room from adjacent spaces		No	N/A □
	nd outside the room with the door slightly open while checking airflow high door opening (see "How to Measure Airflow").	and l	ow ii	1
5c.	Ensured that air is flowing toward the exhaust intake	Ø		
	TIVITY 21: EXHAUST DUCTWORK Checked that the exhaust ductwork downstream of the exhaust fan (which i under positive pressure) is sealed and in good condition		a	
6.	QUANTITY OF OUTDOOR AIR			
AC	TIVITY 22: OUTDOOR AIR MEASUREMENTS AND CALCULATIO	NS		
NO	TE: Refer to "How to Measure Airflow" for techniques.			
6a.	Measured the quantity of outdoor air supplied (22a) to each ventilation unit	🗀		B
6b.	Calculated the number of occupants served (22b) by the ventilation unit under consideration			Z
6c.	Divided outdoor air supply (22a) by the number of occupants (22b) to determine the existing quantity of outdoor air supply per person (22c)	<u></u> _	٦	Ø
AC	TIVITY 23: ACCEPTABLE LEVELS OF OUTDOOR AIR QUANTITI	ES		
6d.	Compared the existing outdoor air per person (22c) to the recommended levels in Table 1		_	æ
6e.	Corrected problems with ventilation units that supplied inadequate quantities of outdoor air to ensure that outdoor air quantities (22c) meet the recommended levels in Table 1	🗅		Þ



Walkthrough Inspection Checklist

Name: Christina Pos	
School: Charles Dame	un.
Room or Area:	Date Completed: 5/6/24
Signature:	

Instructions

- Read the IAQ Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

1.	GROUND LEVEL	Yes J	Ma	N/Δ
la,	Ensured that ventilation units operate properly			٠,,,
	Ensured there are no obstructions blocking air intakes			⊐
	Checked for nests and droppings near outdoor air intakes	ॼ	J	コ
	Determined that dumpsters are located away from doors, windows, and outdoor air intakes		۵	٦
le.	Checked potential sources of air contaminants near the building	-/		_
lf.	(chimneys, stacks, industrial plants, exhaust from nearby buildings)			
	Ensured that vehicles avoid idling near outdoor air intakes Minimized pesticide application		7	7
	Ensured that there is proper drainage away from the building (including	🕶 ,	, 	_
	roof downspouts)	a		
li.	Ensured that sprinklers spray away from the building and outdoor			1
	air intakes			2
lj.	Ensured that walk-off mats are used at exterior entrances and that they are cleaned regularly		′¬	_
	they are cleaned regularly			_
2.	ROOF			
Whi	ile on the roof, consider inspecting the HVAC units (use the Ventilation Che	cklist)	9	
2a.	Ensured that the roof is in good condition		7	
	Checked for evidence of water ponding		3	í l
	Checked that ventilation units operate properly (air flows in)		A]
	Ensured that exhaust fans operate properly (air flows out)		Z	
	Ensured that air intakes remain open, even at minimum setting		<u> </u>	
	Checked for nests and droppings near outdoor air intakes	,,,,	\exists	
2g.	Ensured that air from plumbing stacks and exhaust outlets flows away		_	_
	from outdoor air intakes	****	Z	J
3.	ATTIC			
3a.	Checked for evidence of roof and plumbing leaks	₫	J	\supset
3Ь.	Checked for birds and animal nests		a	⊐
4.	GENERAL CONSIDERATIONS			
4a	Ensured that temperature and humidity are maintained within			
	acceptable ranges	347	-d	⊐
4b.	Ensured that no obstructions exist in supply and exhaust vents	_	J	コ
	Checked for odors			\supset
4d.	Checked for signs of mold and mildew growth	🗹	\Box	\Box

4e. 4f. 4g. 5 .	Checked for signs of water damage	च च च	0 0 0	ī	
6	Water is poured into sinks at least once per week (about 2 cups of water) Toilets are flushed at least once per week MAINTENANCE SUPPLIES	2		<u> </u>	
6a. 6b. 6c.	Ensured that chemicals are used only with adequate ventilation and when building is unoccupied	1	ם ם		
7a. 7b. 7c.	Combustion appliances Checked for combustion gas and fuel odors Ensured that combustion appliances have flues or exhaust hoods. Checked for leaks, disconnections, and deterioration. Ensured there is no soot on inside or outside of flue components.	3 3 3	מחם		Deterioration of Boiler
8a.	OTHER Checked for peeling and flaking paint (if the building was built before 1980, this could be a lead hazard) Determined date of last radon test		٥	_ _	many locations have pecling paint
, 5	Roof needs to be replaced Standing water in our condition in library Name locations of puckers paint many water marks from I in cuttings				şc s



- 1. Read the IAQ
 Backgrounder and the Background
 Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
 - Make comments in the "Notes" section as necessary.
- Return the checklist portion of this document to the IAQ Coordinator.

Integrated Pest Management Checklist

Sc	me: Charles VARNER hool: Barnum Elementury com or Area: Date Completed: Nov 15, 2 gnature: Charles VARNER	202	24	
1.	OFFICIAL POLICY STATEMENT	es	No	N/A
la.	Developed or located the school's official policy statement for integrated pest management (IPM)	<u> </u>	コ	
2.	DESIGNATING PEST MANAGEMENT ROLES			
2a.	Assigned and trained a qualified person to be the pest manager	4	J	
2b.	Involved decision makers in the IPM program	Z)	
2C.	and asked them to keep their areas clean and free of clutter	6	\supset	
2dr	Encouraged parents to learn about IPM practices and implement them	6	_	
2e.	Developed a program to educate and train all IPM participants	7		
	Included language about IPM into contracts with pest management professionals	1	コ	
3.	SETTING PEST MANAGEMENT OBJECTIVES			
3a.	Set appropriate pest management objectives for school buildings (such as		,	
	preventing pests from interfering with students' learning environment and preserving the integrity of the building structure)	1	\Box	
3b.	Set appropriate pest management objectives for school grounds (such as	_		
	providing safe playing areas and the best athletic surfaces possible)	D		
4.	INSPECTING, IDENTIFYING, AND MONITORING			
4a.	Inspected all buildings and grounds for pest evidence, entry points,	7		
	food, water, and harborage sites			_
4b. 4c.		1		
	Monitored to determine the extent of pest problems and to estimate pest	T /		
	populations	Ø	\supset	
4e.	Developed plans to modify habitat (for example, exclusion, repair, and sanitation efforts) to prevent or resolve any pest problems	Z		Ţ
4f.		_	, -	

estimate pest population levels and identify evidence of pests and

5.	SETTING ACTION THRESHOLDS			
Ţ	Evaluated all available data obtained through inspecting, identifying, and monitoring		No □	N/A
5b.	Determined how many pests the school buildings, grounds. and occupants can tolerate		á,	
5c.	Set action thresholds	<u>A</u>	A	
6.	PREVENTIVE STRATEGIES			
INI	DOOR SITES			
6a.	Implemented appropriate strategies to prevent pests from inhabiting the fo	llowir	g are	eas:
	• Entryways	/		
	• Classrooms	🗹	\supset	
	• Gymnasiums			
	• Locker rooms	🖵		
	• Offices		\supset	
	• Staff lounges	🗹		
	• Bathrooms	() P ()	\Box	
	• Food preparation and serving areas	· P		
	• Rooms with extensive plumbing	Į		
	Maintenance areas	P		
	• Other	그		
οU	TDOOR SITES			
б b.	Implemented appropriate strategies to prevent pests from inhabiting the fo		ng are	east
)	• Playgrounds			
	• Parking lots			
	• Lawns and athletic fields			
	• Teaching gardens or greenhouses	<u>A</u>		
	• Loading docks			
	• Dumpsters			
	Areas with ornamental shrubs and trees Other		J	0
7.	PESTICIDE USE AND STORAGE			
	Explored alternative pest management methods before concluding that	,		
	pesticides were necessary	I	\Box	
7b.	Ensured that pest management professionals integrate IPM into their pest management methods		٦	
7c.	Identified the least toxic, target-specific chemical (or pesticide			
	formulation) that is the most effective to address the pest problem, preferably as baitsand granules	<u>a</u>	\supset	
7d.	Reviewed and followed all label instructions on pesticides and learned how to properly apply and handle these chemicals	₹		
7e.	Used spot-treatment (or bait, crack, and crevice applications) to apply			
	pesticides whenever possible and only treated the obviously infested	1		_
	plants in the area	-		
	Used protective clothing or equipment when applying pesticides	1		
7g	Placed all pesticides in tamper-resistant bait boxes or locations that are	1	_	
3	inaccessible to children and non-target species	#		4






7.	PESTICIDE USE AND STORAGE (cont.)			
	Locked or fastened lids of all bait boxes and placed bait away from the runway of the box	Yes . 🛭	No □	N/A
7i.	Applied pesticides when occupants were not present or in areas where they would not be exposed to the chemicals	. <u>d</u>	\supset	۵
7j.	Ensured that school occupants (students and staff) are notified of upcoming pesticide applications through posted notices and/or letters	A		_
7k	Ensured that parents are notified of upcoming pesticide applications through letters	1		
71.	Kept copies of current pesticide labels and information on pesticides easily accessible	. Z	\Box	
7m.	Stored pesticides off site or in areas that are locked and accessible only to designated personnel	🗹	٦	
	Ensured that storage areas are adequately ventilated and are located away from areas prone to flooding or where spills or leaks may contaminate the environment			
7p.	Ensured that pesticides are stored in their original containers and all lids are securely fastened	21		۵
7q.	Ensured that air in the storage space cannot mix with the air in the central ventilation system	⊿	\supset	
	ii ii			

8. EVALUATING RESULTS AND RECORD KEEPING

8a. Ensured that accurate, up-to-date records of IPM practices and a pest

oa.	Ensured that accurate, up-to-date records of it w practices and a pest		
	management log for each property are kept		
	Ensured that pesticide records necessary to meet all state, local, and school board requirements are maintained	\supset	
8c.	Ensured that each log book contains the following items:		
	• Copy of the pest management plan		
	• Service schedules for maintenance of buildings and grounds	\supset	
	• Current EPA-registered labels	\supset	
	• Current Material Safety Data Sheets (MSDS) for each pesticide project		
	Pest surveillance data sheets		□



- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.


Food Service Checklist

	ood Service Checkhat			
Na	me: ErviE Koschmieden			
Scl	hool:CB	, 1		
Ro	om or Area: KiTCHew Date Completed: 7/	11/2	24	
Sic	gnature: 6 1/	-20 A	/	
3,6	min houlement			
1.	COOKING AREA			
la.	Determined that local exhaust fans operate properly (note if fans are excessively noisy)	Yes ₃	No □	N/A
	Checked for odors near cooking. preparation, and eating areas	I		
	Ensured that exhaust fans are used whenever cooking, washing dishes, and cleaning		٦	а
	Determined that gas appliances function properly			
	Verified that gas appliances are vented outdoors	🗆		پ
	Ensured there are no combustion gas or natural gas odors, leaks, backdrafting, or headaches when gas appliances are used Ensured that kitchen is clean after use		_	٩
_	Checked for signs of microbiological growth in the kitchen, including	100	_	
1i.	the upper walls and ceiling (for example, mold, slime, and algae)	1	']	
	manufacturer's directions for use, and carefully reviewed the method of application	₩ ₹		
1j.	Verified the kitchen is free of plumbing and ceiling leaks (signs include stains, discoloration, and damp areas)	⊋∕		
2.	FOOD HANDLING AND STORAGE			
2a.	Checked food preparation, cooking, and storage areas for signs of insects		_	
	and vermin (for example, feces or remains)			
	surfaces			
	Ensured that food preparation, cooking, and storage practices are sanitary			
	Disposed of food scraps properly and removed crumbs		٦	
2e.	Cleaned counters with soap and water or a disinfectant (according to school policy)			
2f.	Swept and wet mopped floors			
3.	WASTE MANAGEMENT			
3a.	Selected and placed waste in appropriate containers	D	_ _	
3b.	Ensured that containers' lids are securely closed			
3c.	Separated food waste and food-contaminated items from other wastes,		. ¬	_
3d-	if possible		~]	٥
	Ensured that dumpsters are properly located (away from air intake	or te	_	

vents, operable windows, and food service doors in relation to

prevailing winds)

4.	DELIVERIES	Yes	No	N/A	
1.	Instructed vendors to avoid idling their engines during deliveries		' ם	Ċ	
	Posted a sign prohibiting vehicles from idling their engines in receiving areas	그	3	/ a	
4c.	Ensured that doors or air barriers are closed between receiving area and kitchen	¥	1	۵	



NOTES

KITCHEN IS Very Limited.