

Facility or Building Name	Jenny Lind Elementary
Did the facility test using the MDH testing program (WIIN)? (Yes or No)	No
Facility Type (School or Child Care)	School
School ID Number or Child Care License Number	0001-03-151
Facility or Building Address	5025 Bryant Ave North,
Mailing Address	1225 North 7th Street Minneapolis,
Contact Person	Lee Setter
Title	Manager, EH&S
Phone	612-668-0308
Email	Lee.Setter@mpls.k12.mn.us
Lead Related Website (if applicable-required for schools)	https://www.mpschools.org/depart

SUMMARY	ANSWER
Total number of samples	50
Total number of fixtures sampled	50
Total number of results above 5 ppb	0
Total number of remediation actions	0
Next Scheduled Sampling Date (Month/Year)	11/2029

Unique Sample	Fixture Type	Location Description	Fixture Status	Sample	Laboratory	Date/Time	Date/Time	Numeric	Unit of	Name of	Remediation Action	Other	Was Remediation	Additional Notes or Comments
0001-03-151-01	Drinking Fountain	Cafeteria 141 DF Left	Active - Consumption	Initial - First Draw	24-14536	11/22/2024 3:30	12/7/2024 13:32	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-02	Drinking Fountain	Cafeteria 141 DF Right	Active - Consumption	Initial - First Draw	24-14537	11/22/2024 3:30	12/7/2024 13:50	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-03	Sink	Rm 146 Sink	Active - Consumption	Initial - First Draw	24-14538	11/22/2024 3:31	12/7/2024 14:12	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-04	Sink	Kitchen Wash Sink	Active - Consumption	Initial - First Draw	24-14539	11/22/2024 3:32	12/7/2024 14:18	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-05	Filtered bottle filler	Bath 139 Hallway FBF Left	Active - Consumption	Initial - First Draw	24-14540	11/22/2024 3:33	12/7/2024 14:24	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-06	Drinking Fountain	Bath 139 Hallway DF Right	Active - Consumption	Initial - First Draw	24-14541	11/22/2024 3:33	12/7/2024 14:30	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-07	Drinking Fountain	Rm 144 DF	Active - Consumption	Initial - First Draw	24-14542	11/22/2024 3:34	12/7/2024 14:36	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-08	Sink	Rm 134 Sink	Active - Consumption	Initial - First Draw	24-14543	11/22/2024 3:35	12/7/2024 14:42	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-09	Drinking Fountain	Gym 133 DF Left	Active - Consumption	Initial - First Draw	24-14544	11/22/2024 3:36	12/7/2024 14:48	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-10	Drinking Fountain	Gym 133 DF Right	Active - Consumption	Initial - First Draw	24-14545	11/22/2024 3:37	12/7/2024 14:54	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-11	Drinking Fountain	Gym 131 DF Left	Active - Consumption	Initial - First Draw	24-14546	11/22/2024 3:37	12/7/2024 15:00	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-12	Drinking Fountain	Gym 131 DF Right	Active - Consumption	Initial - First Draw	24-14547	11/22/2024 3:38	12/7/2024 15:18	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-13	Sink	Rm 130G Sink	Active - Consumption	Initial - First Draw	24-14548	11/22/2024 3:38	12/7/2024 15:36	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-14	Sink	Rm 130J Sink	Active - Consumption	Initial - First Draw	24-14549	11/22/2024 4:24	12/7/2024 15:42	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-15	Sink	Nurse Rm 130A Sink	Active - Consumption	Initial - First Draw	24-14550	11/22/2024 4:25	12/7/2024 15:48	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-16	Drinking Fountain	Rm 120 DF	Active - Consumption	Initial - First Draw	24-14551	11/22/2024 4:25	12/7/2024 15:54	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-17	Drinking Fountain	Rm 118 DF	Active - Consumption	Initial - First Draw	24-14552	11/22/2024 3:39	12/7/2024 16:00	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-18	Drinking Fountain	Rm 116 DF	Active - Consumption	Initial - First Draw	24-14553	11/22/2024 3:40	12/7/2024 16:06	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-19	Drinking Fountain	Rm 114 DF	Active - Consumption	Initial - First Draw	24-14554	11/22/2024 3:42	12/7/2024 16:12	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-20	Drinking Fountain	Rm 104 DF	Active - Consumption	Initial - First Draw	24-14555	11/22/2024 3:43	12/7/2024 16:18	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-21	Drinking Fountain	Rm 102 DF	Active - Consumption	Initial - First Draw	24-14556	11/22/2024 3:44	12/7/2024 16:24	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-22	Drinking Fountain	Rm 098 DF	Active - Consumption	Initial - First Draw	24-14557	11/22/2024 3:45	12/7/2024 16:53	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-23	Drinking Fountain	Rm 101 DF	Active - Consumption	Initial - First Draw	24-14558	11/22/2024 3:46	12/7/2024 17:11	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-24	Drinking Fountain	Rm 103 DF	Active - Consumption	Initial - First Draw	24-14559	11/22/2024 3:47	12/7/2024 17:17	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-25	Drinking Fountain	Rm 105 DF	Active - Consumption	Initial - First Draw	24-14560	11/22/2024 3:48	12/7/2024 17:23	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-26	Drinking Fountain	Bath 107 Hallway DF Right	Active - Consumption	Initial - First Draw	24-14561	11/22/2024 3:49	12/7/2024 17:29	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-27	Drinking Fountain	Bath 107 Hallway DF Left	Active - Consumption	Initial - First Draw	24-14562	11/22/2024 3:51	12/7/2024 17:35	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-28	Drinking Fountain	Rm 201 DF	Active - Consumption	Initial - First Draw	24-14563	11/22/2024 3:51	12/7/2024 17:41	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-29	Drinking Fountain	Rm 203 DF	Active - Consumption	Initial - First Draw	24-14564	11/22/2024 3:52	12/7/2024 17:47	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-30	Drinking Fountain	Rm 205 DF	Active - Consumption	Initial - First Draw	24-14565	11/22/2024 3:53	12/7/2024 17:53	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-31	Drinking Fountain	Bath 207 Hallway DF Right	Active - Consumption	Initial - First Draw	24-14566	11/22/2024 3:54	12/7/2024 17:59	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-32	Drinking Fountain	Bath 207 Hallway DF Left	Active - Consumption	Initial - First Draw	24-14567	11/22/2024 3:55	12/9/2024 10:37	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-33	Drinking Fountain	Rm 204 DF	Active - Consumption	Initial - First Draw	24-14568	11/22/2024 3:55	12/9/2024 10:57	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-34	Drinking Fountain	Rm 206 DF	Active - Consumption	Initial - First Draw	24-14569	11/22/2024 3:56	12/9/2024 11:03	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-35	Drinking Fountain	Rm 212 DF	Active - Consumption	Initial - First Draw	24-14570	11/22/2024 3:57	12/9/2024 11:09	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-36	Drinking Fountain	Rm 214 DF	Active - Consumption	Initial - First Draw	24-14571	11/22/2024 3:58	12/9/2024 11:15	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-37	Drinking Fountain	Rm 216 DF	Active - Consumption	Initial - First Draw	24-14572	11/22/2024 3:59	12/9/2024 11:22	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-38	Drinking Fountain	Rm 220 DF	Active - Consumption	Initial - First Draw	24-14573	11/22/2024 4:12	12/9/2024 11:28	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-39	Drinking Fountain	Rm 230 DF	Active - Consumption	Initial - First Draw	24-14574	11/22/2024 4:14	12/9/2024 11:34	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-40	Drinking Fountain	Rm 232 DF	Active - Consumption	Initial - First Draw	24-14575	11/22/2024 4:15	12/9/2024 11:40	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-41	Drinking Fountain	Rm 236 DF	Active - Consumption	Initial - First Draw	24-14576	11/22/2024 4:16	12/9/2024 11:46	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-42	Drinking Fountain	Rm 238 DF	Active - Consumption	Initial - First Draw	24-14577	11/22/2024 4:17	12/9/2024 12:04	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-43	Drinking Fountain	Rm 244 DF	Active - Consumption	Initial - First Draw	24-14578	11/22/2024 4:18	12/9/2024 12:22	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-44	Drinking Fountain	Rm 246 DF	Active - Consumption	Initial - First Draw	24-14579	11/22/2024 4:19	12/9/2024 12:28	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-45	Drinking Fountain	Rm 243 DF	Active - Consumption	Initial - First Draw	24-14580	11/22/2024 4:21	12/9/2024 12:34	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-46	Drinking Fountain	Rm 247 DF	Active - Consumption	Initial - First Draw	24-14581	11/22/2024 4:31	12/9/2024 12:40	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-47	Drinking Fountain	Rm 243 DF	Active - Consumption	Initial - First Draw	24-14582	11/22/2024 4:33	12/9/2024 12:46	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-48	Drinking Fountain	Bath 241 Hallway DF Left	Active - Consumption	Initial - First Draw	24-14583	11/22/2024 4:35	12/9/2024 12:52	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-49	Drinking Fountain	Bath 241 Hallway DF Right	Active - Consumption	Initial - First Draw	24-14584	11/22/2024 4:37	12/9/2024 12:58	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-151-50	Drinking Fountain	Rm 219 DF	Active - Consumption	Initial - First Draw	24-14585	11/22/2024 4:39	12/9/2024 13:04	ND	µg/L	Twin City Water Clinic, Inc.				

Definitions of Reporting Fields

Field Name	Response Needed or Definition	Where does this information come
Unique Sample Site Identification Number	A unique number or code using numbers and or letters that a facility assigns to each fixture in the building. This prevents confusion about which sample goes with which fixture.	Facility
Fixture Type	Describes the type of fixture such as sink, fountain, bottle filler, ice machine, kitchen kettle, coffee machine, etc..	Facility
Location Description	Specific description of the location of the fixture. Ex. Classroom sink in Room 112 or Left drinking fountain in gym	Facility
Fixture Status	Describes if the fixture is currently being used and how it is used. Examples are Active-Consumption, Inactive-Consumption, Active-Nonconsumption, Inactive-Nonconsumption	Facility
Sample Collection Type	Initial first draw, Initial Flushed, Follow-up First Draw, Follow-up Flushed, Other	Facility
Laboratory Identification Number	Number assigned by the laboratory to each sample. It may be helpful for facilities using this spreadsheet to cross reference to their lab results. (Optional)	Lab
Date/Time Collected	Date and time the sample was collected Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab
Date/Time Analyzed	Date and time the sample was analyzed Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab
Numeric Result	This is the number representing the result reported by the lab. Ex. 5.12, 7.03, 89.02, for results that are not detected please use ND	Lab
Unit of Measure	This is the unit of the result reported by the lab Ex. Parts per billion (ppb), micrograms per liter (ug/L).	Lab
Name of Laboratory Used For Analysis	The name of the laboratory used for sample analysis.	Lab
Remediation Action	Describes the type of remediation (if needed). Select from drop down menu. You only need to complete if result is 5ppb or more. If the action you took is not listed select OTHER and describe	Facility
Other Remediation-Please Describe	Use this field to type in your remediation action if the choice was not listed in the Remediation Action Drop down menu.	Facility
Was Remediation Successful (ie. Follow-up testing below 5 ppb)	Select from the drop down. Options are Yes, No, Not Applicable(N/A), and Pending Results	Facility

Other Important Terms	Definitions
Consumption	For the purposes of this testing consumption means a fixture where the water is used for drinking water or food/formula preparation.
Non-Consumption	A fixture that is not used for drinking water or food preparation such as a laboratory sink or a mop sink in a locked custodial closet. MDH recommends that non-consumption fixtures be labeled as not for drinking if they are not tested.
Active	A fixture currently able to be used.
Inactive	A fixture that has been taken out of service either temporarily or permanently
First Draw	A type of water sample where the water has been stagnant for 8-18 hours before collecting a sample. The most common type of lead sample type.
Flushed	A type of water sample where the water has been allowed to run before collecting. Typically collected when investigating to source of lead or evaluating remediation options.
Initial	This is typically a first draw sample collected during a round of monitoring. A sample may be an initial-first draw or an initial-flushed
Follow-up	This is typically collected if an initial sample collected during a round of sampling is 5ppb or more. Follow-up samples can be repeated first draw samples or flushed samples depending on the type of follow-up activities conducted to reduce lead.