

Lead in School Drinking Water Report

Rosalind Franklin Stem Elementary



Date(s) collected: 2024-05-01

Date(s) analyzed: 2024-05-16, 2024-05-20

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371311	Main Building	Pot Filler	Kitchen	5 of 5	Tap	center	3
371032	Main Building	Fountain	North Wing Outdoor	2 of 2	Water Fountain	right	2
371020	Main Building	Fountain/Tap Combo	Rm 119	1 of 2	Tap	right	<1
371021	Main Building	Sink - Multi-Compartment	210	1 of 1	Tap	center	<1
371022	Main Building	Sink - Multi-Compartment	Rm 119	2 of 2	Tap	center	<1
371023	Main Building	Fountain/Tap Combo	208	1 of 1	Tap	left	<1
371024	Main Building	Sink - Multi-Compartment	Rm 119	2 of 2	Sprayer	right	<1
371025	Main Building	Fountain/Tap Combo	208	1 of 1	Water Fountain	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371026	Main Building	Fountain	West Wing Outdoor	1 of 2	Water Fountain	left	<1
371027	Main Building	Fountain/Tap Combo	207	1 of 1	Water Fountain	left	<1
371028	Main Building	Fountain	West Wing Outdoor	2 of 2	Water Fountain	right	<1
371029	Main Building	Fountain/Tap Combo	207	1 of 1	Tap	right	<1
371030	Main Building	Fountain	North Wing Outdoor	1 of 2	Water Fountain	left	<1
371031	Main Building	Fountain	Outside 112	1 of 2	Water Fountain	left	<1
371033	Main Building	Fountain	Outside 112	2 of 2	Water Fountain	right	<1
371034	Main Building	Fountain/Tap Combo	201	1 of 1	Tap	left	<1
371035	Main Building	Sink	103	1 of 1	Tap	center	<1
371036	Main Building	Fountain/Tap Combo	201	1 of 1	Water Fountain	right	<1
371037	Main Building	Fountain/Tap Combo	112	1 of 1	Water Fountain	left	<1
371038	Main Building	Fountain/Tap Combo	Rm 214	1 of 1	Water Fountain	left	<1
371039	Main Building	Fountain/Tap Combo	112	1 of 1	Tap	right	<1
371040	Main Building	Fountain/Tap Combo	Rm 214	1 of 1	Tap	right	<1
371041	Main Building	Fountain/Tap Combo	104	1 of 1	Tap	left	<1
371042	Main Building	Fountain	Outside 202	1 of 2	Water Fountain	left	<1
371043	Main Building	Fountain/Tap Combo	104	1 of 1	Water Fountain	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371044	Main Building	Fountain	Outside 202	2 of 2	Water Fountain	right	<1
371045	Main Building	Fountain/Tap Combo	111	1 of 1	Water Fountain	left	<1
371046	Main Building	Sink - Multi-Compartment	202	1 of 1	Tap	center	<1
371047	Main Building	Fountain/Tap Combo	111	1 of 1	Tap	right	<1
371048	Main Building	Sink - Multi-Compartment	213	1 of 1	Tap	center	<1
371049	Main Building	Fountain/Tap Combo	105	1 of 1	Water Fountain	left	<1
371050	Main Building	Sink - Multi-Compartment	203	1 of 1	Tap	center	<1
371051	Main Building	Fountain/Tap Combo	105	1 of 1	Tap	right	<1
371052	Main Building	Sink - Multi-Compartment	212	1 of 1	Tap	center	<1
371053	Main Building	Fountain/Tap Combo	110	1 of 1	Tap	left	<1
371054	Main Building	Sink - Multi-Compartment	204	1 of 1	Tap	center	<1
371055	Main Building	Fountain/Tap Combo	110	1 of 1	Water Fountain	right	<1
371056	Main Building	Sink - Multi-Compartment	211	1 of 1	Tap	center	<1
371057	Main Building	Fountain/Tap Combo	106	1 of 1	Tap	left	<1
371058	Main Building	Sink - Multi-Compartment	205	1 of 1	Tap	center	<1
371059	Main Building	Fountain/Tap Combo	106	1 of 1	Water Fountain	right	<1
371300	Main Building	Fountain/Tap Combo	Rm 114	1 of 1	Water Fountain	right	<1
371301	Main Building	Sink - Multi-Compartment	Kitchen	2 of 5	Tap	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371302	Main Building	Fountain/Tap Combo	Rm 123	1 of 1	Water Fountain	left	<1
371303	Main Building	Sink - Multi-Compartment	Kitchen	2 of 5	Tap	right	<1
371304	Main Building	Fountain/Tap Combo	Rm 123	1 of 1	Tap	right	<1
371305	Main Building	Sink	Kitchen	3 of 5	Tap	center	<1
371306	Main Building	Fountain/Tap Combo	Rm 122	1 of 1	Water Fountain	left	<1
371307	Main Building	Sink	Kitchen	3 of 5	Sprayer	center	<1
371308	Main Building	Fountain/Tap Combo	Rm 122	1 of 1	Tap	right	<1
371309	Main Building	Sink	Kitchen	4 of 5	Tap	center	<1
371310	Main Building	Fountain/Tap Combo	Rm 115	1 of 1	Tap	left	<1
371312	Main Building	Fountain/Tap Combo	Rm 115	1 of 1	Water Fountain	right	<1
371313	Main Building	Fountain	By Room 110	1 of 1	Water Fountain	center	<1
371314	Main Building	Fountain/Tap Combo	Rm 121	1 of 1	Water Fountain	left	<1
371315	Main Building	Sink	Rm 110	1 of 1	Tap	center	<1
371316	Main Building	Fountain/Tap Combo	Rm 121	1 of 1	Tap	right	<1
371317	Main Building	Fountain	N Hallway By Gym	1 of 2	Water Fountain	left	<1
371318	Main Building	Fountain/Tap Combo	Rm 116	1 of 1	Tap	left	<1
371319	Main Building	Fountain - Multi-Level with Bottle Filler	N Hallway By Gym	2 of 2	Water Fountain	right	<1
371320	Main	Fountain/Tap	Rm 116	1 of 1	Water	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371321	Building	Combo			Fountain		
	Main Building	Fountain - Multi-Level with Bottle Filler	N Hallway Outside Gym	2 of 2	Water Bottle Filler	center	<1
371322	Main Building	Fountain/Tap Combo	Rm117	1 of 1	Tap	left	<1
371323	Main Building	Sink	Staff Lounge	1 of 1	Tap	center	<1
371324	Main Building	Fountain/Tap Combo	Rm 117	1 of 1	Water Fountain	right	<1
371325	Main Building	Fountain/Tap Combo	Nurse Room	1 of 1	Tap	left	<1
371326	Main Building	Fountain/Tap Combo	Rm 120	1 of 1	Water Fountain	left	<1
371327	Main Building	Fountain/Tap Combo	Nurse Room	1 of 1	Water Fountain	right	<1
371328	Main Building	Fountain/Tap Combo	Rm 120	1 of 1	Tap	right	<1
371329	Main Building	Fountain	Central Vestibule To Portables	1 of 2	Water Fountain	left	<1
371330	Main Building	Sink - Multi-Compartment	Rm 118	1 of 2	Tap	center	<1
371331	Main Building	Fountain	Central Vestibule To Portables	2 of 2	Water Fountain	right	<1
371332	Main Building	Sink - Multi-Compartment	Rm 118	1 of 2	Sprayer	right	<1
371333	Main Building	Sink	Library Office	1 of 1	Tap	center	<1
371334	Main Building	Fountain/Tap Combo	Rm 118	2 of 2	Tap	left	<1
371335	Main Building	Fountain	Outside Rm 113	1 of 2	Water Fountain	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371336	Main Building	Fountain/Tap Combo	Rm 118	2 of 2	Water Fountain	right	<1
371337	Main Building	Fountain	Outside Rm 113	2 of 2	Water Fountain	right	<1
371338	Main Building	Fountain/Tap Combo	Rm 119	1 of 2	Water Fountain	left	<1
371339	Main Building	Fountain/Tap Combo	Rm 114	1 of 1	Tap	left	<1
371341	Main Building	Fountain/Tap Combo	109	1 of 1	Water Fountain	left	<1
371343	Main Building	Fountain/Tap Combo	109	1 of 1	Tap	right	<1
371345	Main Building	Fountain/Tap Combo	107	1 of 1	Water Fountain	left	<1
371347	Main Building	Fountain/Tap Combo	107	1 of 1	Tap	right	<1
371349	Main Building	Fountain/Tap Combo	108	1 of 1	Tap	left	<1
371351	Main Building	Fountain/Tap Combo	108	1 of 1	Water Fountain	right	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**