

Lead in School Drinking Water Report

Ruth Livingston Elementary School



Date(s) collected: 2024-03-13

Date(s) analyzed: 2024-03-25, 2024-03-27

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371417	Main Building	Fountain/Tap Combo	B7	1 of 1	Tap	left	18
370783	Main Building	Fountain/Tap Combo	A5	2 of 2	Water Fountain	right	5
370807	Portable 2	Fountain/Tap Combo	Portable 2	1 of 1	Water Fountain	right	4
370784	Main Building	Fountain/Tap Combo	B1	1 of 1	Tap	left	3
370797	Main Building	Fountain/Tap Combo	A10	1 of 1	Tap	left	3
370801	Portable 4	Fountain/Tap Combo	Portable 4	1 of 1	Tap	right	2
370803	Portable 4	Fountain/Tap Combo	Portable 4	1 of 1	Water Fountain	right	2
370815	Portable 7	Fountain/Tap Combo	Portable 7	1 of 1	Water Fountain	right	2
370817	Portable	Sink	Portable 9	1 of 1	Tap	center	2

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	8/9						
371385	Main Building	Fountain/Tap Combo	C1	1 of 1	Tap	left	2
371389	Main Building	Fountain/Tap Combo	C2	1 of 1	Tap	left	2
371397	Main Building	Fountain	C Pod Hallway Fountain	1 of 1	Water Fountain	right	2
370795	Main Building	Fountain/Tap Combo	A9	1 of 1	Water Fountain	right	1
370796	Main Building	Fountain	B Pod Commons Hallway	1 of 1	Water Fountain	right	1
370808	Main Building	Fountain/Tap Combo	A2	1 of 1	Tap	left	1
370809	Portable 1	Fountain/Tap Combo	Portable 1	1 of 1	Tap	left	1
371395	Main Building	Fountain/Tap Combo	C3	1 of 1	Water Fountain	right	1
371399	Main Building	Fountain/Tap Combo	C9	1 of 1	Tap	left	1
371404	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Sprayer	left	1
371410	Main Building	Pot Filler	Kitchen	2 of 2	Tap	left	1
370780	Main Building	Fountain/Tap Combo	B6	1 of 1	Tap	left	<1
370781	Main Building	Fountain/Tap Combo	A5	2 of 2	Tap	left	<1
370782	Main Building	Fountain/Tap Combo	B6	1 of 1	Water Fountain	right	<1
370785	Main Building	Sink	A6	1 of 2	Tap	left	<1
370786	Main Building	Fountain/Tap Combo	B1	1 of 1	Water Fountain	right	<1
370787	Main Building	Fountain	A6	2 of 2	Water Fountain	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
370788	Main Building	Fountain/Tap Combo	B2	1 of 1	Tap	left	<1
370789	Main Building	Fountain/Tap Combo	A8	1 of 1	Tap	left	<1
370790	Main Building	Fountain/Tap Combo	B2	1 of 1	Water Fountain	right	<1
370791	Main Building	Fountain/Tap Combo	A8	1 of 1	Water Fountain	right	<1
370792	Main Building	Fountain/Tap Combo	B3	1 of 1	Tap	left	<1
370793	Main Building	Fountain/Tap Combo	A9	1 of 1	Tap	left	<1
370794	Main Building	Fountain/Tap Combo	B3	1 of 1	Water Fountain	right	<1
370798	Main Building	Fountain/Tap Combo	B Pod Commons	1 of 1	Tap	left	<1
370799	Main Building	Fountain/Tap Combo	A10	1 of 1	Water Fountain	right	<1
370800	Main Building	Fountain/Tap Combo	B 5	1 of 1	Tap	left	<1
370802	Main Building	Fountain/Tap Combo	B5	1 of 1	Water Fountain	right	<1
370804	Main Building	Fountain/Tap Combo	A1	1 of 1	Tap	left	<1
370805	Portable 2	Fountain/Tap Combo	Portable 2	1 of 1	Tap	left	<1
370806	Main Building	Fountain/Tap Combo	A1	1 of 1	Water Fountain	right	<1
370810	Main Building	Fountain/Tap Combo	A2	1 of 1	Water Fountain	right	<1
370811	Portable 1	Fountain/Tap Combo	Portable 1	1 of 1	Water Fountain	right	<1
370812	Main Building	Fountain/Tap Combo	A3	1 of 1	Tap	left	<1
370813	Portable 7	Fountain/Tap Combo	Portable 7	1 of 1	Tap	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
370814	Main Building	Fountain/Tap Combo	A3	1 of 1	Water Fountain	right	<1
370816	Main Building	Fountain/Tap Combo	A Commons	1 of 1	Tap	left	<1
370818	Main Building	Fountain	A Pod	1 of 2	Water Fountain	left	<1
370819	Portable 8/9	Sink	Portable 8	1 of 1	Tap	center	<1
370821	Portable 10/11	Sink	Portable 11	1 of 1	Tap	center	<1
370823	Portable 10/11	Sink	Portable 10	1 of 1	Tap	center	<1
370825	Portable 12/13	Fountain/Tap Combo	Portable 13	1 of 1	Tap	center	<1
370827	Portable 12/13	Fountain/Tap Combo	Portable 13	1 of 1	Water Fountain	right	<1
370829	Portable 12/13	Fountain/Tap Combo	Portable 12	1 of 1	Tap	center	<1
370831	Portable 12/13	Fountain/Tap Combo	Portable 12	1 of 1	Water Fountain	left	<1
371381	Main Building	Sink	Staff Lounge	1 of 1	Tap	center	<1
371383	Main Building	Sink	D1 Library Office	1 of 1	Tap	center	<1
371387	Main Building	Fountain/Tap Combo	C1	1 of 1	Water Fountain	right	<1
371391	Main Building	Fountain/Tap Combo	C2	1 of 1	Water Fountain	right	<1
371393	Main Building	Fountain/Tap Combo	C3	1 of 1	Tap	left	<1
371401	Main Building	Fountain/Tap Combo	C9	1 of 1	Water Fountain	right	<1
371403	Main Building	Fountain/Tap Combo	C5	1 of 1	Tap	left	<1
371405	Main Building	Fountain/Tap Combo	C5	1 of 1	Water Fountain	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371406	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	center	<1
371407	Main Building	Fountain/Tap Combo	C6	1 of 1	Tap	left	<1
371408	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	right	<1
371409	Main Building	Fountain/Tap Combo	C6	1 of 1	Water Fountain	right	<1
371411	Main Building	Fountain/Tap Combo	C7	1 of 1	Tap	left	<1
371412	Main Building	Pot Filler	Kitchen	2 of 2	Sprayer	center	<1
371413	Main Building	Fountain/Tap Combo	C7	1 of 1	Water Fountain	right	<1
371414	Main Building	Fountain	Cafeteria	1 of 1	Water Fountain	right	<1
371415	Main Building	Sink	D8	1 of 1	Tap	center	<1
371416	Main Building	Fountain	Gym	1 of 1	Water Fountain	right	<1
371418	Main Building	Sink	Health Room	1 of 1	Tap	center	<1
371419	Main Building	Fountain/Tap Combo	B7	1 of 1	Water Fountain	right	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**