

Lead in School Drinking Water Report

Edwin Markham Elementary School



Date(s) collected: 2024-02-29

Date(s) analyzed: 2024-03-13, 2024-03-14, 2024-03-19

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
371484	Main Building	Sink	Student Store Rm 66	1 of 1	Tap	5
371420	Main Building	Fountain/Tap Combo	Rm 1	1 of 1	Water Fountain	4
371477	Main Building	Sink	Library Office	1 of 1	Tap	4
371440	Portable 3/4	Fountain/Tap Combo	Portable 3	1 of 1	Water Fountain	3
371460	Main Building	Fountain/Tap Combo	Main Entrance Conference Rm	2 of 2	Tap	3
371472	Main Building	Sink - Multi-Compartment	Kitchen	2 of 4	Tap	3
371483	Main Building	Fountain/Tap Combo	Rm 5	1 of 1	Tap	3
371490	Main	Fountain/Tap	Rm 8	1 of 1	Tap	3

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
	Building	Combo				
371422	Main Building	Fountain/Tap Combo	Rm 2	1 of 1	Tap	2
371462	Main Building	Fountain/Tap Combo	Main Entrance Conference Rm	2 of 2	Water Fountain	2
371464	Main Building	Sink	Health Rm	1 of 1	Tap	2
371470	Main Building	Sink	Kitchen	1 of 4	Tap	2
371474	Main Building	Sink - Multi-Compartment	Kitchen	2 of 4	Tap	2
371478	Main Building	Pot Filler	Kitchen	4 of 4	Tap	2
371480	Main Building	Fountain/Tap Combo	Reading Recovery Rm 34	1 of 1	Tap	2
371482	Main Building	Fountain/Tap Combo	Reading Recovery Rm 34	1 of 1	Water Fountain	2
371486	Main Building	Fountain/Tap Combo	Rm 7	1 of 1	Tap	2
371488	Main Building	Fountain/Tap Combo	Rm 7	1 of 1	Water Fountain	2
371489	Main Building	Fountain/Tap Combo	Rm 4	1 of 1	Water Fountain	2
371492	Main Building	Fountain/Tap Combo	Rm 8	1 of 1	Water Fountain	2
371494	Main Building	Fountain/Tap Combo	Rm 9	1 of 1	Tap	2
371495	Main Building	Fountain/Tap Combo	Commons After Rm 3	1 of 1	Tap	2
371424	Main Building	Fountain/Tap Combo	Rm 2	1 of 1	Water Fountain	1
371426	Portable 1/2	Fountain/Tap Combo	Portable 2	1 of 1	Tap	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
371461	Main Building	Fountain	B Pod Commons	2 of 2	Water Fountain	1
371468	Main Building	Fountain	Cafeteria Restroom Fountain	1 of 1	Water Fountain	1
371469	Main Building	Fountain/Tap Combo	Rm 11	1 of 1	Water Fountain	1
371481	Main Building	Fountain/Tap Combo	Rm 6	1 of 1	Water Fountain	1
371485	Main Building	Fountain/Tap Combo	Rm 5	1 of 1	Water Fountain	1
371487	Main Building	Fountain/Tap Combo	Rm 4	1 of 1	Tap	1
371493	Main Building	Fountain/Tap Combo	Rm 3	1 of 1	Water Fountain	1
371497	Main Building	Fountain/Tap Combo	Commons After Rm 3	1 of 1	Water Fountain	1
371499	Main Building	Fountain/Tap Combo	Rm 1	1 of 1	Tap	1
371428	Portable 1/2	Fountain/Tap Combo	Portable 2	1 of 1	Water Fountain	<1
371430	Portable 1/2	Fountain/Tap Combo	Portable 1	1 of 1	Tap	<1
371432	Portable 1/2	Fountain/Tap Combo	Portable 1	1 of 1	Water Fountain	<1
371434	Portable 3/4	Fountain/Tap Combo	Portable 4	1 of 1	Tap	<1
371436	Portable 3/4	Fountain/Tap Combo	Portable 4	1 of 1	Water Fountain	<1
371438	Portable 3/4	Fountain/Tap Combo	Portable 3	1 of 1	Tap	<1
371444	Main Building	Other	Teacher Lounge	1 of 1	Other	<1
371463	Main Building	Fountain/Tap Combo	Rm 10	1 of 1	Tap	<1
371465	Main Building	Fountain/Tap Combo	Rm 10	1 of 1	Water Fountain	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
371466	Main Building	Sink	Staff Lounge	1 of 1	Tap	<1
371467	Main Building	Fountain/Tap Combo	Rm 11	1 of 1	Tap	<1
371471	Main Building	Fountain/Tap Combo	Rm 12	1 of 1	Tap	<1
371473	Main Building	Fountain/Tap Combo	Rm 12	1 of 1	Water Fountain	<1
371475	Main Building	Fountain	Library	1 of 1	Water Fountain	<1
371476	Main Building	Sink - Multi-Compartment	Kitchen	2 of 4	Sprayer	<1
371479	Main Building	Fountain/Tap Combo	Rm 6	1 of 1	Tap	<1
371491	Main Building	Fountain/Tap Combo	Rm 3	1 of 1	Tap	<1
371496	Main Building	Fountain/Tap Combo	Rm 9	1 of 1	Water Fountain	<1
371498	Main Building	Sink	B Pod Commons	1 of 2	Tap	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: leadfreekids@doh.wa.gov